

FILED  
October 15, 2025  
INDIANA UTILITY  
REGULATORY COMMISSION

STATE OF INDIANA

INDIANA UTILITY REGULATORY COMMISSION

IN THE MATTER OF THE PETITION OF )  
LAFAYETTE, INDIANA, FOR (1) AUTHORITY TO )  
ISSUE BONDS, NOTES, OR OTHER )  
OBLIGATIONS; (2) APPROVAL OF A SYSTEM )  
DEVELOPMENT CHARGE; (3) AUTHORITY TO ) CAUSE NO. 46310  
INCREASE ITS RATES AND CHARGES FOR )  
WATER SERVICE; AND (4) APPROVAL OF A NEW )  
SCHEDULE OF WATER RATES AND CHARGES )  
APPLICABLE THERETO )

**PETITIONER'S EXHIBIT 2**

VERIFIED DIRECT TESTIMONY

OF

ANDREW D. GORDON, P.E.

ON BEHALF OF

THE CITY OF LAFAYETTE, INDIANA

## I. INTRODUCTION

**Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

A. My name is Andrew D. Gordon. My business address is 6219 South East Street, Indianapolis, Indiana 46227.

**Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?**

A. I am employed by Wessler Engineering, Inc. (“Wessler Engineering”) as a Senior Project Manager II. Wessler Engineering has been my employer since June 2003.

**Q. ON WHOSE BEHALF ARE YOU TESTIFYING?**

9 A. I am testifying on behalf of the City of Lafayette, Indiana's municipal water utility  
10 ("Lafayette" or "Utility").

**Q. PLEASE DESCRIBE YOUR EDUCATIONAL AND PROFESSIONAL BACKGROUND.**

13 A. I attended Rose-Hulman Institute of Technology in Terre Haute, Indiana, and graduated  
14 with a Bachelor of Science in Civil Engineering degree in 2002. I obtained my Professional  
15 Engineer (“P.E.”) License, which was issued in January 2008. I am also a licensed water  
16 loss audit validator (license #WV220073) in the State of Indiana since May 2022. I acquire  
17 a minimum of 30 hours of continuing education every two years to fulfill the requirements  
18 to keep my P.E. license and my water loss audit validator’s certification.

19 As Senior Project Manager II, my duties include serving as the primary contact and liaison  
20 with clients, and overseeing the management of assigned projects to provide satisfactory  
21 professional engineering services. Some specific duties include: (1) overseeing and  
22 performing engineering studies and designs for developing plans; (2) developing  
23 specifications of projects; (3) maintaining effective communications throughout the

1 company and with clients; (4) supervising and mentoring project team members; and (5)  
2 reviewing work done on a project for technical and regulatory adequacy.

3 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE THE INDIANA UTILITY**  
4 **REGULATORY COMMISSION (“COMMISSION”), AND HOW DID YOU**  
5 **PREPARE FOR THIS CASE?**

6 A. I have not previously testified before the Commission. My preparations for this testimony  
7 included reviewing the testimony of Dreama E. Doolittle, P.E., filed in Lafayette's 2017  
8 rate case in Cause No. 45006, and conferring with Marty A. Wessler, P.E., CEO of Wessler  
9 Engineering, who was and has been actively engaged in both matters.

10 **Q. ARE YOU A REGISTERED PROFESSIONAL ENGINEER (P.E.)?**

11 A. Yes, I am. I hold Indiana license number PE10809017.

12 **Q. WAS WESSLER ENGINEERING RETAINED BY LAFAYETTE TO PREPARE A**  
13 **WATER SYSTEM MASTER PLAN (“WSMP”) AND CAPITAL IMPROVEMENT**  
14 **PLAN (“CIP”) FOR THE UTILITY?**

15 A. Yes, and Wessler Engineering has prepared the WSMP, inclusive of the CIP. I have attached  
16 the WSMP to my testimony as Petitioner's Confidential Attachment ADG-1. The CIP  
17 consists of the five-year plan for capital improvements, and it is incorporated within the  
18 WSMP and summarized in Table 1 on page 11 of the WSMP (*i.e.*, page 14 of Confidential  
19 Attachment ADG-1).

20 **Q. WHAT IS THE PURPOSE OF YOUR DIRECT TESTIMONY IN THIS**  
21 **PROCEEDING?**

22 A. I am testifying in support of the rate increase requested by Lafayette in this Cause by  
23 presenting engineering evidence to demonstrate that certain capital improvements are  
24 needed in Lafayette's water utility. I will discuss how the WSMP, inclusive of the CIP,

1 was prepared, how the capital projects were selected, and what alternative options were  
2 reviewed.

## **II. WSMP PREPARATION AND EXPLANATION**

4 Q. PLEASE DISCUSS, AT A HIGH LEVEL, THE PROCESS WESSLER  
5 ENGINEERING UNDERTOOK IN PREPARING THE WSMP.

6 A. We used the Water System Capital Improvements Plan (“2016 CIP”) prepared by Wessler  
7 Engineering for Lafayette’s last rate case, Cause No. 45006, as a base and followed the  
8 process outlined in Dreama Doolittle’s direct testimony in Cause No. 45006 to update the  
9 2016 CIP to the WSMP. For purposes of clarity, the 2016 CIP was identified in Cause No.  
10 45006 as Petitioner’s Exhibit 3, Attachment DED-1.

The WSMP identifies improvements projected in 5, 20, and 50-year increments to assist Lafayette in planning for immediate and longer-term water system improvements. In this Cause, we propose funding the capital improvements considered Short-Term (5-year) based on the Long-Term (20-year and 50-year) water supply needs and demand for projected developments. The Long-Term projected system needs were determined by: (1) gathering detailed information through field investigations and discussions with the water utility staff, Lafayette's legal, engineering, and controller's offices; (2) updating the asset management plan ("AMP"), which included all components of the water system with a value greater than \$5,000; (3) hydraulic modeling, hydrogeologic evaluation, and test well drilling; (4) engineering computations and evaluations; and (5) lead service line investigations, which included both office and field work. We compiled the findings and recommendations from these investigations into what became the WSMP.

1 It was necessary to develop a master plan beyond 20 years to study and determine  
2 additional water sources for Lafayette to maintain service to existing and future customers.  
3 As water demands have risen, the water system infrastructure has become more critical to  
4 maintain in order to satisfy those increased customer demands.

5 Wessler Engineering and Utility staff examined both process and distribution system assets.  
6 Process assets included pumps, motors, valves, wells, chemical feed systems, electrical,  
7 controls, buildings, and tanks. New components were added and retired components were  
8 removed from the AMP. Information logged for each component included: name,  
9 manufacturer, type, location, capacity, physical characteristics, age, condition, system  
10 function, and other related information. Distribution system assets included existing water  
11 main and appurtenances. Lafayette maintains records of water main breaks, and the records  
12 include: dates, locations, pipe materials, and approximate ages. Water main break records  
13 between 2016-2022 were added to the previously reported break information from 2001-  
14 2015 to evaluate water main replacement areas. High concentration areas with more recent  
15 water main breaks were reviewed to determine if the breaks were occurring on the same  
16 water main, parallel water mains, branch mains, or services. Significant attention was given  
17 to the age and break/repair history of the water mains as criteria for replacement.

18 Probability of failure and consequence of failure were developed for each process asset. A  
19 redundancy score was also included to indicate the importance of the asset for Lafayette to  
20 meet an acceptable level of service to customers. Based on these three criteria, a business  
21 risk exposure ("BRE") rating was calculated for each asset, and high BRE ratings indicate  
22 the higher risk associated with the asset's failure.

1       Lafayette's hydraulic model was updated to include any improvements to the distribution  
2       system since 2016. Using recorded system information along with staff experience, the  
3       model was calibrated to accurately reflect the existing operational state of the water system.  
4       Strategic planning for future development has already been completed by Lafayette, and it  
5       focuses on eight service areas located in the upper pressure zone, as shown in the location  
6       maps in Figures A-8 through A-24 in Appendix A of the WSMP. Together with Utility staff,  
7       Wessler Engineering prepared estimates of water usage in each of the service areas for the  
8       5, 20, and 50-year timeframes. Hydraulic modeling was used to determine the impact of  
9       increased water demands in each service area and to develop CIP alternatives. The 50-year  
10      timeframe was mainly evaluated to project water demands for determining long-term water  
11      supply needs.

12      Lastly, a hydrogeologic evaluation was completed in January 2023 by Eagon & Associates,  
13      Inc., and determined potential locations for additional water sources. Six areas were  
14      identified throughout Lafayette for groundwater exploration. Lafayette selected specific  
15      areas to explore for water and contracted with a licensed well driller who completed 17  
16      test wells and 3 full-size test production wells in 2024 and 2025. The hydrogeologic results  
17      gathered from the test wells were used by the hydrogeologist to provide a theoretical  
18      estimate of the total capacity of a permanent, full-size well. Future well locations were  
19      entered into the hydraulic model along with distribution system improvements to determine  
20      project alternatives.

21      **Q. PLEASE WALK US THROUGH THE STUDY AREAS IN THE WSMP.**

1 A. The study areas in the WSMP cover Lafayette's existing water service area, including the  
2 Town of Dayton and customers located outside of Lafayette's municipal corporate limits,  
3 as well as future service areas. The WSMP is organized in sections as follows:

1. Project Location – This section identifies the project and basic parameters.

2. Current Needs – This section discusses existing water consumption relating to historical and current population, water customer type and water usage, non-revenue existing water quality from the Utility's water sources, including per- and fluoroalkyl substances (“PFAS”) testing, a discussion on ground water under direct influence and existing water facilities (including information used to identify the BRE), a summary of hydrogeologic exploration to identify additional water sources, the service line replacement program, and Lafayette’s annual main replacement program.

3. Future Needs – This section analyzes projected 20-year population growth, population demands, land use and development, and system demands.

14                   4.       Evaluation of Alternatives – This section identifies potential alternatives to  
15                   meet Lafayette’s water utility needs.

5. Evaluation of Environmental Impacts – This section evaluates the environmental impacts if Lafayette pursues financing through Indiana’s State Revolving Fund (“SRF”).

6. Proposed Improvements – This section identifies the improvements proposed to meet Lafayette’s needs. Summaries of Short-Term and Long-Term projects can be found on pages 77-78 of the WSMP (*i.e.*, pages 80-81 of Confidential Attachment ADG-

1       1; Table 6.1.1 is consistent with Table 1). The Long-Term capital projects identified in the  
2       CIP represent a total investment of over \$167 million and are not included in this rate case.

3           7.       Legal, Financial, and Managerial Capabilities – This section discusses the  
4       legal, financial, and managerial capabilities in the event Lafayette pursues financing  
5       through SRF.

6           8.       Public Participation – This section discusses the requisite public input in the  
7       event Lafayette chose to pursue financing through SRF.

8       **Q.       PLEASE DESCRIBE YOUR FINDINGS CONCERNING THE PHYSICAL STATE  
9           OF THE UTILITY'S SYSTEM AND IDENTIFY ANY HIGH PRIORITY SYSTEM  
10          NEEDS.**

11       A.       Similar to the results in the 2016 CIP, the Utility system is in good shape; however,  
12       improvements are needed for maintaining Lafayette's existing water supply, adding  
13       additional source water capacity, and extending the water distribution system to serve  
14       population growth and future commercial and industrial growth. The investigation and  
15       evaluation process identified several components at a high-risk in Lafayette's water system,  
16       as follows:

- 17           1.       Upper Pressure Zone – Additional Water Supply, Storage, and Upgrades
- 18           2.       Distribution System Improvements – Hydraulic Loops and Extensions
- 19           3.       Replacement of Lead Service Lines

20       **Q.       HOW DID WESSLER ENGINEERING DETERMINE HIGH PRIORITY SYSTEM  
21          NEEDS?**

22       A.       Similar to the 2016 CIP, Wessler Engineering evaluated Lafayette's water system as  
23       described above and assigned a BRE rating to Lafayette's infrastructure. The results of the  
24       BRE evaluation determined whether an asset is at low, moderate, high, or severe risk of

1 failure and includes consideration of the consequence of failure of the asset. Wessler  
2 Engineering used the BRE as a component in determining CIP alternatives and  
3 recommendations for the proposed projects.

4 **Q. PLEASE DISCUSS LAFAYETTE'S SYSTEM NEEDS BASED ON THE FINDINGS  
5 IN THE WSMP.**

6 A. Since the 2016 CIP was developed, Lafayette's average and maximum water demands have  
7 increased from 8.4 million gallons per day ("MGD") and 13.9 MGD to nearly 11.0 MGD  
8 and 17.0 MGD, respectively. As water demands have risen, the water system infrastructure  
9 has become more critical to maintain in order to satisfy customer demand. Improvements  
10 are needed to Lafayette's Canal and Glick well fields just to maintain the current water  
11 supply.

12 Based upon future demands estimated in the WSMP, Lafayette will need additional  
13 capacity for supplying water to customers in the next five years. Future development has  
14 occurred to the south and southeast, primarily in the upper pressure zone where 80% of  
15 Lafayette's water demand occurs. The City's two existing wellfields pump water into the  
16 lower pressure zone and also to reservoirs at Columbian Park and Murdock Park where the  
17 water is then pumped again through booster pump stations into the upper pressure zone.  
18 Neither pump stations has additional capacity to pump water from future source water.  
19 Accordingly, water will need to be pumped directly into the upper pressure zone without  
20 being conveyed through either existing booster station.

21 Distribution system improvements will be needed to convey source water to eight Service  
22 Areas located in Lafayette's upper pressure zone and referenced as Anticipated Future

1 Development in Figures A-8 through A-24 in Appendix A in the WSMP. The needed  
2 distribution system improvements include water main extensions, pumping facilities, and  
3 water storage. The proposed land uses include residential, general business, commercial,  
4 medical, and industrial development.

5 Replacement of lead service lines is needed based upon regulations issued by the U.S.  
6 Environmental Protection Agency (“EPA”) on December 16, 2021; and the EPA issued a  
7 final rule requiring drinking water systems across the country to identify and replace lead  
8 pipes within 10 years.

9 **III. CAPITAL PROJECTS: WELL FIELDS**

10 **Q. PLEASE DESCRIBE LAFAYETTE'S EXISTING WELL FIELDS.**

11 A. Lafayette currently operates 2 well fields containing a total of 14 groundwater wells. The  
12 Glick Well Field is primary and contains 5 groundwater wells. One well was constructed  
13 in 1975, and 4 wells were constructed in 1994. Lafayette cleans their Glick wells every 1  
14 to 2 years on average and frequently takes them out of service for maintenance and repair  
15 to the pumps and motors. This is due to the high levels of iron and manganese. Chemical  
16 and electrical improvements are currently being completed at the Glick Well Field, part of  
17 which was a long-term project identified in the 2016 CIP. Short-term improvements are  
18 needed and consist of replacing wells, pumps, and motors in each of the well fields and  
19 making improvements at the treatment buildings. The Canal Well Field contains 9 wells  
20 constructed as early as 1954, and the newest well was constructed in 1989. Short term  
21 improvements are needed to replace wells and to make improvements at the treatment  
22 buildings.

1   **Q.   WHAT WELL FIELD PROJECTS ARE PROPOSED?**

2   A.   The well field projects fall into two categories: upgrades to existing well fields and new  
3   well fields.

4           The upgrades to existing well fields impact both the Glick and Canal Well Fields. The  
5   projects are described below:

6           1.    Glick Well Field Improvements. This project consists of replacing Well No.  
7           1, adding 2 new redundant wells, and installing 4 new well motors at the  
8   Glick Well Field. On average, Lafayette has been taking Glick wells out of  
9   service for maintenance, cleaning, or repair every year due to the age of  
10   each well and the high iron and manganese concentrations in the aquifer.  
11           Sometimes multiple wells need to be taken out of service at the same time.  
12           It is anticipated that wells will need to be replaced during the planning  
13   period. The estimated project cost is \$2,038,000. The Engineer's Opinion  
14   of Probable Costs is set forth in Appendix B, Table B-4 of the WSMP and  
15   includes construction and non-construction costs.

16           2.    Canal Well Field Improvements. This project consists of replacing each of  
17   the wells, well pumps, motors, and the installation of 2 new production  
18   wells to increase capacity and redundancy. It also includes expanding the  
19   Canal Treatment Building to expose the distribution piping and create  
20   above-grade chemical injection points for safer and improved operations.  
21           The estimated project cost is \$6,353,000. The Engineer's Opinion of

1 Probable Costs is set forth in Appendix B, Table B-3 of the WSMP and  
2 includes construction and non-construction costs.

3 The WSMP also determined that Lafayette needs at least 2 future well fields in the next 20  
4 years to meet customer water demand. Lafayette's growth has significantly outpaced the  
5 projections from the 2016 CIP. As mentioned earlier, any future well fields will need to  
6 pump water directly into the upper pressure zone where development will occur. As shown  
7 in Table 3.1.1 in the WSMP (*i.e.*, page 57 of Confidential Attachment ADG-1) the Total  
8 Anticipated Development Demands indicate the projected average ("avg") and maximum  
9 day ("max") as follows:

- 10 • Short-term (5-years) – 2.9 MGD (avg), 4.3 MGD (max)
- 11 • Long-term (20-years) – 8.2 MGD (avg), 12.1 MGD (max)

12 Lafayette's well driller installed a 12-inch test production well on the New Horizon  
13 property within the A. Ross Properties in June 2025. This included the well casing, screen,  
14 and well packing. A 72-hour pump test was completed in July 2025. Originally, a well field  
15 at New Horizon's was estimated to produce between 2 to 6 MGD. Based upon the test  
16 pumping data and hydraulic modeling results that Lafayette received in mid-September  
17 2025, the estimated well field capacity was determined to be 2.1 MGD. This is much lower  
18 than Lafayette expected and does not meet Lafayette's short-term water needs but may play  
19 a role in longer term water supply needs in the upper pressure zone.

20 The unfavorable test results at the New Horizons property do not alleviate the need for  
21 additional source water for Lafayette, nor do they mitigate Lafayette's present need for rate  
22 relief. Further investigation and test drilling will need to be completed for other potential

1 well field sites before Lafayette makes a decision on where to obtain additional source  
2 water. Notwithstanding the foregoing, the cost estimates in the WSMP for the New  
3 Horizons well field represent a reasonable proxy for the costs associated with a new well  
4 field, and Lafayette proposes to use those figures as an estimate for a new well field.  
5 Because the source water option has not been identified with particularity, it is of course  
6 possible that Lafayette may need to seek additional relief in the future.

7 **Q. HOW DID WESSLER ENGINEERING DETERMINE THAT THE NEW WELL  
8 FIELDS ARE NEEDED TO MAINTAIN ADEQUATE AND RELIABLE WATER  
9 SERVICE?**

10 A. As previously mentioned, population growth and anticipated economic growth in the next  
11 five years will increase water demands beyond the capacity of Lafayette's existing well  
12 field supply. This is illustrated in Table 3.2.1.1 on page 58 of the WSMP (*i.e.*, page 61 of  
13 Confidential Attachment ADG-1). The new well fields will be needed to supply the  
14 additional source water capacity to Lafayette's upper pressure zone where the growth is  
15 anticipated. As I will discuss later, future well fields will necessary to increase distribution  
16 efficiency and maintain adequate and reliable service to satisfy water demands, adequate  
17 water pressure, and fire flows.

18 **Q. WHAT ALTERNATIVES HAS LAFAYETTE CONSIDERED BESIDE PURSUING  
19 A NEW WELL FIELD TO ADDRESS INCREASED DEMANDS ON THE  
20 UTILITY?**

21 A. Two new wells at each of the Glick and the Canal Well Fields were considered in  
22 Alternatives WS4-1 and WS4-2 in the CIP. These wells would add incremental additional  
23 capacity to both well fields; however, their primary purpose is for redundancy when  
24 existing wells need to be taken out of service for maintenance and repair. The additional  
25 wells also will not pump directly into the upper pressure zone and will have to pump water

1 through the lower pressure zone to the booster stations first. Lafayette is moving forward  
2 with the design of 2 additional wells at their Glick Well Field that will be rated at 2 MGD  
3 each. The addition of 2 more wells at the Glick Well Field, however, will not be enough to  
4 meet water supply demands in the Short-Term (5 years) and Long-Term (20 years). A  
5 source of water supply needs to be developed and directly connected to Lafayette's upper  
6 pressure zone for supplying future demands. Further, water quality at the Canal Well Field  
7 is not ideal for adding 2 wells.

8 **Q. AFTER YOU ESTABLISHED THAT LAFAYETTE NEEDED NEW WELL  
9 FIELDS, PLEASE DESCRIBE THE PROCESS LAFAYETTE PURSUED TO  
10 DEVELOP THE NEW WELL FIELDS.**

11 A. A hydrogeologic evaluation was completed in January 2023 by Eagon & Associates, a  
12 subconsultant to Wessler Engineering, and identified potential locations for wells.  
13 Lafayette has completed 17 test wells since September 2023 on the following properties  
14 within Lafayette with the following results:

15 1. Veterans Memorial Parkway West Properties ("VMP-West") – Two test  
16 wells were completed; however, very fine sand was encountered during test drilling. This  
17 is not a preferred location for a well field because the wells would require a well screen  
18 with small slot size to ensure the fine material does not pass through the screen during  
19 pumping, which would limit production capacity per well and potentially increase  
20 maintenance frequency. Accordingly, the VMP-West location was eliminated from  
21 consideration.

22 2. Tippecanoe County Property – This is located across from Kline Property.  
23 One test well encountered very fine sand similar to VMP-West. Accordingly, the  
24 Tippecanoe County Property location was eliminated from consideration.

1                   3. Berlowitz Properties – One test well was completed, and the range of sand  
2 and gravel was not as substantial as what we found at the New Horizons/IU Health  
3 property. This is not a preferred location because the lower aquifer was only 15-feet thick  
4 indicating a limited aquifer extent. Accordingly, the Berlowitz Properties location was  
5 eliminated from consideration.

6                   4. Canal Well Field – Three test wells were completed, and we encountered  
7 arsenic levels above the EPA's Maximum Contaminant Level ("MCL"). This is not a  
8 preferred source since water quality presented challenges. This location also has the  
9 challenge of not easily accessing the upper pressure zone. Accordingly, expansion of the  
10 Canal Well Field for additional source water was eliminated from consideration.

11                  5. Glick Well Field – Three test wells were completed with favorable capacity  
12 and water quality. Lafayette completed 2 test production wells and has begun design on the  
13 permanent wells. As discussed earlier, these proposed wells are intended to add capacity  
14 and redundancy to the Glick Well Field, particularly when existing wells need to be taken  
15 out of service, rather than serve as additional source water capacity.

16                  6. North of McAllister Park – One test well was completed north of Glick Well  
17 No. 5 to confirm whether the aquifer formation continued north of Lafayette's existing  
18 Glick Well Field and to confirm whether any residual Volatile Organic Compounds were  
19 present from the early 2000's. The aquifer formation was confirmed to continue north, and  
20 the water quality did not have any immediate concerns. This was not originally a preferred  
21 location for a well field because it would require a lengthy transmission main to connect to

1 the upper pressure zone, but may be reconsidered in light of the need for additional source  
2 water.

3 7. New Horizons/IU Health – Six test wells were completed on the New  
4 Horizons, Parks and Recreation, and IU Health properties. The preliminary field yield was  
5 estimated between 2-6 MGD. The Engineer's Opinion of Probable Costs totaling  
6 \$16,945,000 is set forth in Appendix B, Table B-1 of the WSMP and includes construction  
7 and non-construction costs. A 12-inch test production well was constructed in April 2025  
8 and pumped for 72 hours to determine available capacity and water quality when the  
9 aquifer is pumped continuously. In mid-September of 2025, Eagon & Associates completed  
10 a summary report for New Horizons which estimated well field capacity. The capacity was  
11 determined using the test pumping data obtained from the test production well and also  
12 groundwater hydraulic modeling that Eagon & Associates completed to make its report.  
13 The maximum production yield was determined to be 2.1 MGD. That is not sufficient for  
14 Lafayette's short-term needs; however, the site may be considered in the longer term as a  
15 source of supplemental water supply in the upper pressure zone. Lafayette's decision is a  
16 reasonable approach from an engineering standpoint.

17 **Q. PLEASE DESCRIBE LAFAYETTE'S PREFERRED WELL FIELD OPTION TO  
18 UNDERTAKE IN THE NEAR TERM AND THE PROPOSED BUDGET.**

19 A. Because Lafayette's short-term need for water supply would not be satisfied by the New  
20 Horizons/IU Health property, Lafayette continues to need and scout for potential locations  
21 for new well sites to increase Lafayette's water production and meet urgent current and  
22 new customer demand in the near term. Wessler Engineering budgeted \$16,945,000 for the

1 New Horizons/IU Health well field, which included 6 wells, a water filtration plant, and  
2 raw water main to connect to the upper pressure zone. That figure is a reasonable proxy  
3 budget amount to construct a new, to-be-determined well field and water treatment facility  
4 that will meet Lafayette's near term production demand.

5 Lafayette proposes that the Commission approve a budget of \$16,945,000 for the purpose  
6 of Lafayette identifying and constructing a well field that meets Lafayette's production and  
7 cost criteria. I want to emphasize that while this is a reasonable proposed budget, it is based  
8 on a project at the New Horizons/IU Health site. As with any project, the actual costs may  
9 differ.

10 **Q. PLEASE DESCRIBE THE METHODOLOGY FOR DETERMINING THE RANGE  
11 OF COSTS OF THE PROPOSED WELL FIELDS.**

12 A. Costs were estimated using a theoretical capacity of each well field and associated water  
13 treatment plant. The capacity estimates were determined by Eagon & Associates from  
14 preliminary hydrogeological modeling of the aquifer and formation data gathered from the  
15 test wells and test production well at New Horizons/IU Health. The engineer's opinion of  
16 probable costs for the well field alternatives are based upon 2025 dollars, which includes a  
17 contingency and accounts for inflation for when the project will be bid and constructed.  
18 Each cost estimate was prepared by Wessler Engineering and is based upon the engineer's  
19 qualifications and experience and known market conditions. Because costs for materials  
20 and supplies may be subject to changing market conditions due to tariffs, Wessler  
21 Engineering suggests a pricing range of 15% above and below the Engineer's Opinion of  
22 Probable Costs for materials and supplies. Based on the foregoing, using the \$16,945,000

1 figure as a proxy for development of a new well field is a reasonable approach given  
2 Lafayette's need to develop an additional source of water in the short term.

3 **Q. DID YOU CONSIDER THE IMPACT OF PFAS REGULATION WHEN**  
4 **INVESTIGATING WELL FIELD SITES?**

5 A. Yes, water samples have been collected from each test well and test production well  
6 Lafayette has completed. Each sample has been sent to a laboratory for testing  
7 perfluorooctanoic acid ("PFOA"), perfluorooctane sulfonate ("PFOS"), perfluorononanoic  
8 acid ("PFNA"), hexafluoropropylene oxide dimer acid ("HFPO-DA"), perfluorohexane  
9 sulfonic acid ("PFHxS"), and perfluorobutanesulfonic acid ("PFBS"). The EPA set  
10 enforceable MCLs for five individual PFAS: PFOA, PFOS, PFNA, PFHxS, and HFPO-DA  
11 (also known as the "GenX Chemicals"). All water quality results for each of the wells have  
12 been received, including PFAS. No detection of any PFAS constituents was found at New  
13 Horizons/IU Health, VMP-West, Glick, or north of McAllister Park.

14 PFAS regulation is in a state of flux. For instance on May 14, 2025, the EPA announced it  
15 will maintain the MCLs for PFOA and PFOS and extend the compliance period by two  
16 years but roll back regulations on the other GenX Chemicals. Lafayette will continue  
17 monitoring the regulatory landscape regarding National Primary Drinking Water  
18 Regulations for additional changes to PFAS regulation and any new flexibility and cost  
19 savings that may be offered to public water systems.

20 **Q. DO YOU BELIEVE THE COSTS ASSOCIATED WITH THE PROPOSED WELL**  
21 **FIELD PROJECTS ARE REASONABLE AND NECESSARY?**

22 A. Yes. The costs are based upon current dollars, include contingencies, and incorporate the  
23 timing of the project construction. Again, Lafayette is only seeking to include costs in this  
24 case for a new well field to satisfy short term water supply demands. A future rate request

1 will include another major well field project. I believe the approach to well field  
2 development I have outlined is reasonable and necessary in the current market and  
3 regulatory environment.

4 **IV. CAPITAL PROJECTS: LEAD SERVICE LINE REPLACEMENTS (“LSLRs”)**

5 **Q. HOW IS LAFAYETTE DEALING WITH LEAD SERVICES LINES AND THE**  
6 **LEAD AND COPPER RULE IMPROVEMENTS RECENTLY PROMULGATED?**

7 A. Lafayette completed their lead service line inventory in the Spring of 2023 which contained  
8 documentation for 30,773 service lines. Lafayette submitted its inventory to the Indiana  
9 Finance Authority (“IFA”) and received grants for Type II (Study) and Type III  
10 (Investigation) funding. A preliminary engineering report (“PER”) was completed using  
11 the Type II funds and meter pit and potholing (hydro-excavation) investigations were  
12 completed using the Type III funding. The inventory, which identified 7,948 lead service  
13 lines, was submitted to the IFA prior to the investigative work being completed. Since then,  
14 Lafayette has used the results of the meter pit investigations and potholing work to reduce  
15 the total lead service lines by more than half to 3,207.

16 Lafayette submitted the PER to SRF, and the SRF awarded Lafayette a total of \$5 million:  
17 \$2.5 million in grant funding and \$2.5 million as a 0% loan that closed in December of  
18 2024. SRF has awarded another \$5 million to Lafayette, again as a \$2.5 million grant and  
19 a \$2.5 million, 0% loan that is anticipated to close in spring of 2026. Based on the  
20 December 2024 bond issuance, Lafayette signed a contract with a contractor to start  
21 replacing lead service lines in April 2025. It is my understanding that Commission approval  
22 of that loan was not sought on the basis of HEA 1316 (2023). These funds do not impact

1 the LSLR request in this proceeding. Had Lafayette not been proactive in obtaining this  
2 funding, its LSLR request in this proceeding would have been higher.

3 **Q. WHAT DOLLAR AMOUNT IS LAFAYETTE REQUESTING IN THIS CASE FOR**  
4 **LEAD SERVICE LINE REPLACEMENTS, AND HOW WAS IT CALCULATED?**

5 A. Lafayette is seeking \$22,338,130 for the first five years of its LSLR program. This assumes  
6 that Lafayette will receive no additional funding (grant or loan) from SRF. Lead service  
7 line replacement costs were estimated based upon past similar projects. The Engineer's  
8 Opinion of Probable Costs is included in Appendix B, Table B-36 of the WSMP, and the  
9 cost estimate includes construction and non-construction costs for the entire LSLR project  
10 for which funding is only partially requested in this case.

11 **Q. DOES THE \$22,338,130 FIGURE INCLUDE ALL OF LAFAYETTE'S LEAD**  
12 **SERVICE LINE REPLACEMENTS?**

13 A. No, as I alluded to in my prior response. That amount does not cover all of Lafayette's lead  
14 service line replacements. An additional \$21,458,870 will be needed in years 6 through 10  
15 to fund the remaining replacements.

16 **V. CAPITAL PROJECTS: OTHER WATER SYSTEM IMPROVEMENTS**

17 **Q. WHAT OTHER CAPITAL PROJECTS ARE INCLUDED IN THE CIP?**

18 A. Other Short-Term (5-year) projects include the following:

19 1. New Flow Meter at Columbian Park Booster Station. This project consists  
20 of replacing the flow meter and associated electrical and controls at the Columbian Park  
21 Booster Station. This project is needed to more accurately track water pumped by the  
22 station into the upper pressure zone. The current flow meter installed at Columbian Park is  
23 not accurate and needs replacement. The estimated project cost is \$40,000.

1           2.     Inspection of Existing Water Tanks. This project consists of inspecting  
2     Lafayette's Haggerty Lane Tank (2.0 MG), Plaza South Tank (1.0 MG), Union Street Tank  
3     (1.0 MG), and Fairgrounds Tank (1.0 MG). The last time the tanks were inspected was in  
4     June 2020. The estimated project cost is \$5,000 per tank or \$20,000 total. Wessler  
5     Engineering confirmed that the existing water tanks have been regularly maintained and  
6     timely replacements of tank coatings are planned.

7           3.     Water Main Extensions within Service Area 7. This project consists of  
8     approximately 4,300 feet of new 24-inch ductile iron water main from the existing 24-inch  
9     water main on the VMP-West and down New Castle Road to the intersection with East Old  
10    250 South to serve a projected industrial development at the northern portion of Service  
11    Area 7. As you can tell from the 24-inch main size, this is not the typical main extension  
12    that a developer pays for – rather, this project benefits the entire system: (1) by improving  
13    the daily operation and maintenance of Lafayette's water system; and (2) by facilitating  
14    Lafayette meeting future water demand. Lafayette has received numerous inquiries from  
15    industrial developers for water usage as high as 5 MGD in the northern portion of Service  
16    Area 7. The estimated project cost is \$2,359,000. The Engineer's Opinion of Probable  
17    Costs is set forth in Appendix B, Table B-37 of the WSMP and includes construction and  
18    non-construction costs.

19           4.     Water Main Extensions within Service Area 11A. This project is broken into  
20    three phases. The first phase includes: 5,200 feet of new 16-inch ductile iron water main  
21    from the existing 16-inch water main at the intersection of West 500 South and Wharfside  
22    Parkway; and 400 feet of 18-inch high density polyethylene ("HDPE") water main in 24-

1       inch steel casing under US 231. The estimated project cost for the first phase is \$2,720,000.  
2       The Engineer's Opinion of Probable Costs is set forth in Appendix B, Table B-38 of the  
3       WSMP and includes construction and non-construction costs.  
4       The second phase includes 10,000 feet of new 24-inch ductile iron water main from the  
5       existing 24-inch water main at the intersection of East 300 South and Poland Hill Road to  
6       serve the projected residential developments at Chesapeake Point (290 homes) and Arbor  
7       Homes (200 homes) in Service Area 11A. It also includes 600 feet of 30-inch HDPE water  
8       main by horizontal directional drilling under Elliott Ditch. The estimated project cost is  
9       \$5,507,000. The Engineer's Opinion of Probable Costs is set forth in Appendix B, Table  
10      B-39 of the WSMP and includes construction and non-construction costs.  
11      The third phase includes 10,000 feet of new 16-inch ductile iron water main from the  
12      existing 16-inch water main at the intersection of North Admirals Pointe Drive and Topsoil  
13      Trace to serve the projected residential development at Chesapeake Point and Arbor Homes  
14      in Service Area 11A. It also includes 800 feet of 18-inch HDPE water main by horizontal  
15      directional drilling under Wea Creek. The estimated project cost is \$4,590,000. The  
16      Engineer's Opinion of Probable Costs is set forth in Appendix B, Table B-40 of the WSMP  
17      and includes construction and non-construction costs.  
18      5.       Distribution System Water Main Replacements and Extensions. This project  
19      consists of miscellaneous water main replacements that will be needed during the Short-  
20      Term because it is advantageous to replace them in conjunction with other City of Lafayette  
21      projects, such as road repaving. The estimated project cost is \$2,000,000, which is a

1 reasonable level of funding based on my knowledge of Lafayette's history and my  
2 professional experience generally.

3 **Q. DOES THE RATE INCREASE REQUESTED BY LAFAYETTE IN THIS CAUSE  
4 COVER ALL OF THE PROJECTS IDENTIFIED IN THE WSMP?**

5 A. No. There are multiple Long-Term Projects identified in the WSMP for planning and  
6 discussion purposes only in the 20-year Project Summary. Lafayette does not request  
7 funding for these Long-Term Projects in this Cause, and a future rate case will be needed  
8 to fund them.

9 **VI. CONCLUSION**

10 **Q. DO YOU BELIEVE THE PROPOSED CAPITAL PROJECTS ARE REASONABLE  
11 AND NECESSARY?**

12 A. Yes, I do.

13 **Q. DO YOU BELIEVE THE COSTS OF THE CAPITAL PROJECTS ARE  
14 REASONABLE?**

15 A. Yes, I do.

16 **Q. MR. GORDON, PLEASE SUMMARIZE YOUR TESTIMONY.**

17 A. Lafayette retained Wessler Engineering to prepare a WSMP, inclusive of the CIP. The  
18 WSMP identifies Short-Term (5 years or less; *i.e.*, the CIP) and Long-Term (20 years)  
19 capital needs for Lafayette's water utility, in particular obtaining additional sources of  
20 water supply to accommodate population growth and economic development. Lafayette  
21 determined to implement certain capital projects identified in the CIP. The capital projects  
22 included in this rate case involve source water projects, water distribution extension  
23 projects, water storage projects, upgrades to process infrastructure, and replacement of lead  
24 service lines. All system needs were evaluated and proposed projects were analyzed and

1 alternatives were reviewed in the preparation of the WSMP, including the CIP. The result  
2 is a set of reasonable and prudent capital improvements that, when completed, will sustain  
3 Lafayette as a reliable water purveyor to supply safe, clean drinking water to its customers.


4 **Q. DOES THIS CONCLUDE YOUR VERIFIED DIRECT TESTIMONY AT THIS  
5 TIME?**

6 A. Yes, it does.

7

**VERIFICATION**

I hereby verify under the penalties of perjury that the foregoing representations are true to the best of my knowledge, information, and belief.

Signature:   
Andrew D. Gordon

Dated: 10/15/2025