

Cause No. 45253
Duke Industrial Group
MPG Public WP 9

FILED
November 1, 2019
INDIANA UTILITY
REGULATORY COMMISSION



Independent Statistics & Analysis
U.S. Energy Information
Administration

Capital Cost Estimates for Utility Scale Electricity Generating Plants

November 2016



This report was prepared by the U.S. Energy Information Administration (EIA), the statistical and analytical agency within the U.S. Department of Energy. By law, EIA's data, analyses, and forecasts are independent of approval by any other officer or employee of the United States Government. The views in this report therefore should not be construed as representing those of the Department of Energy or other federal agencies.

Contents

| | |
|---|----|
| Introduction | 1 |
| Developing updated estimates: key design considerations | 1 |
| Findings | 2 |
| EIA's analysis of technology choice in the electric power sector..... | 3 |
| Impact of location on power plant capital costs..... | 5 |
| Summary | 6 |
| Appendix A - Acronym List | 12 |
| Appendix B – Full Report..... | 13 |

Tables

| | |
|---|----|
| Table 1. Updated estimates of power plant capital and operating costs | 7 |
| Table 2. Overnight cost comparison with 2010 estimates..... | 8 |
| Table 3. Status of technologies and components modeled by EIA | 10 |
| Table 4. Regional cost adjustments for technologies modeled by NEMS by Electric Market Module (EMM) region..... | 11 |

Introduction

The current and future projected cost and performance characteristics of new electric generating capacity are critical inputs into the development of energy projections and analyses. The construction and operating costs, along with the performance characteristics of new generating plants, play an important role in determining the mix of capacity additions that will serve future demand for electricity. These parameters also help to determine how new capacity competes against existing capacity, and the response of the electric generators to the imposition of environmental controls on conventional pollutants or any limitations on greenhouse gas emissions.

EIA commissioned an external consultant to develop up-to-date cost and performance estimates for utility-scale electric generating plants for AEO2013.¹ This information allowed EIA to compare the costs of different power plant technologies on a standardized basis and was a key input enhancement to the National Energy Model System (NEMS). For the AEO 2016 development, EIA commissioned the same consultant group to update the cost and performance estimates for a select set of the technologies evaluated in the original 2012 study. This paper summarizes the results of the findings and discusses how EIA used the updated information to analyze the development of new capacity in the electric power sector.

Developing updated estimates: key design considerations

The focus of the 2016 update was to gather current information on the "overnight" construction costs, operating costs, and performance characteristics for a wide range of generating technologies.² The estimates were developed through costing exercises, using a common methodology across technologies. Comparing cost estimates developed on a similar basis using the same methodology is of particular importance to ensure modeling consistency.

Each technology is represented by a generic facility of a specific size and configuration, in a location that does not have unusual constraints or infrastructure requirements. Where possible, costs estimates were based on information on system design, configuration, and construction derived from actual or planned projects known to the consultant, using generic assumptions for labor and materials rates. When this information was not available, the project costs were estimated using a more generic technology representation and costing models that account for the current labor and materials rates necessary to complete the construction of a generic facility as well as consistent assumptions for the contractual relationship between the project owner and the construction contractor.

The specific overnight costs for each type of facility were broken down to include:

- **Civil and structural costs:** allowance for site preparation, drainage, the installation of underground utilities, structural steel supply, and construction of buildings on the site
- **Mechanical equipment supply and installation:** major equipment, including but not limited to, boilers, flue gas desulfurization scrubbers, cooling towers, steam turbine generators,

¹ U.S. Energy Information Administration, [Updated Capital Cost Estimates for Utility Scale Electricity Generating Plants 2013](#)

² The term "overnight" refers to the cost of the project as if no interest were incurred during its construction.

condensers, photovoltaic modules, combustion turbines, wind turbines, and other auxiliary equipment

- **Electrical and instrumentation and control:** electrical transformers, switchgear, motor control centers, switchyards, distributed control systems, and other electrical commodities
- **Project indirect costs:** engineering, distributable labor and materials, craft labor overtime and incentives, scaffolding costs, construction management start up and commissioning, and fees for contingency³
- **Owners costs:** development costs, preliminary feasibility and engineering studies, environmental studies and permitting, legal fees, insurance costs, property taxes during construction, and the electrical interconnection costs, including a tie-in to a nearby electrical transmission system

Non-fuel operations and maintenance (O&M) costs associated with each of the power plant technologies were evaluated as well. The O&M costs that do not vary significantly with a plant's electricity generation are classified as fixed, including salaries for facility staff and maintenance that is scheduled on a calendar basis. The costs incurred to generate electricity are classified as variable such as the cost of consumable materials and maintenance that may be scheduled based on the number of operating hours or start-stop cycles of the plant. The heat rates⁴ were also evaluated for the appropriate technologies. It should be noted that all estimates provided in this report are broad in scope. A more in-depth cost assessment would require a more detailed level of engineering and design work, tailored to a specific site.

Findings

[Table 1](#) summarizes updated cost estimates for generic utility-scale generating technologies, including four powered by coal, six by natural gas, three by solar energy, and one each by wind, biomass, uranium, and battery storage. EIA does not model all of these generating plant types, but included them in the study in order to present consistent cost and performance information for a broad range of generating technologies and to aid in the evaluation for potential inclusion of new or different technologies or technology configurations in future analyses.

The specific technologies represented in the NEMS model for *AEO2016* that use the cost data from this report are identified in the last column of [Table 1](#).

[Table 2](#) compares the updated overnight cost estimates to those developed for the 2013 report. To facilitate comparisons, the costs are expressed in 2016 dollars.⁵ Notable changes include:

- **Ultra Supercritical Coal (USC) with and without carbon capture and storage (USC/CCS).** USC with carbon capture and storage was added for this study to help meet EPA's 111b new source performance standard for carbon emissions. While USC without carbon capture cannot be built under current regulations, inclusion of this technology maintains the capability to analyze policy alternatives that may exclude 111b requirements.

³ Fees for contingency include contractor overhead costs, fees, profit, and construction.

⁴ Heat Rate is a measure of generating station [thermal efficiency](#) commonly stated as Btu per kilowatthour.

⁵ U.S. Energy Information Administration, Annual Energy Outlook 2016, [Table 20](#), GDP chain-type price index

- Conventional Natural Gas Combined Cycle (NGCC) and Advanced Natural Gas Combined Cycle (ANGCC):** The updated overnight capital cost for conventional and advanced NGCC plants remained level relative to the cost in the 2013 study. The capacity of the NGCC unit increased from 400 MW in the 2013 study to 429 MW, while the capacity of the ANGCC unit increased from 620 MW to 702 MW for ANGCC to reflect trends toward larger installations for this technology.
- Onshore Wind:** Overnight costs for onshore wind decreased by approximately 25 percent relative to the 2013 study, primarily due to lower wind turbine prices. EIA adjusted regional cost factors for wind plants from those reported in this report for inclusion in AEO 2016[[hyper link to Table 8.2](#)]. The regional factors in this report primarily account for regional variation in labor and materials costs, but subsequent evaluation of the regional variation in wind plant costs found that other factors, such as typical plant size, may account for a larger share of the observed regional differences in cost for the wind plants.
- Solar Photovoltaic:** The overnight capital costs for solar photovoltaic technologies decreased by 67 percent for the 20 MW fixed tilt photovoltaic systems from the costs presented in the 2013 study. Solar photovoltaic single-axis tracking systems were introduced in this report (including both a 20 MW and 150 MW system configurations). There is not a significant difference in Capital costs between fixed-tilt and single-axis-tracking systems. The overall decreases in costs can be attributed to a decline in the component costs and the construction cost savings for the balance of plant systems.

As previously noted, costs are developed using a consistent methodology that includes a broad project scope and includes indirect and owners costs. The cost figures will not necessarily match those derived in other studies that employ different approaches to cost estimation.

EIA's analysis of technology choice in the electric power sector

EIA's modeling employs a net present value (NPV) capital budgeting methodology to evaluate different investment options for new power plants. Estimates of the overnight capital cost, fixed and variable operations and maintenance costs, and plant heat rates for generic generating technologies serve as a starting point for developing the total cost of new generating capacity. However, other parameters also play a key role in determining the total capital costs. Because several of these factors are dynamic, the realized overall capital cost for given technologies can vary based on a variety of circumstances. Five of the most notable parameters are:

- Financing:** EIA determines the cost of capital required to build new power plants by calculating a weighted average cost of capital using a mix of macro-economic parameters determined through EIA's modeling and an assumed capital structure for the electric power industry.
- Lead Time:** The amount of time needed to build a given type of power plant varies by technology. Projects with longer lead times increase financing costs. Each year of construction represents a year of additional interest charges before the plant is placed in service and starts generating revenue. Furthermore, plants with front-weighted construction and development profiles will incur higher interest charges during construction than plants where most of the construction expenditures occur at the end of the development cycle.

- **Inflation of material and construction costs:** The projected relationship between the rate of inflation for the overall economy and key drivers of plant costs, such as materials and construction, are important elements impacting overall plant costs. A projected economy-wide inflation rate that exceeds the projected inflation rate for materials and construction costs results in a projected decline in real (inflation-adjusted) capital costs and vice versa.
- **Resource Supply:** Technologies such as wind, geothermal, or hydroelectric must be sited in suitable locations to take advantage of the particular resource. In order to capture the site specific costs associated with these technologies, EIA develops upward sloping supply curves for each of these technologies. These curves assume that the lowest-cost, most-favorable resources will be developed first, and when only higher-cost, less-favorable sites remain, development costs will increase and/or project performance will decrease.
- **Learning by doing:** The overnight capital costs developed for the report serve as an input to EIA's long term modeling and represent the cost of construction for a project that could begin as early as 2015. However, these costs are assumed to decrease over time in real terms as equipment manufacturers, power plant owners, and construction firms gain more experience with certain technologies. The rate at which these costs decline is often referred to as the learning rate.

EIA determines learning rates at the power plant component level, not for the power plant technology itself because some technologies share the same component types. It is assumed that the knowledge and experience gained through the manufacture and installation of a given component in one type of power plant can be carried over to the same component in another type of plant. As an example, the experience gained through the construction of natural gas combustion turbine plants can be leveraged to influence the overall cost of building a Natural Gas Combined Cycle unit, which in part, includes the components of a combustion turbine natural gas plant. Other technologies, such as nuclear power and pulverized coal (PC) plants without CCS, do not share component systems, and their learning rates are determined solely as a function of the amount of capacity built over time.

Technologies and their components are represented in the NEMS model at various stages of maturity. EIA classifies technologies into three such stages: mature, evolutionary, and revolutionary. The initial learning rate is evaluated for each technology. The technology classification determines how the rate of cost reduction changes as each technology progresses through the learning function. Generally, overnight costs for technologies and associated components decline at a specified rate based on a doubling of new capacity. The cost decline is fastest for revolutionary technologies and slower for evolutionary and mature technologies.⁶

⁶ U.S. Energy Information Administration, [Electricity Market Module Assumptions Document](#), Table 8.3.

The capacity additions used to influence learning are primarily developed from NEMS results. However, external capacity additions from international projects are also included for some technologies, to account for additional learning from such projects. For power plant technologies with multiple components, the capacity additions are weighted by the contribution of each component to the overall plant construction cost.⁷

Table 3 classifies the status of each technology and component as modeled in *AEO2016*

The NEMS model also assumes that efficiency for all fossil-fueled plants improves as a result of learning by doing. The power plant heat rates provided by the consultant are intended to represent the characteristics of a plant that starts construction in 2015 referred to as “first-of-a-kind.” NEMS assumes that the heat rate for all fossil fueled technologies declines over time to a level referred to as an “nth-of-a-kind” heat rate.⁸ The magnitude of heat rate improvement depends on the current state of the technology, with revolutionary technologies seeing a more significant decline in heat rate than mature technologies. Heat rate improvements are independent of capacity expansion. Fixed and variable O&M are not assumed to achieve learning-related savings. The performance of wind plants, as measured by capacity factor, is also assumed to improve as a result of learning by doing.⁹

Impact of location on power plant capital costs

The estimates provided in this report are representative of a generic facility located in a region without any special issues that would alter its cost. However, the cost of building power plants in different regions of the United States can vary significantly. The report includes location-based cost adjustment tables for each technology in 64 metropolitan areas. These adjustments were made to reflect the impact of remote location costs, costs associated with seismic design that may vary by region, and labor wage and productivity differences by region. In order to reflect these costs in EIA's modeling, these adjustments were aggregated to represent the 22 Electricity Market Module regions. EIA also assumes that the development of certain technologies is not feasible in given regions for geographic, logistical, or regulatory reasons. The regional cost adjustments and development restrictions are summarized in **Table 4**.

Subsequent peer review of these results indicated that the regional factors used for wind plants do not adequately reflect observed regional variation of wind plant costs, which appear to be substantially determined by factors other than those considered above. In particular, EIA found a significant regional variation in typical plant size that generally correlated with regional variation in installation costs. Therefore, EIA does not use the regional factors included in this report for its analysis of wind technologies. Regional factors used for AEO 2016 and related analyses can be found in Table 8.2 of the AEO 2016 Assumptions document, and are also shown in Table 4.

⁷ U.S. Energy Information Administration, [Electricity Market Module Assumptions Document](#), Table 8.4.

⁸ U.S. Energy Information Administration, AEO 2016 [Cost and Performance Characteristics of New Central Station Electricity Generating Technologies](#), Table 8.2.

⁹ U.S. Energy Information Administration, [Renewable Fuels Module](#)

Summary

The estimates provided by the consultant for this report are key inputs for EIA electric market projections, but they are not the sole driver of electric generation capacity expansion decisions. The evolution of the electricity mix in each of the 22 regions modeled in *AEO2016* is sensitive to many factors, including the projected evolution of capital costs over the modeling horizon, projected fuel costs, whether wholesale power markets are regulated or competitive, the existing generation mix, additional costs associated with environmental control requirements, and future electricity demand.

Users interested in additional details regarding these updated cost estimates should review the consultant study prepared by Leidos Engineering, LLC in [Appendix B](#).

Table 1. Updated estimates of power plant capital and operating costs

| Technology | Plant Characteristics | | Plant Costs (2016\$) | | | |
|---|-----------------------|---------------------|--------------------------------|----------------------|-----------------------|------------|
| | Nominal Capacity (MW) | Heat Rate (Btu/kWh) | Overnight Capital Cost (\$/kW) | Fixed O&M (\$/kW-yr) | Variable O&M (\$/MWh) | NEMS Input |
| Coal | | | | | | |
| Ultra Supercritical Coal (USC) ¹⁰ | 650 | 8,800 | 3,636 | 42.1 | 4.6 | N |
| Ultra Supercritical Coal with CCS (USC/CCS) ¹¹ | 650 | 9,750 | 5,084 | 70 | 7.1 | Y |
| Pulverized Coal Conversion to Natural Gas (CTNG) | 300 | 10,300 | 226 | 22 | 1.3 | N |
| Pulverized Coal Greenfield with 10-15 percent | 300 | 8,960 | 4,620 | 50.9 | 5 | N |
| Pulverized Coal Conversion to 10 percent biomass – | 300 | 10,360 | 537 | 50.9 | 5 | Y |
| Natural Gas | | | | | | |
| Natural Gas Combined Cycle (NGCC) | 702 | 6,600 | 978 | 11 | 3.5 | Y |
| Advanced Natural Gas Combined Cycle (ANGCC) ¹³ | 429 | 6,300 | 1,104 | 10 | 2 | Y |
| Combustion Turbine (CT) | 100 | 10,000 | 1,101 | 17.5 | 3.5 | Y |
| Advanced Combustion Turbine (ACT) | 237 | 9,800 | 678 | 6.8 | 10.7 | Y |
| Reciprocating Internal Combustion Engine (RICE) | 85 | 8,500 | 1,342 | 6.9 | 5.85 | N |
| Uranium | | | | | | |
| Advanced Nuclear (AN) | 2,234 | N/A | 5,945 | 100.28 | 2.3 | Y |
| Biomass | | | | | | |
| Biomass (BBFB) | 50 | 13,500 | 4,985 | 110 | 4.2 | N |
| Wind | | | | | | |
| Onshore Wind (WN) | 100 | N/A | 1,877 | 39.7 | 0 | Y |
| Solar | | | | | | |
| Photovoltaic – Fixed | 20 | N/A | 2,671 | 23.4 | 0 | N |
| Photovoltaic – Tracking | 20 | | 2,644 | 23.9 | 0 | N |
| Photovoltaic – Tracking | 150 | N/A | 2,534 | 21.8 | 0 | Y |
| Storage | | | | | | |
| Battery Storage (BES) | 4 | N/A | 2,813 | 40 | 8 | N |

¹⁰ USC coal without CCS is not compliant with 111b new source standards for carbon emissions and cannot be built in the AEO2016 forecast.

¹¹ Ultra Supercritical Coal with 30% CCS

¹² Represents capital cost to retrofit existing coal plants to operate with 10% biomass fuel.

¹³ "Advanced"-higher capital cost with reduced operating costs

Table 2. Overnight cost comparison with 2013 estimates

| | Overnight Capital Cost (2016 \$/kW) | | |
|---|-------------------------------------|-------------|------------------|
| | 2016 Report | 2013 report | % Difference |
| Coal | | | |
| Single Unit Advanced PC | N/A | \$3,453 | N/A |
| Dual Unit Advanced PC | N/A | \$3,121 | N/A |
| Single Unit Advanced PC with CCS | N/A | \$5,561 | N/A |
| Dual Unit Advanced PC with CCS | N/A | \$5,026 | N/A |
| Single Unit IGCC | N/A | \$4,681 | N/A |
| Dual Unit IGCC | N/A | \$4,026 | N/A |
| Single Unit IGCC with CCS | N/A | \$7,020 | N/A |
| Ultra Supercritical Coal (USC) | \$3,636 | N/A | 5% ¹⁴ |
| Ultra Supercritical Coal with CCS (USC/CCS) | \$5,084 | N/A | N/A |
| Pulverized Coal Conversion to Natural Gas (CTNG) | \$226 | N/A | N/A |
| Pulverized Coal Greenfield with 10-15 percent biomass (GCBC) | \$4,620 | N/A | N/A |
| Pulverized Coal Conversion to 10 percent biomass Co-Firing 30 MW (CTCB) | \$537 | N/A | N/A |
| Natural Gas | | | |
| Conventional CC | \$978 | \$976 | 0.3% |
| Advanced CC | \$1,104 | \$1,088 | 1% |
| Advanced CC with CCS | N/A | \$2,229 | N/A |
| Conventional CT | \$1,101 | \$1,035 | 6% |
| Advanced CT | \$678 | \$719 | (6%) |
| Fuel Cells | N/A | \$7,562 | N/A |
| Reciprocating Internal Combustion Engine (RICE) | \$1,342 | N/A | N/A |
| Uranium | | | |
| Dual Unit Nuclear | \$5,945 | \$5,883 | 1% |
| Biomass | | | |
| Biomass CC | N/A | \$8,702 | N/A |
| Biomass BFB | \$4,985 | \$4,377 | 12% |
| Wind | | | |
| Onshore Wind | \$1,877 | \$2,354 | (25%) |
| Offshore Wind | N/A | \$6,628 | N/A |

¹⁴ Comparison of costs of coal units without carbon control, despite difference in generation performance (ultra supercritical vs supercritical)

Table 2. Overnight cost comparison with 2013 estimates (cont.)

| | Overnight Capital Cost (2016 \$/kW) | | |
|--|-------------------------------------|-------------|--------------|
| | 2016 Report | 2013 report | % Difference |
| Solar | | | |
| Solar Thermal | N/A | \$5,390 | N/A |
| Solar Photovoltaic (20 MW) | \$2,671 | \$4,450 | (67%) |
| Solar Photovoltaic (150 MW) | N/A | \$4,120 | N/A |
| Solar Photovoltaic -Tracking (20 MW) | \$2,644 | N/A | N/A |
| Solar Photovoltaic - Tracking (150 MW) | \$2,534 | N/A | N/A |
| Geothermal – Dual Flash | N/A | \$6,641 | N/A |
| Geothermal – Binary | N/A | \$4,640 | N/A |
| Municipal Solid Waste | | | |
| Municipal Solid Waste | N/A | \$8,843 | N/A |
| Hydroelectric | | | |
| Conventional Hydroelectric | N/A | \$3,123 | N/A |
| Pumped Storage | N/A | \$5,626 | N/A |
| Battery Storage (4 MW) | 2,813 | N/A | N/A |

Table 3. Status of technologies and components modeled by EIA

| | Revolutionary | Evolutionary | Mature |
|---|---------------|--------------|--------|
| Pulverized Coal | | | X |
| Pulverized Coal with CCS | | | |
| - Non-CCS portion of Pulverized Coal Plant | | | X |
| - CCS | X | | |
| Integrated Gasification Combined Cycle | | | |
| - Advanced Combustion Turbine | | X | |
| - Heat Recovery Steam Generator | | | X |
| - Gasifier | | X | |
| - Balance of Plant | | | X |
| Conventional Natural Gas Combined Cycle | | | |
| - Conventional Combustion Turbine | | | X |
| - Heat Recovery Steam Generator | | | X |
| - Balance of Plant | | | X |
| Advanced Natural Gas Combined Cycle | | | |
| - Advanced Combustion Turbine | | X | |
| - Heat Recovery Steam Generator | | | X |
| - Balance of Plant | | | X |
| Advanced Natural Gas Combined Cycle with CCS | | | |
| - Advanced Combustion Turbine | | X | |
| - Heat Recovery Steam Generator | | | X |
| - Balance of Plant | | | X |
| - CCS | X | | |
| Conventional Natural Gas Combustion Turbine | | | |
| - Conventional Combustion Turbine | | | X |
| - Balance of Plant | | | X |
| Advanced Natural Gas Combustion Turbine | | | |
| - Advanced Combustion Turbine | | X | |
| - Balance of Plant | | | X |
| Advanced Nuclear | X | | |
| Biomass | | | |
| - Pulverized Coal | | | X |
| - Fuel Preparation | | X | |
| Geothermal | | X | |
| Municipal Solid Waste/Landfill Gas | | | X |
| Conventional Hydroelectric | | | X |
| Wind | | | |
| - Onshore/Common Components | | | X |
| - Offshore Components | X | | |
| Solar Thermal | X | | |
| Solar PV | | | |
| - Modules (Utility and End Use) | | X | |
| - Utility Balance of Plant | | X | |

Table 4. Regional cost adjustments for technologies modeled by NEMS by Electric Market Module (EMM) region¹⁵

| EMM Region | PC | | | Conv. | Adv. | Conv. | Adv. | Adv. CC | Fuel | | | | | On- shore | Off- shore | Solar | Solar |
|---------------|------|------|-------|-------|------|-------|------|------------|------|---------|---------|------|------|--------------|---------------|-------|-------|
| | PC | IGCC | w/CCS | CT | CT | CC | CC | w/CCS | Cell | Nuclear | Biomass | MSW | Wind | Wind | Thermal | PV | |
| 1 (ERCT) | 0.91 | 0.92 | 0.92 | 0.93 | 0.95 | 0.91 | 0.92 | 0.9 | 0.96 | 0.96 | 0.93 | 0.93 | 0.95 | 0.92 | 0.86 | 0.87 | |
| 2 (FRCC) | 0.92 | 0.93 | 0.94 | 0.93 | 0.93 | 0.91 | 0.92 | 0.92 | 0.97 | 0.97 | 0.94 | 0.94 | N/A | N/A | 0.89 | 0.9 | |
| 3 (MRDE) | 1.01 | 1.01 | 0.99 | 0.99 | 1.01 | 0.99 | 0.99 | 0.97 | 0.99 | 1.01 | 0.99 | 0.98 | 0.99 | 0.97 | N/A | 0.96 | |
| 4 (MROW) | 0.95 | 0.96 | 0.96 | 0.98 | 1.00 | 0.97 | 0.97 | 0.96 | 0.98 | 0.98 | 0.96 | 0.96 | 1.03 | 1.01 | N/A | 0.95 | |
| 5 (NEWE) | 1.1 | 1.09 | 1.05 | 1.16 | 1.2 | 1.16 | 1.15 | 1.08 | 1.01 | 1.05 | 1.04 | 1.02 | 1.06 | 1.03 | N/A | 1.03 | |
| 6 (NYCW) | N/A | N/A | N/A | 1.63 | 1.68 | 1.68 | 1.66 | 1.5 | 1.14 | N/A | 1.26 | 1.26 | N/A | 1.29 | N/A | N/A | |
| 7 (NYLI) | N/A | N/A | N/A | 1.63 | 1.68 | 1.68 | 1.66 | 1.5 | 1.14 | N/A | 1.26 | 1.26 | 1.25 | 1.29 | N/A | 1.45 | |
| 8 (NYUP) | 1.11 | 1.1 | 1.05 | 1.17 | 1.22 | 1.16 | 1.16 | 1.06 | 1.00 | 1.07 | 1.03 | 1.00 | 1.01 | 0.99 | N/A | 0.98 | |
| 9 (RFCE) | 1.15 | 1.14 | 1.09 | 1.21 | 1.25 | 1.21 | 1.21 | 1.12 | 1.02 | 1.08 | 1.07 | 1.03 | 1.05 | 1.03 | N/A | 1.05 | |
| 10 (RFCM) | 0.98 | 0.98 | 0.98 | 1.01 | 1.02 | 1.00 | 1.00 | 0.99 | 0.99 | 0.99 | 0.98 | 0.98 | 1.00 | 0.98 | N/A | 0.97 | |
| 11 (RFCW) | 1.05 | 1.04 | 1.02 | 1.05 | 1.06 | 1.04 | 1.04 | 1.02 | 1.00 | 1.03 | 1.02 | 1.00 | 1.02 | 1.01 | N/A | 1.00 | |
| 12 (SRDA) | 0.92 | 0.93 | 0.93 | 0.95 | 0.96 | 0.93 | 0.93 | 0.92 | 0.97 | 0.96 | 0.93 | 0.94 | 0.96 | 1.00 | N/A | 0.89 | |
| 13 (SRGW) | 1.07 | 1.06 | 1.05 | 1.05 | 1.05 | 1.06 | 1.05 | 1.04 | 1.02 | 1.03 | 1.03 | 1.03 | 1.04 | 1.00 | N/A | 1.05 | |
| 14 (SRSE) | 0.92 | 0.93 | 0.93 | 0.95 | 0.97 | 0.93 | 0.94 | 0.92 | 0.97 | 0.96 | 0.93 | 0.94 | 0.96 | 0.93 | N/A | 0.89 | |
| 15 (SRCE) | 0.93 | 0.94 | 0.94 | 0.94 | 0.95 | 0.93 | 0.93 | 0.92 | 0.97 | 0.97 | 0.94 | 0.94 | 0.96 | 1.00 | N/A | 0.89 | |
| 16 (SRVC) | 0.89 | 0.91 | 0.91 | 0.91 | 0.93 | 0.88 | 0.89 | 0.88 | 0.96 | 0.95 | 0.91 | 0.91 | 0.95 | 0.92 | N/A | 0.84 | |
| 17 (SPNO) | 0.98 | 0.99 | 0.98 | 1.00 | 1.01 | 0.99 | 0.99 | 0.98 | 0.99 | 0.99 | 0.98 | 0.98 | 1.02 | N/A | 0.97 | 0.97 | |
| 18 (SPSO) | 0.98 | 0.99 | 0.98 | 1.00 | 1.01 | 0.99 | 0.99 | 0.98 | 0.99 | 0.99 | 0.98 | 0.98 | 1.02 | N/A | 0.97 | 0.97 | |
| 19 (AZNM) | 1.00 | 1.00 | 0.99 | 1.03 | 1.04 | 1.02 | 1.02 | 1.00 | 0.99 | 1.00 | 1.00 | 0.99 | 1.03 | 1.00 | 0.99 | 0.99 | |
| 20 (CAMX) | N/A | N/A | 1.12 | 1.24 | 1.29 | 1.25 | 1.24 | 1.15 | 1.03 | N/A | 1.08 | 1.06 | 1.12 | 1.05 | 1.13 | 1.11 | |
| 21 (NWPP) | 1.01 | 1.01 | 1.00 | 1.02 | 1.03 | 1.01 | 1.01 | 0.99 | 0.99 | 1.01 | 1.00 | 0.98 | 1.05 | 1.02 | 0.99 | 0.99 | |
| 22 (RMPPA) | 0.99 | 0.99 | 0.97 | 1.02 | 1.05 | 1.01 | 1.01 | 0.96 | 0.98 | 1.01 | 0.97 | 0.95 | 1.03 | N/A | 0.93 | 0.93 | |

Note: Geothermal and Hydroelectric plants are not included in the table because EIA uses site specific cost estimates for these technologies which include regional factors.

¹⁵ The regional tables in the report were aggregated to the appropriate Electricity Market Module region in order to represent regional cost factors in NEMS
U.S. Energy Information Administration | Capital Cost Estimates for Utility Scale Electricity Generating Plants

Appendix A - Acronym List

BFB - Bubbling Fluidized Bed
CC - Combined Cycle
CCS - Carbon Capture and Sequestration
CT - Combustion Turbine
CTCB – Conversion to Biomass Co-Firing
CTNG – Conversion to Natural Gas
GCBC – Greenfield Conversion Biomass Co-Firing
IGCC - Integrated Gasification Combined Cycle
PC - Pulverized Coal
PV – Photovoltaic
RICE – Reciprocating Internal Combustion Engine
USC – Ultra Supercritical Coal

Appendix B – Full Report

**EOP III TASK 10388, SUBTASK 4 and TASK 10687, SUBTASK
2.3.1 – REVIEW OF
POWER PLANT COST AND PERFORMANCE
ASSUMPTIONS FOR NEMS**

**Technology Documentation Report
FINAL - REVISED**

**Prepared by:
LEIDOS ENGINEERING, LLC**

**Prepared For:
Energy Information Administration
Office of Electricity, Coal, Nuclear, and Renewables Analysis
Chris Namovicz
Jim Diefenderfer**

April 2016

Disclaimer

Certain statements included in this report constitute forward-looking statements. The achievement of certain results or other expectations contained in such forward-looking statements involve known and unknown risks, uncertainties and other factors which may cause actual results, performance or achievements described in the report to be materially different from any future results, performance or achievements expressed or implied by such forward-looking statements. We do not plan to issue any updates or revisions to the forward-looking statements if or when our expectations or events, conditions, or circumstances on which such statements are based occur.

TABLE OF CONTENTS

| | | |
|-------|---|-----|
| 1. | Introduction | 1-1 |
| 1.1 | Technologies Assessed | 1-1 |
| 2. | General Basis for Technology Evaluation Basis | 2-1 |
| 2.1 | Leidos Engineering, LLC Background | 2-1 |
| 2.2 | Base Fuel Characteristics | 2-1 |
| 2.3 | Environmental Compliance Basis | 2-4 |
| 2.4 | Local Capacity Adjustments | 2-4 |
| 2.5 | Technology Specifications | 2-6 |
| 2.6 | Cost Estimation Methodology | 2-6 |
| 2.6.1 | Capital Cost | 2-6 |
| 2.6.2 | Operation and Maintenance (O&M) Expenses | 2-7 |
| 3. | Ultra Supercritical Coal (USC) | 3-1 |
| 3.1 | Mechanical Equipment and Systems | 3-1 |
| 3.2 | Electrical and Control Systems | 3-2 |
| 3.3 | Off-Site Requirements | 3-2 |
| 3.4 | Capital Cost Estimate | 3-3 |
| 3.5 | O&M Estimate | 3-4 |
| 3.6 | Environmental Compliance Information | 3-5 |
| 4. | Ultra Supercritical Coal with CCS (USC/CCS) | 4-1 |
| 4.1 | Mechanical Equipment and Systems | 4-1 |
| 4.2 | Electrical and Control Systems | 4-2 |
| 4.3 | Off-Site Requirements | 4-2 |
| 4.4 | Capital Cost Estimate | 4-2 |
| 4.5 | O&M Estimate | 4-4 |
| 4.6 | Environmental Compliance Information | 4-4 |
| 5. | Pulverized Coal Brownfield Conversion to Natural Gas (CTNG) | 5-1 |
| 5.1 | Mechanical Equipment and Systems | 5-1 |
| 5.2 | Electrical and Control Systems | 5-2 |
| 5.3 | Off-Site Requirements | 5-2 |
| 5.4 | Capital Cost Estimate | 5-2 |
| 5.5 | O&M Estimate | 5-4 |

- 5.6 Environmental Compliance Information 5-4
- 6. Pulverized Coal Greenfield with 10-15% Biomass (GCBC) 6-1
 - 6.1 Mechanical Equipment and Systems 6-1
 - 6.2 Electrical and Control Systems 6-1
 - 6.3 Off-Site Requirements 6-2
 - 6.4 Capital Cost Estimate 6-2
 - 6.5 O&M Estimate 6-3
 - 6.6 Environmental Compliance Information 6-3
- 7. Pulverized Coal Brownfield Conversion to Coal with 10% Biomass – 30 MW Co-Firing (CTCB) 7-1
 - 7.1 Mechanical Equipment and Systems 7-1
 - 7.2 Electrical and Control Systems 7-1
 - 7.3 Off-Site Requirements 7-2
 - 7.4 Capital Cost Estimate 7-2
 - 7.5 O&M Estimate 7-3
 - 7.6 Environmental Compliance Information 7-3
- 8. Conventional Natural Gas Combined Cycle (NGCC) 8-1
 - 8.1 Mechanical Equipment and Systems 8-1
 - 8.2 Electrical and Control Systems 8-2
 - 8.3 Off-Site Requirements 8-2
 - 8.4 Capital Cost Estimate 8-3
 - 8.5 O&M Estimate 8-5
 - 8.6 Environmental Compliance Information 8-5
- 9. Advanced Generation Natural Gas Combined Cycle (AG-NGCC) 9-1
 - 9.1 Mechanical Equipment and Systems 9-1
 - 9.2 Electrical and Control Systems 9-1
 - 9.3 Off-Site Requirements 9-1
 - 9.4 Capital Cost Estimate 9-2
 - 9.5 O&M Estimate 9-2
 - 9.6 Environmental Compliance Information 9-3
- 10. Conventional Combustion Turbine (CT) 10-1
 - 10.1 Mechanical Equipment and Systems 10-1
 - 10.2 Electrical and Control Systems 10-1

| | | |
|------|---------------------------------------|------|
| 10.3 | Off-Site Requirements | 10-1 |
| 10.4 | Capital Cost Estimate | 10-2 |
| 10.5 | O&M Estimate | 10-3 |
| 10.6 | Environmental Compliance Information | 10-4 |
| 11. | Advanced Combustion Turbine (ACT) | 11-1 |
| 11.1 | Mechanical Equipment and Systems | 11-1 |
| 11.2 | Electrical and Control Systems | 11-1 |
| 11.3 | Off-Site Requirements | 11-1 |
| 11.4 | Capital Cost Estimate | 11-1 |
| 11.5 | O&M Estimate | 11-2 |
| 11.6 | Environmental Compliance Information | 11-3 |
| 12. | Advanced Nuclear (AN) | 12-1 |
| 12.1 | Mechanical Equipment and Systems | 12-1 |
| 12.2 | Electrical and Control Systems | 12-3 |
| 12.3 | Off-Site Requirements | 12-3 |
| 12.4 | Capital Cost Estimate | 12-4 |
| 12.5 | O&M Estimate | 12-5 |
| 12.6 | Environmental Compliance Information | 12-5 |
| 13. | Biomass Bubbling Fluidized Bed (BBFB) | 13-1 |
| 13.1 | Mechanical Equipment and Systems | 13-1 |
| 13.2 | Electrical and Control Systems | 13-2 |
| 13.3 | Off-Site Requirements | 13-2 |
| 13.4 | Capital Cost Estimate | 13-2 |
| 13.5 | O&M Estimate | 13-4 |
| 13.6 | Environmental Compliance Information | 13-4 |
| 14. | Onshore Wind (WN) | 14-1 |
| 14.1 | Mechanical Equipment and Systems | 14-1 |
| 14.2 | Electrical and Control Systems | 14-1 |
| 14.3 | Off-Site Requirements | 14-2 |
| 14.4 | Capital Cost Estimate | 14-2 |
| 14.5 | O&M Estimate | 14-4 |
| 14.6 | Environmental Compliance Information | 14-4 |

| | | |
|------|---|------|
| 15. | Utility-Scale Photovoltaic (PV) Facility | 15-1 |
| 15.1 | Mechanical Equipment and Systems | 15-1 |
| 15.2 | Electrical and Control Systems | 15-2 |
| 15.3 | Off-Site Requirements | 15-2 |
| 15.4 | Capital Cost Estimate | 15-2 |
| 15.5 | O&M Estimate | 15-6 |
| 15.6 | Environmental Compliance Information | 15-7 |
| 16. | Reciprocating Internal Combustion Engine (RICE) | 16-1 |
| 16.1 | Mechanical Equipment and Systems | 16-1 |
| 16.2 | Electrical and Control Systems | 16-2 |
| 16.3 | Off-Site Requirements | 16-2 |
| 16.4 | Capital Cost Estimate | 16-3 |
| 16.5 | O&M Estimate | 16-4 |
| 16.6 | Environmental Compliance Information | 16-4 |
| 17. | Battery Storage (BES) | 17-1 |
| 17.1 | Mechanical Equipment and Systems | 17-1 |
| 17.2 | Electrical and Control Systems | 17-1 |
| 17.3 | Off-Site Requirements | 17-2 |
| 17.4 | Capital Cost Estimate | 17-2 |
| 17.5 | O&M Estimate | 17-4 |
| 17.6 | Environmental Compliance Information | 17-4 |

LIST OF FIGURES

| | |
|--|------|
| Figure 3-1 – Ultra Supercritical Coal Design Configuration | 3-2 |
| Figure 4-1 – USC Facility Diagram | 4-1 |
| Figure 4-2 – USC/CCS Facility Diagram | 4-2 |
| Figure 5-1 – CTNG Design Configuration | 5-2 |
| Figure 6-1 – GCBC Design Configuration | 6-1 |
| Figure 7-1 – CTCB Design Configuration | 7-1 |
| Figure 8-1 – Conventional NGCC Design Configuration | 8-2 |
| Figure 9-1 – AG-NGCC Design Configuration | 9-1 |
| Figure 10-1 – Conventional CT Design Configuration | 10-1 |
| Figure 11-1 – Advanced CT Design Configuration | 11-1 |
| Figure 12-1 – AN Design Configuration | 12-3 |
| Figure 13-1 – BBFB Design Configuration | 13-1 |
| Figure 14-1 – WN Design Configuration | 14-1 |
| Figure 15-1 – Typical PV Facility | 15-1 |
| Figure 16-1 – RICE Schematic Configuration | 16-2 |
| Figure 17-1 – BES Design Configuration | 17-1 |

LIST OF TABLES

| | |
|---|------|
| Table 1-1 – List of Technologies for Review | 1-2 |
| Table 2-1 – Reference Coal Specification | 2-2 |
| Table 2-2 – Natural Gas Specification | 2-3 |
| Table 2-3 – Wood Biomass Specification ⁽¹⁾ | 2-3 |
| Table 2-4 – CT Capacity Adjustments | 2-5 |
| Table 2-5 – Technology Performance Specifications | 2-10 |
| Table 3-1 – Base Plant Site Capital Cost Estimate for USC | 3-3 |
| Table 3-3 – O&M Expenses for USC (650,000 kw) | 3-5 |
| Table 3-4 – Environmental Emissions for USC | 3-5 |
| Table 4-1 – Base Plant Site Capital Cost Estimate for USC/CCS | 4-3 |
| Table 4-3 – O&M Expenses for USC/CCS (650,000 kW) | 4-4 |
| Table 4-4 – Environmental Emissions for USC/CCS | 4-4 |
| Table 5-1 – Base Plant Site Capital Cost Estimate for CTNG | 5-3 |
| Table 5-3 – O&M Expenses for CTNG | 5-4 |
| Table 5-4 – Environmental Emissions for CTNG | 5-4 |
| Table 6-1 – Location-Based Costs for GCBC | 6-2 |
| Table 6-3 – O&M Expenses for GCBC | 6-3 |
| Table 6-4 – Environmental Emissions for GCBC | 6-4 |
| Table 7-1 – Location-Based Costs for CTCB | 7-2 |
| Table 7-3 – O&M Expenses for CTCB | 7-3 |
| Table 7-4 – Environmental Emissions for CTCB | 7-3 |
| Table 8-1 – Base Plant Site Capital Cost Estimate For Conventional NGCC | 8-3 |
| Table 8-3 – O&M Expenses for Conventional NGCC | 8-5 |
| Table 8-4 – Environmental Emissions for Conventional NGCC | 8-5 |
| Table 9-1 – Base Plant Site Capital Cost Estimate for AG-NGCC | 9-2 |
| Table 9-3 – O&M Expenses for AG-NGCC | 9-3 |
| Table 9-4 – Environmental Emissions for AG-NGCC | 9-3 |
| Table 10-1 – Base Plant Site Capital Cost Estimate For Conventional CT | 10-2 |
| Table 10-3 – O&M Expenses for Conventional CT | 10-4 |
| Table 10-4 – Environmental Emissions for Conventional CT | 10-4 |

| | |
|--|------|
| Table 11-1 – Base Plant Site Capital Cost Estimate for Advanced CT | 11-2 |
| Table 11-3 – O&M Expenses for Advanced CT | 11-3 |
| Table 11-4 – Environmental Emissions for Advanced CT | 11-3 |
| Table 12-1 – Base Plant Site Capital Cost Estimate For AN | 12-4 |
| Table 12-3 – O&M Expenses for AN | 12-5 |
| Table 12-4 – Environmental Emissions for AN | 12-5 |
| Table 13-1 – Base Plant Site Capital Cost Estimate For BBFB | 13-3 |
| Table 13-3 – O&M Expenses for BBFB | 13-4 |
| Table 13-4 – Environmental Emissions for BBFB | 13-5 |
| Table 14-1 – Location-Based Costs for WN | 14-3 |
| Table 14-3 – O&M Expenses for WN | 14-4 |
| Table 14-4 – Environmental Emissions for WN | 14-4 |
| Table 15-1 – Base Plant Site Capital Cost Estimate For PV | 15-3 |
| Table 15-2 – Base Plant Site Capital Cost Estimate For PV | 15-4 |
| Table 15-3 – Base Plant Site Capital Cost Estimate For PV | 15-5 |
| Table 15-7 – O&M Expenses for PV FIXED Facility (20 MW) | 15-6 |
| Table 15-8 – O&M Expenses for PV-tracker Facility (20 MW) | 15-6 |
| Table 15-9 – O&M Expenses for PV-tracking Facility (150 MW) | 15-6 |
| Table 15-10 – Environmental Emissions for PV | 15-7 |
| Table 16-1 – Location-Based Costs for RICE | 16-3 |
| Table 16-3 – O&M Expenses for RICE | 16-4 |
| Table 16-4 – Environmental Emissions for RICE | 16-5 |
| Table 17-1 – Location-Based Costs for BES | 17-3 |
| Table 17-3 – O&M Expenses for BES | 17-4 |
| Table 17-4 – Environmental Emissions for BES | 17-4 |
| Table 3-2 – Location-Based Costs for USC (650,000 kW) | A-1 |
| Table 4-2 – Location-Based Costs for USC/CCS Facility (650,000 kW) | A-3 |
| Table 5-2 – Location-Based Costs for CTNG Facility (300,000 kW) | A-5 |
| Table 6-2 – Location-Based Costs for GCBC Facility (300,000 kW) | A-7 |
| Table 7-2 – Location-Based Costs for CTCB Facility (300,000 kW) | A-9 |
| Table 8-2 – Location-Based Costs for NGCC Facility (702,000 kW) | A-11 |
| Table 9-2 – Location-Based Costs for AG-NGCC Facility (429,000 kW) | A-13 |

| | |
|--|------|
| Table 10-2 – Location-Based Costs for CT Facility (100,000 kW) | A-15 |
| Table 11-2 – Location-Based Costs for ACT Facility (237,000 kW) | A-17 |
| Table 12-2 – Location-Based Costs for AN Facility (2,234,000 kW) | A-19 |
| Table 13-2– Location-Based Costs for BBFB Facility (50,000 kW) | A-21 |
| Table 14-2 – Location-Based Costs for WN Facility (100,000 kW) | A-23 |
| Table 15-4 – Location-Based Costs for PV Fixed Facility (20,000 kW) | A-25 |
| Table 15-5 – Location-Based Costs for PV Tracker Facility (20,000 kW) | A-27 |
| Table 15-6 – Location-Based Costs for PV Tracker Facility (150,000 kW) | A-29 |
| Table 16-2 – Location-Based Costs for RICE Facility (85,000 kW) | A-31 |
| Table 17-2 – Location-Based Costs for BES Facility (4,000 kW) | A-33 |

LIST OF ACRONYMS AND ABBREVIATIONS

| | |
|--------------------------------|---|
| AC | Alternating Current |
| AG | Advanced Generation |
| AG-NGCC | Advanced Generation Natural Gas Combined Cycle |
| AG-NGCC/CCS | Advanced Generation Natural Gas Combined Cycle with CCS |
| AGR | Acid Gas Removal |
| AN | Advanced Nuclear |
| ASU | Air Separation Unit |
| BACT | Best Available Control Technology |
| BBFB | Biomass Bubbling Fluidized Bed |
| BES | Battery Storage |
| BFB | Bubbling Fluidized Bed |
| BOP | Balance-of-Plant |
| Btu | British Thermal Unit |
| C | Carbon |
| CCS | Carbon Capture and Sequestration |
| C ₂ H ₆ | Ethane |
| C ₃ H ₈ | Propane |
| C ₄ H ₁₀ | <i>n</i> -Butane |
| CH ₄ | Methane |
| CO | Carbon Monoxide |
| CO ₂ | Carbon Dioxide |
| COS | Carbonyl Sulfide |
| CT | Combustion Turbine |
| DC | Direct Current |
| DCS | Distributed Control System |
| DLN | Dry Low-NO _x Combustion |
| EIA | Energy Information Administration |
| EMM | Electricity Market Module of NEMS |
| EPC | Engineering, Procurement and Construction |
| °F | Degrees Fahrenheit |
| FGD | Flue Gas Desulfurization |
| FOM | Fixed O&M |
| GHG | Greenhouse Gas |
| GSU | Generator Step-up Transformer |
| GT | Geothermal |
| H ₂ S | Hydrogen Sulfide |
| HHV | High(er) Heating Value |
| HP | High Pressure |
| HRSG | Heat Recovery Steam Generator |
| HY | Hydroelectric |
| Hz | Hertz |
| I&C | Instrumentation and Controls |
| IP | Intermediate Pressure |
| ISO | International Standard Organization |
| kg | Kilograms |
| KJ | Kilojoules |
| kW | Kilowatt |
| kWh | Kilowatt-hour |

| | |
|-----------------|--|
| kV | Kilovolt |
| kVA | kilovolt-amperes |
| lb | Pound |
| Leidos | Leidos Engineering, LLC |
| LHV | Low(er) Heating Value |
| LP | Low Pressure |
| MEA | Monoethanolamine |
| MJ | Mega joules |
| MMBtu | Million Btu |
| MSW | Municipal Solid Waste |
| MW | Megawatt |
| MWe | Megawatts Electric |
| MWh | Megawatt-hour |
| MVA | Mega-volt-amperes |
| N ₂ | Nitrogen |
| NEMS | National Energy Modeling System |
| NGCC | Natural Gas Combined Cycle |
| NH ₃ | Ammonia |
| NO _x | Oxides of Nitrogen |
| O ₂ | Oxygen |
| O&M | Operating and Maintenance |
| NO _x | Nitrogen Oxides |
| ppmv | Parts per Million Volume Dry |
| PS | Pumped Storage |
| psia | Pounds per Square Inch Absolute |
| PV | Photovoltaic |
| PWR | Pressurized Water Reactor |
| RCS | Reactor Coolant System |
| RICE | Reciprocating Internal Combustion Engine |
| S | Sulfur |
| SCADA | Supervisory Control and Data Acquisition |
| scf | Standard Cubic Feet |
| scm | Standard Cubic Meters |
| SCR | Selective Catalytic Reduction |
| SNCR | Selective Non-catalytic Reduction |
| SO | Solar Thermal |
| SO ₂ | Sulfur Dioxide |
| SRU | Sulfur Recovery Unit |
| ST | Steam Turbine |
| TGF | Turbine Generating Facility |
| U.S. | United States |
| USC | Ultra Supercritical Coal Facility |
| USC/CCS | Ultra Supercritical Coal with CCS |
| V | Volt |
| VOM | Variable Operating and Maintenance |
| WFGD | Wet Flue Gas Desulfurization |
| WN | Onshore Wind |
| WTG | Wind Turbine Generator |

1. Introduction

This report presents Leidos Engineering, LLC (“Leidos”) performance and cost assessment of power generation technologies utilized by the Energy Information Administration (“EIA”) in the Electricity Market Module (“EMM”) of the National Energy Modeling System (“NEMS”). The assessment for each of the technologies considered includes the following:

- Overnight construction costs, construction lead times, first year of commercial application, typical unit size, contingencies, fixed and variable operating costs, and efficiency (heat rate). The analysis was conducted to ensure that the overnight cost estimates developed for use in the EMM for electric generating technologies are consistent in scope, accounting for generally all costs in the planning and development of a power plant including the basic interconnection to the grid at the plant site and other utility interconnections, but excluding financing costs.
- For emission control technologies, the removal rates for pollutants and other assumptions were examined.
- Review of the regional multipliers that are used to represent local conditions, such as labor rates that are included in EMM.
- Review of the appropriateness of technology-specific project and process contingency assumptions (capturing differences between engineering estimates and realized costs for new technologies).
- Where possible, compare the values used by EIA with those for recently built facilities in the United States (“U.S.”) or abroad. Where such actual cost estimates do not exist, an assessment was made between values used by EIA and other analyst estimates, as well as vendor estimates.
- The key factors expected to drive each technology’s costs.
- Document the source and basis for final recommendations for altering or retaining the various assumptions.

1.1 Technologies Assessed

The following table lists all technologies to be assessed in this project.

TABLE 1-1 – LIST OF TECHNOLOGIES FOR REVIEW

| TECHNOLOGY | DESCRIPTION | COMMENTS |
|---|--|---|
| Ultra Supercritical Coal (USC) | 650 MWe with advanced pollution control technologies | Greenfield Installation |
| Ultra Supercritical Coal with Carbon Capture and Sequestration (USC/CCS) | 650 MWe; supercritical; with advanced pollution control technologies, including CCS technologies | Greenfield Installation |
| Pulverized Coal Brownfield Conversion to Natural Gas (CTNG) | 300 MWe | Brownfield Installation |
| Pulverized Coal Greenfield with 10%-15% Biomass Co-Firing (GCBC) | 300 MWe | Greenfield Installation |
| Pulverized Coal Brownfield Conversion to Coal with 10% Biomass Co-Firing (CTCB) | 300 MWe net plant output; 30 MWe of added Biomass | Brownfield Installation, added 30MWe of Wood Fuel |
| Conventional Natural Gas Combined Cycle (NGCC) | 702 MWe; F-Class system | Greenfield Installation |
| Advanced Generation Natural Gas Combined Cycle (AG-NGCC) | 429 MWe; H-Class system | Greenfield Installation |
| Conventional Combustion Turbine (CT) | 100 MWe; (2) LM 6000 Class turbines | Greenfield Installation |
| Advanced Combustion Turbine (ACT) | 237 MWe; F-Class turbine | Greenfield Installation |
| Advanced Nuclear (AN) | 2,234 234MWe; (2) AP1000 PWR Basis | Brownfield Installation |
| Biomass Bubbling Fluidized Bed (BBFB) | 50 MWe | Greenfield Installation; Wood Fuel |
| Wind Farm – Onshore (WN) | 100 MWe; (56) 1.79 MWe WTG’s | Greenfield Installation |
| Utility-Scale Photovoltaic (PV) | 20 MWe –AC Fixed; 20 MWe-AC Tracker and 150 MWe – AC Tracker | Greenfield Installation |
| Internal Combustion (IC) | 85 MWe; (5) Wartsila 17MWe Engines | Greenfield Installation |
| Battery Storage (BES) | 4 MWe | Greenfield Installation |

2. General Basis for Technology Evaluation Basis

This section specifies the general evaluation basis used for all technologies reviewed herein.

2.1 Leidos Engineering, LLC Background

Leidos is a technical solutions and infrastructure consulting firm that has been providing technical and business consulting in the energy industry since 1942. Particularly, Leidos has supported the purchase, sale, financing and Owner's advisory consulting for tens-of-billions of dollars of power plants across the world in all commercial power generating technologies as well as many emerging technologies. This background has supported Leidos' acumen with respect to construction costs, operating costs, technology development and evolution, as well as trends in environmental regulation and compliance.

2.2 Base Fuel Characteristics

This section provides a general fuel basis for each of the fuel types utilized by the technologies considered in this report, which was listed in Table 1-1. Each of the technologies that combust a fuel has the ability to operate over a range of fuels; thus Table 2-1, Table 2-2 and Table 2-3 show a typical fuel specification for coal, natural gas, and wood-biomass, respectively.

TABLE 2-1 – REFERENCE COAL SPECIFICATION

| Rank | Bituminous | |
|---|--------------------------------|------------------|
| Seam | Illinois No. 6 (Herrin) | |
| Source | Old Ben Mine | |
| Proximate Analysis (weight %) (Note A) | | |
| | As Received | Dry |
| Moisture | 11.12 | 0.00 |
| Ash | 9.70 | 10.91 |
| Volatile Matter | 34.99 | 39.37 |
| Fixed Carbon | 44.19 | 49.72 |
| Total | 100.00 | 100.00 |
| Sulfur | 3 | 3.38 |
| HHV ⁽¹⁾ , KJ/kg ⁽²⁾ | 27,113 | 30,506 |
| HHV, Btu/lb ⁽³⁾ | 11,666 | 13,126 |
| LHV ⁽⁴⁾ , KJ/kg | 26,151 | 29,544 |
| LHV, Btu/lb | 11,252 | 12,712 |
| Ultimate Analysis (weight %) | | |
| | As Received | Dry |
| Moisture | 11.12 | 0.00 |
| Carbon | 63.75 | 71.72 |
| Hydrogen | 4.50 | 5.06 |
| Nitrogen | 1.25 | 1.41 |
| Chlorine | 0.29 | 0.33 |
| Sulfur | 3.0 | 3.38 |
| Ash | 9.70 | 10.91 |
| Oxygen | 6.88 | 7.75 |
| Total | 100.00 (rounded) | 100.00 (rounded) |

- (1) High(er) heating value (“HHV”).
- (2) Kilojoules per kilogram (“KJ/kg”).
- (3) British thermal units per pound (“Btu/lb”).
- (4) Low(er) heating value (“LHV”).

TABLE 2-2 – NATURAL GAS SPECIFICATION

| Component | | Volume Percentage |
|------------------------|--------------------------------|-------------------|
| Methane | CH ₄ | 93.9 |
| Ethane | C ₂ H ₆ | 3.2 |
| Propane | C ₃ H ₈ | 0.7 |
| <i>n</i> -Butane | C ₄ H ₁₀ | 0.4 |
| Carbon Dioxide | CO ₂ | 1.0 |
| Nitrogen | N ₂ | 0.8 |
| Total | | 100.0 |
| | | LHV |
| | | HHV |
| kJ/kg | | 47,764 |
| MJ/scm ⁽¹⁾ | | 35 |
| | | 52,970 |
| | | 39 |
| Btu/lb | | 20,552 |
| Btu/scf ⁽²⁾ | | 939 |
| | | 22,792 |
| | | 1,040 |

(1) Mega joules per standard cubic meter (“MJ/scm”).

(2) Standard cubic feet (“scf”).

TABLE 2-3 – WOOD BIOMASS SPECIFICATION⁽¹⁾

| Component | | Volume Percentage |
|-----------------------|----------------|-------------------|
| Moisture | | 17.27 |
| Carbon | C | 41.55 |
| Hydrogen | H ₂ | 4.77 |
| Nitrogen | N ₂ | 0.37 |
| Sulfur | S | <0.01 |
| Ash | | 2.35 |
| Oxygen ⁽²⁾ | O ₂ | 33.75 |
| Total | | 100.0 |
| | | HHV |
| Btu/lb | | 6,853 |

(1) As received.

(2) Oxygen by Difference.

2.3 Environmental Compliance Basis

The technology assessments considered the emissions rates after implementation of best available control technology (“BACT”), including sulfur dioxide (“SO₂”), oxides of nitrogen (“NO_x”), particulate matter, mercury, and carbon dioxide (“CO₂”). With respect to CCS technologies, which are not currently considered “proven” or BACT by regulating bodies, Leidos assumed capture and sequestration technologies that are currently in development for large-scale deployment, as discussed herein, and at industry expected rates of CO₂ removal (i.e., 30 percent).

2.4 Local Capacity Adjustments

For power plants that use CT technologies, adjustments were made for regional ambient conditions. The adjustments took into consideration that CTs are machines that produce power proportional to mass flow. Since air density is inversely proportional to temperature, ambient temperature has a strong influence on the capacity of a given technology utilizing a CT (e.g., peaking power plant, combined-cycle power plant, and some gasification power plants). Additionally, relative humidity impacts the available capacity of a CT and consequently a CT-based power plant, primarily driven by the base assumption that the CT-based technologies incorporate inlet evaporative cooling. By circulating water across a porous media in the CT compressor inlet (across which the air flows), the inlet evaporative cooling reduces the difference between the ambient dry-bulb temperature (the temperature that is typically reported to the public as a measure of “local temperature”) and the wet-bulb temperature (a measure of relative humidity). Since inlet evaporative cooling is limited by the wet-bulb temperature, the effectiveness of these devices increases in areas of high dry-bulb temperature and low relative humidity. The final adjustment for ambient conditions made for the CT-based plants is ambient pressure, which on average (notwithstanding high or low pressure weather fronts that pass through a region) takes into consideration elevation (average number of feet above sea level). Air density is proportional to ambient pressure.

Table 2-4 provides the aggregate capacity adjustment for each location, which provides regional differences related to capital costs against the International Standard Organization (“ISO”) net capacity for the CT-based power plant technologies.

2.5 Technology Specifications

This section provides the base performance specifications for each technology. Table 2-5 provides the current technology specifications.

2.6 Cost Estimation Methodology

The approach taken in this latest cost analysis of capital and operating estimates concentrated primarily in these three areas:

1. Escalation over the past three years.
2. Technology-specific changes in pricing; for example, overall wind and solar capex pricing lowered due to lower equipment pricing.
3. Updated actual costs being made available to Projects with which we are familiar.

2.6.1 Capital Cost

A summary base capital cost estimate (“Cost Estimate”) was developed for each power plant technology, based on a generic facility of a certain size (capacity) and configuration, and assuming a non-specific U.S. location with no unusual location impacts (e.g., urban construction constraints) or infrastructure needs (e.g., a project-dedicated interconnection upgrade cost).

Each Cost Estimate was developed assuming costs in first quarter 2016 dollars on an “overnight” capital cost basis. In each Cost Estimate, the total project engineering, procurement and construction (“EPC”) cost was organized into the following categories:

- Civil/structural material and installation,
- Mechanical equipment supply and installation,
- Electrical instrumentation and controls (“I&C”) supply and installation,
- Project indirect costs, fees and contingency, and
- Owner’s costs (excluding project financing costs).

It should be noted that an EPC (turnkey) or equipment supply/balance of plant, as applicable to a given technology, contracting approach was assumed for each of the technologies, which included a risk sharing between the project owner and project construction contractor that, based on our experience, would be required in typical financing markets. This approach does not always result in the lowest cost of construction; however, on average, we believe this approach to result in an achievable cost of construction, given the other considerations discussed herein.

In addition to the base Cost Estimate provided for the given technology, specific regional cost differences were determined. Regional costs for 64 unique locations in the U.S. were analyzed. Eleven subcategories were used (depending on the specific technology under review) to estimate the differences in various regions of the U.S. for the each power plant technology. The regional analyses include, but are not limited to, assessing the cost differences for outdoor installation considerations, air-cooled condensers versus cooling tower issues, seismic design differences, zero-water discharge issues, local enhancements, remote location issues, urban high-density population issues, labor wage and productivity differences, location adjustments, owner cost

differences, and the increase in overheads associated with these locations. More detail with respect to regional differences for each given technology is provided in the following sections.

2.6.1.1 Costing Scope

The *civil and structural costs* include allowance for site preparation, such as clearing, roads, drainage, underground utilities installation, concrete for foundations, piling material, structural steel supply and installation, and buildings.

The *mechanical equipment supply and installation* includes major equipment (technology and process dependent), including but not limited to, boilers, scrubbers, cooling towers, combustion turbines (“CT”), steam turbines (“ST”) generators, wind turbine generators (“WTG”), PV modules, as well as auxiliary equipment such as material handling, fly and bottom ash handling, pumps, condensers, and balance of plant (“BOP”) equipment such as fire protection, as applicable to a given technology.

The *electrical and I&C supply and installation* includes electrical transformers, switchgear, motor control centers, switchyards, distributed control systems (“DCS”) and instrumentation, and electrical commodities, such as wire, cable tray, and lighting.

While commodities, project equipment, and site assumptions can vary widely from project-to-project for a given technology, the Cost Estimates are based upon a cross section of projects.

The *project indirect costs* include engineering, distributable labor and materials, craft labor overtime and incentives, scaffolding costs, construction management, and start-up and commissioning. The fees and contingency include contractor overhead costs, fees and profit, and construction contingency. Contingency in this category is considered “contractor” contingency, which would be held by a given contractor to mitigate its risk in the construction of a project.

The *owner’s costs* include development costs, preliminary feasibility and engineering studies, environmental studies and permitting, legal fees, project management (including third-party management), insurance costs, infrastructure interconnection costs (e.g., gas, electricity), Owner’s Contingency, and property taxes during construction. The electrical interconnection cost includes an allowance for the plant switchyard and a subsequent interconnection to an “adjacent” (e.g. within a mile) of the plant, but does not include significant transmission system upgrades.

2.6.2 Operation and Maintenance (O&M) Expenses

O&M expenses consist of non-fuel O&M costs, owner’s expenses, and fuel-related expenses. In evaluating the non-fuel O&M expenses for use in the EMM of NEMS, we focused on non-fuel O&M costs associated with the direct operation of the given power plant technology, referred to here as the “Production Related Non-Fuel O&M Expenses,” to allow for comparison of O&M costs on the same basis.

Production Related Non-Fuel O&M Expenses include the following categories:

- Fixed O&M (“FOM”)
- Variable O&M (“VOM”)
- Major Maintenance

Presented below is a brief summary below of the expense categories included within the categories of Fixed O&M, Variable O&M, and Major Maintenance. Further, Sections 3 through 17 provide

more specific information related to Production-Related Non-Fuel O&M Expenses for each technology.

Owner's expenses, which are not addressed in this report, include expenses paid by plant owners that are plant specific and can vary significantly between two virtually identical plants in the same geographic region. For example, the owner's expenses include, but are not limited to, property taxes, asset management fees, energy marketing fees, and insurance.

2.6.2.1 Fixed O&M (FOM)

FOM expenses are those expenses (excluding fuel-related costs) incurred at a power plant that do not vary significantly with generation and include the following categories:

- Staffing and monthly fees under pertinent operating agreements
- Typical bonuses paid to the given plant operator
- Plant support equipment which consists of equipment rentals and temporary labor
- Plant-related general and administrative expenses (postage, telephone, etc.)
- Routine preventive and predictive maintenance performed during operations
- Maintenance of structures and grounds
- Other fees required for a project to participate in the relevant National Electric Reliability Council region and be in good standing with the regulatory bodies

Routine preventive and predictive maintenance expenses do not require an extended plant shutdown and include the following categories:

- Maintenance of equipment such as water circuits, feed pumps, main steam piping, and demineralizer systems
- Maintenance of electric plant equipment, which includes service water, DCS, condensate system, air filters, and plant electrical
- Maintenance of miscellaneous plant equipment such as communication equipment, instrument and service air, and water supply system
- Plant support equipment which consists of tools, shop supplies and equipment rental, and safety supplies

2.6.2.2 Variable O&M (VOM)

VOM expenses are production-related costs (excluding fuel-related costs) which vary with electrical generation and include the following categories, as applicable to the given power plant technology:

- Raw water
- Waste and wastewater disposal expenses
- Purchase power (which is incurred inversely to operating hours), demand charges and related utilities
- Chemicals, catalysts and gases

- Ammonia (“NH₃”) for selective catalytic reduction (“SCR”), as applicable
- Lubricants
- Consumable materials and supplies

2.6.2.3 Major Maintenance

Major maintenance expenses generally require an extended outage, are typically undertaken no more than once per year; and are assumed to vary with electrical generation or the number of plant starts based on the given technology and specific original equipment manufacturer recommendations and requirements. These major maintenance expenses include the following expense categories:

- Scheduled major overhaul expenses for maintaining the prime mover equipment at a power plant
- Major maintenance labor
- Major maintenance spare parts costs
- BOP major maintenance, which is major maintenance on the equipment at the given plant that cannot be accomplished as part of routine maintenance or while the unit is in commercial operation.
- Major maintenance expenses are included in the O&M Expenses for each plant. These expenses may be in either the fixed or variable O&M rate depending on the cost structure of the particular plant considering such things as capacity factor, hour and start cycling patterns, O&M contract structure (if applicable), and major maintenance timing triggers.

TABLE 2-5 – TECHNOLOGY PERFORMANCE SPECIFICATIONS

| Technology | Fuel | Net Nominal Capacity (kW) ⁽¹⁾ | Net Nominal Heat Rate (Btu/kWh) ⁽²⁾ | Capital Cost (\$/kW) ⁽³⁾ | Fixed O&M (\$/kW-yr) ⁽⁴⁾ | Variable O&M (\$/MWh) ⁽⁵⁾ | SO ₂ (lb/MMBtu) ⁽⁶⁾ | NO _x (lb/MMBtu) | CO ₂ (lb/MMBtu) |
|---|--------------|--|--|-------------------------------------|-------------------------------------|--------------------------------------|---|----------------------------|----------------------------|
| Ultra Supercritical Coal (USC) | Coal | 650,000 | 8,800 | 3,636 | 42.10 | 4.60 | 0.1 ⁽⁷⁾ | 0.06 | 206 ⁽⁷⁾ |
| Ultra Supercritical Coal with CCS (USC/CCS) | Coal | 650,000 | 9,750 | 5,084 | 70.0 | 7.10 | 0.02 ⁽⁸⁾ | 0.06 | 144 ⁽⁹⁾ |
| Pulverized Coal Conversion to Natural Gas (CTNG) | Gas | 300,000 | 10,300 | 226 | 22.0 | 1.30 | .001 | 0.11 | 117 |
| Pulverizer Coal Greenfield with 10-15 percent biomass (GCBC) | Coal/Biomass | 300,000 | 8,960 | 4,620 | 50.90 | 5.00 | 0.1 | 0.06 | 204 |
| Pulverized Coal Conversion to 10 percent biomass – 30 MW (CTCB) | Coal/Biomass | 300,000 | 10,360 | 537 | 50.90 | 5.00 | 0.1 | 0.06 | 204 |
| NGCC | Gas | 702,000 | 6,600 | 978 | 11.00 | 3.50 | 0.001 | 0.0075 ⁽¹⁰⁾ | 117 |
| AG-NGCC | Gas | 429,000 | 6,300 | 1,104 | 10.00 | 2.00 | 0.001 | 0.0075 ⁽¹⁰⁾ | 117 |
| CT | Gas | 100,000 | 10,000 | 1,101 | 17.50 | 3.50 | 0.001 | 0.03 ⁽¹¹⁾ | 117 |
| ACT | Gas | 237,000 | 9,800 | 678 | 6.80 | 10.70 | 0.001 | 0.03 ⁽¹¹⁾ | 117 |
| Advanced Nuclear (AN) | Uranium | 2,234,000 | N/A | 5,945 | 100.28 | 2.30 | 0 | 0 | 0 |
| Biomass (BBFB) | Biomass | 50,000 | 13,500 | 4,985 | 110.00 | 4.20 | 0 | 0.08 | 195 ⁽¹²⁾ |
| Onshore Wind (WN) | Wind | 100,000 | N/A | 1,877 | 39.70 | 0 | 0 | 0 | 0 |
| Photovoltaic - Fixed | Solar | 20,000 | N/A | 2,671 | 23.40 | 0 | 0 | 0 | 0 |
| Photovoltaic – Tracking | Solar | 20,000 | | 2,644 | 23.90 | 0 | 0 | 0 | 0 |
| Photovoltaic – Tracking | Solar | 150,000 | N/A | 2,534 | 21.80 | 0 | 0 | 0 | 0 |
| Reciprocating Internal Combustion Engine (RICE) | Gas | 85,000 | 8,500 | 1,342 | 6.90 | 5.85 | 0.001 | 0.07 | 117 |
| Battery Storage (BES) | | 4,000 | N/A | 2,813 | 40.00 | 8.00 | N/A | N/A | N/A |

Footnotes are listed on the next page.

- (1) Capacity is net output basis and includes auxiliary loads.
- (2) Heat Rate is on a HHV basis for British thermal units per kilowatt-hour (“Btu/kWh”) at ISO conditions.
- (3) Capital Cost excludes financing-related costs (e.g., fees, interest during construction).
- (4) FOM expenses exclude owner's costs (e.g., insurance, property taxes, and asset management fees).
- (5) VOM expenses include major maintenance but not fuel-related expenses.
- (6) Million Btu (“MMBtu”).
- (7) Based on high sulfur bituminous fuel.
- (8) Assuming 3 percent sulfur coal at 12,000 British thermal units per pound (“Btu/lb”) and a 99.5 percent sulfur removal rate.
- (9) Assuming 30 percent capture.
- (10) Assuming 2 ppmvd corrected to 15 percent O₂ for F-Class engine.
- (11) Assuming 9 parts per million volume dry (“ppmvd”) corrected to 15 percent O₂; simple-cycle E-Class or F-Class engine.
- (12) Does not account for the life-cycle fate of CO₂ after emission from power generation unit.

3. Ultra Supercritical Coal (USC)


3.1 Mechanical Equipment and Systems

The following describes the Ultra Supercritical Coal (“USC”) Facility, which is a nominal 650 MW net output coal-fired supercritical steam-electric generating unit built in a Greenfield location. This unit employs a supercritical Rankine power cycle in which coal is burned to produce steam in a boiler, which is expanded through a ST to produce electric power. The steam is then condensed to water and pumped back to the boiler to be converted to steam once again to complete the cycle.

The unit will operate at steam conditions of approximately 3,800 pounds per square inch-absolute (“psia”) and 1,112 degrees Fahrenheit (“F”) at the ST inlet. The superheated steam produced in the boiler is supplied to the ST, which drives an electric generator. After leaving the high-pressure (“HP”) ST, the steam is reheated and fed to the intermediate-pressure (“IP”) ST. In the low-pressure (“LP”) ST, the steam admitted directly from the IP ST expands to condenser pressure and is condensed in the condenser. Cooling tower water is used for the condensing process. Condensate collected in the condenser hotwell is discharged by the main condensate pumps and returned to the deaerator/feedwater storage tank via the LP feedwater heaters. The feedwater pumps discharge feedwater from the feedwater storage tank to the boiler via the HP feedwater heaters. In the boiler, the supercritical fluid is heated for return to the ST.

The combustion air and flue gas systems are designed for balanced draft and start with the ambient air drawn in by the forced draft fans. This air is heated by steam preheaters and the regenerative air heaters. Some of the air is passed through the primary air fans for use in drying and conveying the pulverized coal to the boiler. The air and coal combust in the boiler furnace and the flue gas passes through the furnace and back passes of the boiler, giving up heat to the supercritical fluid in the boiler tubes. The flue gas exiting the boiler economizer enters the SCR equipment for NO_x reduction (low NO_x burners are assumed for the boiler) and into the regenerative air heaters where it transfers heat to the incoming air. From the regenerative air heaters, the flue gas is treated with an injection of hydrated lime, enters a pulse-jet fabric filter (baghouse) for the collection of particulate material, and then flows to the induced draft fans. From the fans, gas enters the Wet Flue Gas Desulfurization (“WFGD”) absorber. From the absorber, the flue gas discharges into the stack. Figure 3-1 presents the USC process flow diagram.

FIGURE 3-1 – ULTRA SUPERCRITICAL COAL DESIGN CONFIGURATION



3.2 Electrical and Control Systems

The USC Facility has one ST electric generator. The generator is a 60 Hertz (“Hz”) machine rated at approximately 720 mega-volt-amperes (“MVA”) with an output voltage of 24 kilovolts (“kV”). The ST electric generator is directly connected to generator step-up transformer (“GSU”), which in turn is connected between two circuit breakers in the high-voltage bus in the USC Facility switchyard through a disconnect switch. The GSU increases the voltage from the electric generator from 24 kV to interconnected transmission system high voltage.

The USC Facility is controlled using a DCS. The DCS provides centralized control of the plant by integrating the control systems provided with the boiler, ST and associated electric generator and the control of BOP systems and equipment.

3.3 Off-Site Requirements

Coal is delivered to the facility via rail, truck or barge. Water for all processes at the USC Facility can be obtained from one of a variety of sources; however, water is typically sourced from an adjacent river, when possible. The USC Facility uses a water treatment system and a high-efficiency reverse osmosis system to reduce the dissolved solids from the cooling water and to provide distilled water for boiler makeup. Wastewater is sent to an adjacent river or other approved alternative. Further, the electrical interconnection from the USC on-site switchyard is effectuated

by a connection to an adjacent utility substation, assumed to be no more than 1 mile from the USC Facility.

3.4 Capital Cost Estimate

The base Cost Estimate for the USC Facility with a nominal capacity of 650 MW is \$3,636/kilowatt (“kW”). Table 3-1 summarizes the Cost Estimate categories for the USC Facility.

TABLE 3-1 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR USC

| Technology: USC | | |
|--|-----------------------------------|-----------|
| Nominal Capacity (ISO): 650,000 kW | | |
| Nominal Heat Rate (ISO): 8,800 Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> | |
| Civil Structural Material and Installation | | 247,250 |
| Mechanical Equipment Supply and Installation | | 991,831 |
| Electrical / I&C Supply and Installation | | 141,900 |
| Project Indirects ⁽¹⁾ | | 393,350 |
| EPC Cost before Contingency and Fee | | 1,774,331 |
| Fee and Contingency | | 195,176 |
| Total Project EPC | | 1,969,507 |
| Owner's Costs (excluding project finance) | | 393,901 |
| Total Project Cost (excluding finance) | | 2,363,408 |
| Total Project EPC | \$ / kW | 3,030 |
| Owner Costs 20% (excluding project finance) | \$ / kW | 606 |
| Total Project Cost (excluding project finance) | \$ / kW | 3,636 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: outdoor installation considerations, seismic design differences, remote location issues, labor wage and productivity differences, location adjustments, owner cost differences, and the increase in overheads associated with these six adjustment criteria.

Outdoor installation locations are considered in geographic areas where enclosed structures for the boilers would not be required due to the low probability of freezing. The locations that were included in outdoor installation are Alabama, Arizona, Arkansas, Florida, Georgia, Louisiana, Mississippi, New Mexico, and South Carolina.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the USC Facility include Fairbanks, Alaska; Great Falls, Montana; Albuquerque, New Mexico; and Cheyenne, Wyoming.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the USC Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Illinois, Indiana, Maine, Maryland, Massachusetts, Minnesota, New York, Ohio, Oregon, Pennsylvania, Virginia, Washington, Wisconsin, and Wyoming.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 3-2 in the Appendix shows the USC capital cost variations for alternative U.S. plant locations, including the difference between the given location and the average location specified for the Cost Estimate.

3.5 O&M Estimate

In addition to the general O&M items discussed in Section 2.6.2, the USC Facility includes the major maintenance for boiler, ST, associated generator, BOP, and emissions reduction catalysts. These major maintenance expenses are included with the VOM expense for this technology and are given on an average basis across the megawatt-hours (“MWh”) incurred. Typically, significant overhauls on an USC Facility occur no less frequently than six or seven years. Table 3-3 presents the FOM and VOM expenses for the USC Facility. Table 3-3 presents the O&M expenses for the USC Facility.

TABLE 3-3 – O&M EXPENSES FOR USC (650,000 KW)

| Technology: | USC |
|---------------------------------|------------------------|
| Fixed O&M Expense | \$42.10/kW-year |
| Variable O&M Expense | \$4.60/MWh |

3.6 Environmental Compliance Information

As mentioned in Section 3.1, the USC Facility is assumed to include low NO_x combustion burners in the boiler, SCR, and a flue gas desulfurization (“FGD”) to further control the emissions of NO_x and SO₂, respectively. Table 3-4 presents the environmental emissions for the USC Facility.

TABLE 3-4 – ENVIRONMENTAL EMISSIONS FOR USC

| Technology: | USC |
|-----------------------|------------------------------------|
| NO_x | 0.06 lb/ MMBtu |
| SO₂ | 0.1 lb/MMBtu |
| CO₂ | 206 lb/MMBtu ⁽¹⁾ |

(1) Variable O&M costs shown in this report do not account for state or regional carbon trading programs

4. Ultra Supercritical Coal with CCS (USC/CCS)

4.1 Mechanical Equipment and Systems

The plant configuration for the USC with CCS Facility (“USC/CCS”) is the same as the USC case with two exceptions: (1) an amine scrubbing system, utilizing monoethanolamine (“MEA”) as a solvent, to capture CO₂ from the flue gas, and (2) the scaling of the boiler to a larger size, as described below. The assumed carbon capture was set at 30 percent. The captured CO₂ is compressed to approximately 2,000 psia for injection into a pipeline at the plant fence line as a supercritical fluid. The net output of the USC/CCS Facility case is 650 MW, and since the CCS system requires about 10 percent of the given facility’s gross capacity in auxiliary load, the USC/CCS Facility assumes that the boiler is increased by approximately 12 percent (i.e., it is approximately 110 percent the size of the boiler in the USC Facility), which provides the necessary steam to facilitate the capture process and to run a steam-driven compressor for compressing the CO₂ for sequestration. Leidos used 800 MW gross output to obtain the 650 MW net output. Figure 4-1 presents a diagram of the USC and Figure 4-2 presents a diagram of the USC/CCS Facility.

FIGURE 4-1 – USC FACILITY DIAGRAM





FIGURE 4-2 – USC/CCS FACILITY DIAGRAM



4.2 Electrical and Control Systems

The electrical and control systems for the USC/CCS Facility are materially similar to the USC Facility.

4.3 Off-Site Requirements

The off-site requirements for the USC/CCS Facility are materially similar to the USC Facility, except that the CO₂ needs sequestering in one of the following geologic formations: (1) exhausted gas storage location, (2) unminable coal seam, (3) enhanced oil recovery, or (4) saline aquifer. To the extent that a sequestration site is not near the given facility being analyzed, transportation for a viable sequestration site has the potential to materially affect the capital cost estimates discussed below.

4.4 Capital Cost Estimate

The base Cost Estimate for the USC/CCS Facility with a nominal capacity of 650 MW is \$5,084/kW. The capital cost estimate was based on the USC Facility (without CCS) and the base Cost Estimate was increased to include the expected costs of CCS at 30 percent. Since there are limited full-scale pulverized coal facilities operating with CCS in the world, our estimate is based on industry research. Our team tested the veracity of this research against assumptions for implementing the additional equipment necessary to effectuate CCS on an advanced coal facility. Table 4-1 summarizes the Cost Estimate categories for the USC/CCS Facility.

TABLE 4-1 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR USC/CCS

| Technology: USC/CCS | | |
|--|-----------------------------------|--------------|
| Nominal Capacity (ISO): 650,000 kW | | |
| Nominal Heat Rate (ISO): 9,750 Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> | |
| Civil Structural Material and Installation | 299,790 | |
| Mechanical Equipment Supply and Installation | 1,414,117 | |
| Electrical / I&C Supply and Installation | 215,293 | |
| Project Indirects ⁽¹⁾ | 549,580 | |
| EPC Cost before Contingency and Fee | 2,478,780 | |
| Fee and Contingency | 275,176 | |
| Total Project EPC ⁽²⁾ | 2,753,956 | |
| Owner Costs (excluding project finance) ⁽²⁾ | 550,791 | |
| Total Project Cost (excluding finance) | 3,304,747 | |
| Total Project EPC | / kW | 4,237 |
| Owner Costs 20% (excluding project finance) | / kW | 847 |
| Total Project Cost (excluding project finance) | / kW | 5,084 |
| ⁽¹⁾ Includes engineering, distributable costs, scaffolding, construction management, and start-up. ⁽²⁾ EPC costs include Sequestration to Plant Fence, Owners cost may not bear all pipeline costs required past the demarcation point. | | |

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: outdoor installation considerations, seismic design differences, remote location issues, labor wage and productivity differences, location adjustments, owner cost differences, and the increase in overheads associated with these six adjustment criteria. The methodology used for the USC/CCS Facility is the same as that discussed in Section 3.4 for the USC Facility (without CCS).

Table 4-2 in the Appendix shows the USC capital cost variations for alternative U.S. plant locations, including the difference between the given location and the average location specified for the Cost Estimate.

4.5 O&M Estimate

The O&M items for the USC/CCS Facility are the same as those discussed in Section 3.5 for the USC Facility (without CCS), except that adders are included to both FOM and VOM to accommodate the expenses associated with compressor maintenance, sequestration maintenance, and the associated additional labor required to manage, operate, and maintain the additional equipment. Table 4-3 presents the FOM and VOM expenses for the USC/CCS Facility.

TABLE 4-3 – O&M EXPENSES FOR USC/CCS (650,000 KW)

| Technology: | USC/CCS |
|---------------------------------|------------------------|
| Fixed O&M Expense | \$70.00/kW-year |
| Variable O&M Expense | \$7.10/MWh |

4.6 Environmental Compliance Information

In addition to the equipment utilized for environmental compliance in the USC Facility, the USC/CCS Facility includes an amine scrubber that is intended to remove 30 percent of the CO₂ produced in the combustion process, wherein the captured CO₂ is later compressed to HP and sequestered, as discussed above. Increased amount of SO₂ scrubbing is required to avoid contamination of the MEA. Such costs for increased scrubbing are included. Table 4-4 presents the environmental emissions for the USC/CCS Facility.

TABLE 4-4 – ENVIRONMENTAL EMISSIONS FOR USC/CCS

| Technology: | USC/CCS |
|-----------------------|----------------------|
| NO_x | 0.06 lb/MMBtu |
| SO₂ | 0.02 lb/MMBtu |
| CO₂ | 144 lb/MMBtu |

5. Pulverized Coal Brownfield Conversion to Natural Gas (CTNG)

5.1 Mechanical Equipment and Systems


The Conversion from Coal to Natural Gas Facility (“CTNG”) is based on an existing 300 MWe Coal plant and converting to a Natural Gas fired plant. The total design capacity is 300 MWe.

The following describes the Pulverized Coal Brownfield Conversion to Natural Gas (“CTNG”) Facility, which is a nominal 300 MW net output coal-fired subcritical steam-electric generating unit built in a Brownfield location. This unit employs a subcritical Rankine power cycle in which natural gas burning capability is added, replacing coal, to produce steam in a boiler which is expanded through a ST to produce electric power. The steam is then condensed to water and pumped back to the boiler to be converted to steam once again to complete the cycle.

The unit will operate at steam conditions of approximately 2,600 pounds per square inch-absolute (“psia”) and 1,005 degrees Fahrenheit (“°F”) at the ST inlet. The superheated steam produced in the boiler is supplied to the ST, which drives an electric generator. After leaving the high-pressure (“HP”) ST, the steam is reheated and fed to the intermediate-pressure (“IP”) ST. In the low-pressure (“LP”) ST, the steam admitted directly from the IP ST expands to condenser pressure and is condensed in the condenser. Cooling tower water is used for the condensing process. Condensate collected in the condenser hotwell is discharged by the main condensate pumps and returned to the deaerator/feedwater storage tank via the LP feedwater heaters. The feedwater pumps discharge feedwater from the feedwater storage tank to the boiler via the HP feedwater heaters. In the boiler, the subcritical fluid is heated for return to the ST.

The combustion air and flue gas systems are designed for balanced draft and starts with the ambient air drawn in by the forced draft fans. This air is heated by steam preheaters and the regenerative air heaters. The air and natural gas combust in the boiler furnace and the flue gas passes through the furnace and back passes of the boiler, giving up heat to the subcritical fluid in the boiler tubes. The flue gas exiting the boiler economizer enters the regenerative air heaters where it transfers heat to the incoming air. From the regenerative air heaters, the flue gas then flows to the induced draft fans and then into the stack. Figure 3-1 presents the USC process flow diagram.

FIGURE 5-1 – CTNG DESIGN CONFIGURATION



5.2 Electrical and Control Systems

The electrical and control systems for the CTNG Facility are materially similar to the USC Facility with a smaller output capacity.

5.3 Off-Site Requirements

The off-site requirements for the CTNG Facility are materially similar to the CCNG Facility, except that the Facility will use lower pressure natural gas than that required for the combustion turbines.

5.4 Capital Cost Estimate

The base Cost Estimate for the CTNG with a nominal capacity of 300 MW is \$226/kW. Table 5-1 summarizes the Cost Estimate categories for the CTNG Facility.

TABLE 5-1 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR CTNG

| Technology: CTNG | | |
|---|-----------------------------------|---------------|
| Nominal Capacity (ISO): 300,000 kW | | |
| Nominal Heat Rate (ISO): 10,300 Btu/kWh-HHV ⁽³⁾ | | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> | |
| Civil Structural Material and Installation | | 7,820 |
| Mechanical Equipment Supply and Installation | | 26,300 |
| Electrical / I&C Supply and Installation | | 6,370 |
| Project Indirects ⁽¹⁾ | | 12,310 |
| EPC Cost before Contingency and Fee ⁽²⁾ | | 52,800 |
| Fee and Contingency | | 6,154 |
| Total Project EPC | | 58,954 |
| Owner Costs (excluding project finance) | | 8,843 |
| Total Project Cost (excluding finance) | | 67,797 |
| Total Project EPC | / kW | 197 |
| Owner Costs 15% (excluding project finance) | / kW | 29 |
| Total Project Cost (excluding project finance) | / kW | 226 |
| <small>(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up. (2) Assumes demolition and mitigation will not be required (3) Assumes Subcritical for conversion</small> | | |

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: seismic design differences, remote location issues, labor wage and productivity differences, location adjustments, and owner cost differences and the increase in overheads associated with these five adjustments.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher

equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the Facility include Fairbanks, Alaska; Great Falls, Montana; Albuquerque, New Mexico; Cheyenne, Wyoming; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the CTNG Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Illinois, Indiana, Iowa, Kansas, Maine, Maryland, Massachusetts, Michigan, Minnesota, Montana, Nebraska, New York, North Dakota, Ohio, Pennsylvania, South Dakota, West Virginia, Wisconsin, and Wyoming.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 5-2 in the Appendix shows the CTNG capital cost variations for alternative U.S. plant locations, including the difference between the given location and the average location specified for the Cost Estimate.

5.5 O&M Estimate

The O&M for a natural gas fired facility is much lower than a pulverized coal facility since coal conveying and pulverizing equipment is not used. Additionally, the emissions controls equipment that is required for pulverized coal firing is not needed for natural gas firing.

TABLE 5-3 – O&M EXPENSES FOR CTNG

| Technology: | CTNG |
|---------------------------------|------------------------|
| Fixed O&M Expense | \$22.00/kW-year |
| Variable O&M Expense | \$1.30/MWh |

5.6 Environmental Compliance Information

Table 5-4 presents environmental emissions for the CTNG Facility. Since the conversion of coal to gas fuel would inherently reduce emissions, the installation of an SCR with gas fuel was not assumed. Low NO_x burners on the gas-fired boiler are assumed.

TABLE 5-4 – ENVIRONMENTAL EMISSIONS FOR CTNG

| Technology: | CTNG |
|-----------------------|-----------------------|
| NO_x | 0.11 lb/MMBtu |
| SO₂ | 0.001 lb/MMBtu |
| CO₂ | 117 lb/MMBtu |


6. Pulverized Coal Greenfield with 10-15% Biomass (GCBC)

6.1 Mechanical Equipment and Systems

The Coal Co-Firing with 10-15% Biomass Facility (“GCBC”) is based on a total design capacity of 300 MWe.

The plant configuration for the Pulverized coal greenfield with 10-15% biomass (“GCBC”) is the same as the USC case with two exceptions: (1) the size of the plant is 300 MW net capacity, and (2) the modifications to feed and burn biomass are made to the facility. These modifications would include conveyors, feeders, storage capability, and sootblowers. This biomass fuel for this facility is assumed to be a dry, pelletized fuel which can be mixed directly into the coal pulverizers.

FIGURE 6-1 – GCBC DESIGN CONFIGURATION



6.2 Electrical and Control Systems

The electrical and control systems for the GCBC Facility are materially similar to the USC Facility with a smaller output capacity.

6.3 Off-Site Requirements

The off-site requirements for the GCBC Facility are materially similar to the USC Facility, except that pelletized biomass will need to be prepared and delivered to the site for storage.

6.4 Capital Cost Estimate

The base Cost Estimate for the GCBC Facility with a nominal capacity of 300 MWe is \$4,620/kW. Table 6-1 summarizes the Cost Estimate categories for the GCBC Facility.

TABLE 6-1 – LOCATION-BASED COSTS FOR GCBC

| Technology: GCBC | |
|---|--|
| Nominal Capacity (ISO): 300,000 kW | |
| Nominal Heat Rate (ISO): 8,960 Btu/kWh-HHV | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> |
| Civil Structural Material and Installation | 115,992 |
| Mechanical Equipment Supply and Installation | 583,500 |
| Electrical / I&C Supply and Installation | 106,179 |
| Project Indirects ⁽¹⁾ | 228,694 |
| EPC Cost before Contingency and Fee | 1,034,365 |
| Fee and Contingency | 120,559 |
| Total Project EPC | 1,154,924 |
| Owner Costs (excluding project finance) | 230,985 |
| Total Project Cost (excluding finance) | 1,385,909 |
| Total Project EPC | 3,850 |
| / kW | |
| Owner Costs 20% (excluding project finance) | 770 |
| / kW | |
| Total Project Cost (excluding project finance) | 4,620 |
| / kW | |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: seismic design differences, remote location issues, labor wage and

productivity differences, location adjustments, and owner cost differences and the increase in overheads associated with these five adjustments.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the Coal Biomass Co-Firing Facility include, Fairbanks, Alaska; Great Falls, Montana; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the GCBC Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Illinois, Maine, Maryland, Massachusetts, Minnesota, New Jersey, New York, Ohio, Oregon, Rhode Island, Virginia, Washington, and Wisconsin.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 6-2 in the Appendix presents the GCBC Facility capital cost variations for alternative U.S. plant locations.

6.5 O&M Estimate

The O&M expenses for the GCBC facility are materially similar to the pulverized coal fired facility.

TABLE 6-3 – O&M EXPENSES FOR GCBC

| Technology: | GCBC |
|---------------------------------|------------------------|
| Fixed O&M Expense | \$50.90/kW-year |
| Variable O&M Expense | \$5.00/MWh |

6.6 Environmental Compliance Information

Since wind utilizes a renewable fuel and no additional fuel is combusted to make power from an Greenfield Coal Biomass Co-Firing Facility, air emissions are not created. Table 6-4 presents environmental emissions for the GCBC Facility.

TABLE 6-4 – ENVIRONMENTAL EMISSIONS FOR GCBC

| Technology: | GCBC |
|-----------------------|----------------------|
| NO_x | 0.06 lb/MMBtu |
| SO₂ | 0.1 lb/MMBtu |
| CO₂ | 204 lb/MMBtu |


7. Pulverized Coal Brownfield Conversion to Coal with 10% Biomass – 30 MW Co-Firing (CTCB)

7.1 Mechanical Equipment and Systems

The Coal Brownfield Conversion to 10% Biomass Co-Firing Facility (“CTCB”) is the addition of 30 MWe to an existing 300 MWe Coal plant; the overall net MWe output will remain 300 MWe.

The plant configuration for the Pulverized coal brownfield with 10% biomass (“GCBC”) is the same as the pulverized coal brownfield conversion to natural gas (“CTNG”) case with the exception that pulverized coal firing will not be discontinued. The size of the plant is 300 MW net capacity and the modifications to feed and burn biomass are made to the facility. These modifications would include conveyors, feeders, storage capability, and sootblowers. This biomass fuel for this facility is assumed to be a dry, pelletized fuel which can be mixed directly into the coal pulverizers.

FIGURE 7-1 – CTCB DESIGN CONFIGURATION



7.2 Electrical and Control Systems

The electrical and control systems for the CTNG Facility are materially similar to the USC Facility with a smaller output capacity.

7.3 Off-Site Requirements

The off-site requirements for the CTCB Facility are materially similar to the USC Facility, except that pelletized biomass will need to be prepared and delivered to the site for storage.

7.4 Capital Cost Estimate

The base Cost Estimate for the CTCB Facility with a nominal capacity of 300 MW is \$537/kW. Table 7-1 summarizes the Cost Estimate categories for the CTCB Facility.

TABLE 7-1 – LOCATION-BASED COSTS FOR CTCB

| Technology: CTCB | | |
|---|-------------|-----------------------------------|
| Nominal Capacity (ISO): 300,000 kW | | |
| Nominal Heat Rate (ISO): 10,360 Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | | <u>(000s) (January 1, 2016\$)</u> |
| Civil Structural Material and Installation | | 11,688 |
| Mechanical Equipment Supply and Installation | | 78,338 |
| Electrical / I&C Supply and Installation | | 4,801 |
| Project Indirects ⁽¹⁾ | | 21,846 |
| EPC Cost before Contingency and Fee | | 116,674 |
| Fee and Contingency | | 17,501 |
| Total Project EPC | | 134,175 |
| Owner Costs (excluding project finance) | | 26,835 |
| Total Project Cost (excluding finance) | | 161,010 |
| Total Project EPC | / kW | 447 |
| Owner Costs 20% (excluding project finance) | / kW | 89 |
| Total Project Cost (excluding project finance) | / kW | 537 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: seismic design differences, remote location issues, labor wage and

productivity differences, location adjustments, and owner cost differences and the increase in overheads associated with these five adjustments.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3, and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the CTCB Facility include Fairbanks, Alaska; Great Falls, Montana; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the CTCB Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Illinois, Maine, Maryland, Massachusetts, Minnesota, Oregon, Virginia, and Washington.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 7-2 in the Appendix presents the CTCB Facility capital cost variations for alternative U.S. plant locations.

7.5 O&M Estimate

The O&M expenses for a CTCB facility are materially similar to a pulverized coal facility.

TABLE 7-3 – O&M EXPENSES FOR CTCB

| Technology: | CTCB |
|---------------------------------|------------------------|
| Fixed O&M Expense | \$50.90/kW-year |
| Variable O&M Expense | \$5.00/MWh |

7.6 Environmental Compliance Information

Table 7-4 presents environmental emissions for the CTCB Facility.

TABLE 7-4 – ENVIRONMENTAL EMISSIONS FOR CTCB


| Technology: | CTCB |
|-----------------------|----------------------|
| NO_x | 0.06 lb/MMBtu |
| SO₂ | 0.1 lb/MMBtu |
| CO₂ | 204 lb/MMBtu |

8. Conventional Natural Gas Combined Cycle (NGCC)

8.1 Mechanical Equipment and Systems

The Conventional Natural Gas Combined Cycle (“NGCC”) produces 702 MW of net electricity. The facility utilizes two natural gas-fueled F5-class CTs and associated electric generators, two supplemental-fired heat recovery steam generators (“HRSG”), and one condensing ST and associated electric generator operating in combined-cycle mode. Each CT is designed to produce nominally 242 MW and includes a dry-low NO_x (“DLN”) combustion system and a hydrogen-cooled electric generator. The two triple-pressure HRSGs include integrated deaerators, SCRs, oxidation catalyst for the control of carbon monoxide (“CO”), and supplemental duct firing with associated combustion management. The ST is a single-reheat condensing ST designed for variable pressure operation, designed to produce an additional 246 MW. The ST exhaust is cooled in a closed-loop condenser system with a mechanical draft cooling tower. The CTs are equipped with inlet evaporative coolers to reduce the temperature of the turbine inlet air to increase summer output. The Conventional NGCC plant also includes a raw water treatment system consisting of clarifiers and filters and a turbine hall, in which the CTs, ST, and HRSGs are enclosed to avoid freezing during periods of cold ambient temperatures. Figure 8-1 presents the Conventional NGCC process flow diagram.

FIGURE 8-1 – CONVENTIONAL NGCC DESIGN CONFIGURATION



8.2 Electrical and Control Systems

The Conventional NGCC has two CT electric generators and one ST electric generator. The generators for the CTs are 60 Hz and rated at approximately 215 MVA with an output voltage of 18 kV. The ST electric generator is 60 Hz and rated at approximately 310 MVA with an output voltage of 18 kV. Each CT and ST electric generator is connected to a high-voltage bus in the Conventional NGCC via a dedicated generator circuit breaker, generator GSU, and a disconnect switch. The GSUs increase the voltage from the electric generators from 18 kV to interconnected high voltage.

The Conventional NGCC is controlled using a DCS. The DCS provides centralized control of the facility by integrating the control systems provided with each individual CT and associated electric generator, ST and associated electric generator, and the control of BOP systems and equipment.

8.3 Off-Site Requirements

Natural gas is delivered to the facility through a lateral connected to the local natural gas trunk line. Water for all processes at the Conventional NGCC Facility is obtained from one of several available water sources (e.g., municipal water supply). The Conventional NGCC Facility uses a water treatment system and a high-efficiency reverse osmosis system to reduce the dissolved solids from the cooling water and to provide distilled water for HRSG makeup. Wastewater is sent to a

municipal wastewater system. Further, the electrical interconnection from the Conventional NGCC on-site switchyard is effectuated by a connection to an adjacent utility substation.

8.4 Capital Cost Estimate

The base Cost Estimate for the Conventional NGCC Facility with a nominal capacity of 702 MW is \$978/kW. Table 8-1 summarizes the Cost Estimate categories for the Conventional NGCC Facility.

TABLE 8-1 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR CONVENTIONAL NGCC

| Technology: Conventional NGCC | | |
|---|-----------------------------------|------------|
| Nominal Capacity (ISO): 702,000 kW | | |
| Nominal Heat Rate (ISO): 6,600 Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> | |
| Civil Structural Material and Installation | 49,126 | |
| Mechanical Equipment Supply and Installation | 324,043 | |
| Electrical / I&C Supply and Installation | 43,753 | |
| Project Indirects ⁽¹⁾ | 99,220 | |
| EPC Cost before Contingency and Fee | 516,142 | |
| Fee and Contingency | 55,743 | |
| Total Project EPC | 571,885 | |
| Owner Costs (excluding project finance) | 114,377 | |
| Total Project Cost (excluding finance) | 686,262 | |
| Total Project EPC | / kW | 815 |
| Owner Costs 20% (excluding project finance) | / kW | 163 |
| Total Project Cost (excluding project finance) | / kW | 978 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: outdoor installation considerations, air-cooled condensers compared to cooling towers, seismic design differences, zero-water discharge issues, local technical enhancements (e.g., additional noise remediation that is generally required in urban siting), remote location issues, urban – high density population issues, labor wage and productivity differences,

location adjustments, owner cost differences, and the increase in overheads associated with these 10 adjustments.

Outdoor installation locations are considered in geographic areas where enclosed structures for the boilers would not be required due to the low probability of freezing. The locations that were included in outdoor installation are Alabama, Arizona, Arkansas, Florida, Georgia, Louisiana, Mississippi, New Mexico, South Carolina, and Puerto Rico.

The potential locations relating to the use of air-cooled condensers in place of mechanical draft wet cooling towers were identified as Arizona, California, Connecticut, Delaware, District of Columbia, Maryland, Massachusetts, New Hampshire, New York, Oregon, Pennsylvania, Rhode Island, Virginia, and Puerto Rico. These locations are identified as those where conservation of water, notwithstanding supply, has been and/or is becoming a significant issue in plant permitting/siting.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

The potential locations relating to the need of zero-water discharge were identified as Arizona, California, Colorado, Connecticut, Delaware, District of Columbia, Maryland, Massachusetts, New Hampshire, New York, Oregon, Pennsylvania, Rhode Island, Virginia, and Puerto Rico. Similar to water usage discussed above in this section on Conventional NGCC, wastewater treatment and disposal is considered a critical permitting/siting issue in these areas.

The locations with local technical enhancements include California, Colorado, Connecticut, Delaware, District of Columbia, Maryland, Massachusetts, Montana, New Jersey, New York, Rhode Island, Vermont, and Virginia. These areas are places where noise, visual impacts, and other technical enhancements generally need to be made by a project developer or utility to comply with the applicable permitting/siting requirements.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the Conventional NGCC include Fairbanks, Alaska; Albuquerque, New Mexico; Cheyenne, Wyoming; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the Conventional NGCC Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Illinois, Indiana, Iowa, Kansas, Maine, Maryland, Massachusetts, Michigan, Minnesota, Montana, Nebraska, New York, North Dakota, Ohio, Pennsylvania, South Dakota, West Virginia, Wisconsin, and Wyoming.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 8-2 in the Appendix presents the Conventional NGCC capital cost variations for alternative U.S. plant locations, including the difference between the given location and the average location specified for the Cost Estimate.

8.5 O&M Estimate

In addition to the general O&M items discussed in Section 2.6.2, the Conventional NGCC Facility includes the major maintenance for the CTs, as well as the BOP, including the ST, associated electric generators, HRSGs, and emissions reduction catalysts. These major maintenance expenses are included with the VOM expense for this technology and are given on an average basis across the MWhs incurred. Typically, significant overhauls on a Conventional NGCC Facility occur no less frequently than 16,000 operating hour intervals. Recently, some manufacturers are extending these intervals to 25,000 operating hours. Table 8-3 presents the O&M expenses for the Conventional NGCC Facility.

TABLE 8-3 – O&M EXPENSES FOR CONVENTIONAL NGCC

| Technology: | Conventional NGCC |
|---------------------------------|--------------------------|
| Fixed O&M Expense | \$11.00/kW-year |
| Variable O&M Expense | \$3.50/MWh |

8.6 Environmental Compliance Information

The Conventional NGCC utilizes DLN combustion systems in the primary combustion zone of the CT and best available burner technology with respect to the duct burners in the HRSGs to manage the production of NO_x and CO. Additional control of NO_x and CO is accomplished through an SCR and an oxidization catalyst, respectively. Oxides of sulfur in the Conventional NGCC are managed through the natural gas fuel quality, which is generally very low in sulfur U.S. domestic pipeline quality natural gas, and consequently the low sulfur content translates into SO₂ after combustion. The Conventional NGCC does not include any control devices for CO₂, which is proportional to the heat rate (inversely proportional to the efficiency) of the technology. Water, wastewater, and solid waste compliance are achieved through traditional on-site and off-site methods, and the costs for such compliance are included in the O&M estimate for the Conventional NGCC Facility. Table 8-4 presents environmental emissions for the Conventional NGCC Facility.

TABLE 8-4 – ENVIRONMENTAL EMISSIONS FOR CONVENTIONAL NGCC


| Technology: | Conventional NGCC |
|-----------------------|--------------------------|
| NO_x | 0.0075 lb/MMBtu |
| SO₂ | 0.001 lb/MMBtu |
| CO₂ | 117 lb/MMBtu |

9. Advanced Generation Natural Gas Combined Cycle (AG-NGCC)

9.1 Mechanical Equipment and Systems

The Advanced Generation (“AG”)-NGCC design is the same as the Conventional NGCC, except an H-class CT is utilized in lieu of F-class, and there is only one CT/HRSG supporting the ST included. Since the H-class CT design employs steam cooling of both stationary and rotational hot parts, the HRSG systems and the ST are both considered “advanced” designs, as compared to the Conventional NGCC. The AG-NGCC has advantages compared to the Conventional NGCC. The advantages of the AG-NGCC are for the same size of equipment – more megawatt output due to higher firing temperature. The higher firing temperature is due to more technically advanced metallurgical metals and coatings, and blade cooling systems. The AG-NGCC may or may not have a better ramping rate depending on the geographical location of the facility. The net output of the AG-NGCC is 429 MW. Figure 9-1 presents the AG-NGCC process flow diagram.

FIGURE 9-1 – AG-NGCC DESIGN CONFIGURATION



9.2 Electrical and Control Systems

The AG-NGCC electrical and control systems are similar to the Conventional NGCC Facility, except that the sizing of the generators and transformers are larger to support the larger CT and ST equipment utilized in the AG-NGCC.

9.3 Off-Site Requirements

The off-site requirements for the AG-NGCC Facility are the same as the Conventional NGCC. Refer to Section 8.3 for the description of the Conventional NGCC off-site requirements.

9.4 Capital Cost Estimate

The base Cost Estimate for the AG-NGCC Facility with a nominal capacity of 429 MW is \$1,104/kW. Table 9-1 summarizes the Cost Estimate categories for the AG-NGCC Facility.

TABLE 9-1 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR AG-NGCC

| Technology: AG-NGCC | |
|---|--|
| Nominal Capacity (ISO): 429,000 kW | |
| Nominal Heat Rate (ISO): 6,300 Btu/kWh-HHV | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> |
| Civil Structural Material and Installation | 25,790 |
| Mechanical Equipment Supply and Installation | 214,313 |
| Electrical / I&C Supply and Installation | 30,370 |
| Project Indirects ⁽¹⁾ | 86,695 |
| EPC Cost before Contingency and Fee | 357,168 |
| Fee and Contingency | 37,503 |
| Total Project EPC | 394,671 |
| Owner Costs (excluding project finance) | 78,934 |
| Total Project Cost (excluding finance) | 473,605 |
| Total Project EPC | 920 |
| / kW | |
| Owner Costs 20% (excluding project finance) | 184 |
| / kW | |
| Total Project Cost (excluding project finance) | 1,104 |
| / kW | |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

The locational adjustments for the AG-NGCC Facility similar to those made for the Conventional NGCC Facility.

Table 9-2 in the Appendix presents the AG-NGCC Facility capital cost variations for alternative U.S. plant locations, including the difference between the given location and the average location specified for the Cost Estimate.

9.5 O&M Estimate

The O&M items for the AG-NGCC Facility are the same as those described in Section 8.5 for the Conventional NGCC Facility. Table 9-3 presents the O&M expenses for the AG-NGCC Facility.

TABLE 9-3 – O&M EXPENSES FOR AG-NGCC

| Technology: | AG-NGCC |
|---------------------------------|------------------------|
| Fixed O&M Expense | \$10.00/kW-year |
| Variable O&M Expense | \$2.00/MWh |

9.6 Environmental Compliance Information

The environmental compliance strategy and equipment for the AG-NGCC Facility is the same as those described in Section 8.6 for the Conventional NGCC Facility. Table 9-4 presents environmental emissions for the AG-NGCC Facility.

TABLE 9-4 – ENVIRONMENTAL EMISSIONS FOR AG-NGCC


| Technology: | AG-NGCC |
|-----------------------|------------------------|
| NO_x | 0.0075 lb/MMBtu |
| SO₂ | 0.001 lb/MMBtu |
| CO₂ | 117 lb/MMBtu |

10. Conventional Combustion Turbine (CT)

10.1 Mechanical Equipment and Systems

The Conventional Combustion Turbine (“CT”) Facility produces 100 MW of electricity using two single natural gas-fueled LM-6000 CTs and associated electric generators in simple-cycle mode. The CTs are equipped with an inlet evaporative cooler to reduce the temperature of the turbine inlet air to increase summer output. Figure 10-1 presents the Conventional CT Facility process flow diagram.

FIGURE 10-1 – CONVENTIONAL CT DESIGN CONFIGURATION



10.2 Electrical and Control Systems

The Conventional CT Facility has two CT electric generators. The generators are 60 Hz machines rated at approximately 101 MVA with an output voltage of 13.8 kV. The CT electric generators are connected to a high-voltage bus in the Conventional CT Facility switchyard via a dedicated generator circuit breaker, GSU, and a disconnect switch. The GSU increases the voltage from the electric generator from 13.8 kV to interconnected transmission system high voltage.

The Conventional CT Facility is controlled using a DCS. The DCS provides centralized control of the facility by integrating the control systems provided with the individual CT and associated electric generator and the control of BOP systems and equipment.

10.3 Off-Site Requirements

Natural gas is delivered to the facility through a lateral connected to the local natural gas trunk line within close proximity to the Conventional CT Facility. Water for the limited processes that utilize water at the Conventional CT Facility is obtained from a one of several available water sources (e.g., municipal water supply). The Conventional CT Facility uses a water treatment system and

a high-efficiency reverse osmosis system to reduce the dissolved solids for compressor cleaning. Wastewater is sent to a municipal wastewater system. Further, the electrical interconnection from the Conventional CT on-site switchyard is effectuated by a connection to an adjacent utility substation.

10.4 Capital Cost Estimate

The base Cost Estimate for the Conventional CT Facility with a nominal capacity of 100 MW is \$1,101/kW. Table 10-1 summarizes the Cost Estimate categories for the Conventional CT Facility.

**TABLE 10-1 – BASE PLANT SITE
CAPITAL COST ESTIMATE FOR CONVENTIONAL CT**

| Technology: Conventional CT | |
|---|-----------------------------------|
| Nominal Capacity (ISO): 100,000 kW | |
| Nominal Heat Rate (ISO): 10,000 Btu/kWh-HHV | |
| Capital Cost Category | (000s) (January 1, 2016\$) |
| Civil Structural Material and Installation | 6,630 |
| Mechanical Equipment Supply and Installation | 50,350 |
| Electrical / I&C Supply and Installation | 12,065 |
| Project Indirects ⁽¹⁾ | 14,344 |
| EPC Cost before Contingency and Fee | 83,390 |
| Fee and Contingency | 8,339 |
| Total Project EPC | 91,729 |
| Owner Costs (excluding project finance) | 18,346 |
| Total Project Cost (excluding finance) | 110,075 |
| Total Project EPC | 917 |
| Owner Costs 20% (excluding project finance) | 183 |
| Total Project Cost (excluding project finance) | 1,101 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: outdoor installation considerations, seismic design differences, local technical enhancements (e.g., additional noise remediation that is generally required in urban

siting), remote location issues, urban – high density population issues, labor wage and productivity differences, location adjustments, owner cost differences, and the increase in overheads associated with these previous eight location adjustments.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

The locations with local technical enhancements include California, Colorado, Connecticut, Delaware, District of Columbia, Maryland, Massachusetts, New Jersey, New York, Rhode Island, Vermont, and Virginia. These are areas where noise, visual impacts, and other technical enhancements generally need to be made by a project developer or utility to comply with the applicable permitting/siting requirements.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the Conventional CT Facility include Fairbanks, Alaska; Honolulu, Hawaii; Great Falls, Montana; Albuquerque, New Mexico; Cheyenne, Wyoming; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the Conventional CT Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Hawaii, Illinois, Indiana, Iowa, Kansas, Maine, Maryland, Massachusetts, Michigan, Minnesota, Montana, Nebraska, New York, North Dakota, Ohio, Pennsylvania, South Dakota, West Virginia, Wisconsin, and Wyoming.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 10-2 in the Appendix presents the Conventional CT Facility capital cost variations for alternative U.S. plant locations.

10.5 O&M Estimate

In addition to the general O&M items discussed in Section 2.6.2, the Conventional CT Facility includes the major maintenance for the CT and associated electric generator. These major maintenance expenses are included with the VOM expense for this technology. Significant overhauls on a Conventional CT Facility occur every 25,000 operating hours; with more significant major maintenance outages occurring at 50,000 operating hour intervals. The frequency of starts in relation to operating hours does not have an effect on major maintenance timing for this type of CT, as it does for frame-type units. Table 10-3 presents the O&M expenses for the Conventional CT Facility.

TABLE 10-3 – O&M EXPENSES FOR CONVENTIONAL CT

| Technology: | Conventional CT |
|---------------------------------|------------------------|
| Fixed O&M Expense | \$17.50/kW-year |
| Variable O&M Expense | \$3.50/MWh |

10.6 Environmental Compliance Information

Typically, a Conventional CT Facility would be equipped with only the DLN combustion hardware to mitigate emissions. There are some states in the U.S. that do require a “hot” SCR that can operate at the higher exhaust temperatures of a simple-cycle plant, though that equipment was not contemplated herein. Table 10-4 presents environmental emissions for the CT Facility.

TABLE 10-4 – ENVIRONMENTAL EMISSIONS FOR CONVENTIONAL CT


| Technology: | Conventional CT |
|-----------------------|------------------------|
| NO_x | 0.03 lb/MMBtu |
| SO₂ | 0.001 lb/MMBtu |
| CO₂ | 117 lb/MMBtu |

11. Advanced Combustion Turbine (ACT)

11.1 Mechanical Equipment and Systems

The Advanced CT (“ACT”) Facility produces 237 MW of electricity using a single natural gas-fueled, F-class CT and associated electric generator. The CT is equipped with an inlet evaporative cooler to reduce the temperature of the turbine inlet air to increase summer output. Figure 11-1 presents the Advanced CT process flow diagram.

FIGURE 11-1 – ADVANCED CT DESIGN CONFIGURATION



11.2 Electrical and Control Systems

The Advanced CT Facility has the same general electrical and control systems as the Conventional CT Facility, except that the electric generator is rated at approximately 234 MVA and the corresponding GSU is larger in the Advanced CT Facility.

11.3 Off-Site Requirements

The off-site requirements for the Advanced CT Facility are materially similar to the Conventional CT Facility.

11.4 Capital Cost Estimate

The base Cost Estimate for the Advanced CT Facility with a nominal capacity of 237 MW is \$678/kW. Table 11-1 summarizes the Cost Estimate categories for the Advanced CT Facility.

TABLE 11-1 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR ADVANCED CT

| Technology: Advanced CT | | |
|---|-----------------------------------|------------|
| Nominal Capacity (ISO): 237,000 kW | | |
| Nominal Heat Rate (ISO): 9,800 Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> | |
| Civil Structural Material and Installation | 13,660 | |
| Mechanical Equipment Supply and Installation | 71,245 | |
| Electrical / I&C Supply and Installation | 17,896 | |
| Project Indirects ⁽¹⁾ | 18,851 | |
| EPC Cost before Contingency and Fee | 121,652 | |
| Fee and Contingency | 12,165 | |
| Total Project EPC | 133,818 | |
| Owner Costs (excluding project finance) | 26,764 | |
| Total Project Cost (excluding finance) | 160,582 | |
| Total Project EPC | / kW | 565 |
| Owner Costs 20% (excluding project finance) | / kW | 113 |
| Total Project Cost (excluding project finance) | / kW | 678 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

The locational considerations for the Advanced CT Facility are the same as those set forth in the section on the Conventional CT Facility.

Table 11-2 in the Appendix presents the Advanced CT Facility capital cost variations for alternative U.S. plant locations.

11.5 O&M Estimate

In addition to the general O&M items discussed in Section 2.6.2, the Advanced CT Facility includes the major maintenance for the CT and associated electric generator. These major maintenance expenses are included with the VOM expense for this technology, based upon an operating profile of approximately 8 hours of operation per CT start. Typically, significant overhauls on an Advanced CT Facility occur no less frequently than 450 starts; with more significant major maintenance outages occurring at 900 and 1,800 start intervals. Table 11-3 presents the O&M expenses for the Advanced CT Facility.

TABLE 11-3 – O&M EXPENSES FOR ADVANCED CT

| Technology: | Advanced CT |
|---------------------------------|-----------------------|
| Fixed O&M Expense | \$6.80/kW-year |
| Variable O&M Expense | \$10.70/MWh |

11.6 Environmental Compliance Information

The environmental compliance strategy and equipment for the Advanced CT Facility are the same as those used for the Conventional CT Facility (see Section 10.6). Table 11-4 presents environmental emissions for the Advanced CT Facility.

TABLE 11-4 – ENVIRONMENTAL EMISSIONS FOR ADVANCED CT

| Technology: | Advanced CT |
|-----------------------|-----------------------|
| NO_x | 0.03 lb/MMBtu |
| SO₂ | 0.001 lb/MMBtu |
| CO₂ | 117 lb/MMBtu |

12. Advanced Nuclear (AN)

12.1 Mechanical Equipment and Systems

The Advanced Nuclear (“AN”) Facility consists of two nominally rated 1,117 MW Westinghouse AP1000 nuclear power units built at a brownfield (existing nuclear facility) site.

The steam cycle of a nuclear powered electric generation facility is similar to other steam-powered generating facilities. The difference is with the source of heat used to generate steam. In units that use fossil fuels, hydrocarbons are burned to heat water, producing steam. In the AP1000, splitting the nucleus (fission) of enriched-uranium atoms provides the energy to heat the water.

Nuclear fuel is a enriched-uranium dioxide ceramic pellet typically encased in a zircalloy tube. The uranium atoms in the pellet absorb neutrons causing the nucleus of the atoms to split, or fission. When the uranium atom splits, a large amount of energy, as well as additional neutrons and fission fragments are released. The resulting nuclei contain a great deal of kinetic energy which ultimately adds heat to the primary coolant. The neutrons can be absorbed by other uranium atoms which then fission, producing more neutrons available for further fissions. The chain reaction is maintained at criticality (e.g., “self-sustaining”: neither sub-critical nor super-critical) by controlling the number of thermal neutrons available for fission such that, on average, each fission results in exactly one thermal neutron being used in a subsequent thermal fission. The number of neutrons available is controlled by the temperature (and hence the density) of the water in the nuclear reactor core, the arrangement of neutron absorbing control rods inserted into the core, the design of the core, and by controlling the void fraction and temperature of the coolant water (which both affect the density of water which affects the neutrons available for the fission process). This concept is commonly referred to as “moderation”. Moderation is the slowing down or lowering the energy of a fast neutron to a thermal neutron state such that the neutron has a higher probability of resulting in a thermal fission.

The enriched-uranium fuel is contained inside a pressurized water reactor (“PWR”). The AP1000 is a two-loop PWR. The fission of the uranium fuel releases heat to the surrounding water (reactor cooling water), which under pressure does not boil. The pressurized water from the reactor (the primary side) enters a heat exchanger (typically referred to as a steam generator) which converts lower pressure water into steam in the secondary side of the steam generator.

In the primary loop, the cooling water inside the PWR is circulated through the nuclear core by reactor coolant pumps. This cooling water system is termed the Reactor Coolant System (“RCS”). The RCS consists of two heat transfer circuits, with each circuit containing one Delta-125 U-tube type steam generator, two reactor coolant pumps, and a single hot leg and two cold legs for circulating coolant between the reactor and the steam generators. The system also includes a pressurizer, interconnecting piping, and the valves and instrumentation necessary for operational control and the actuation of safeguards. Each AP1000 unit has a 130-foot diameter freestanding containment vessel with four ring sections and an upper and lower head.

In the secondary loop, the main steam from the steam generator is routed to the HP section of the ST. The ST consists of a double-flow HP ST section and three double-flow LP ST sections in a tandem-compound configuration. As the steam exits the HP section it passes through a moisture separator and reheater. The moisture separator and reheater dries and reheats the steam before it enters the LP ST section, which improves the cycle efficiency and reduces moisture related erosion


of the LP ST blades. A portion of the steam is extracted from the HP and LP sections of the ST and with ST exhaust heats the condensate and feedwater before it is sent back to the reactor. The HP and LP STs are connected via a common shaft that drives the generator which produces the electrical power output of approximately 1,100 MW per unit.

The steam that exits the LP section of the ST, as well as the drains from the feedwater heaters, are directed to the condenser. The condenser is a surface condensing (tube type) heat exchanger that is maintained under vacuum to increase the turbine efficiency. The steam condenses on the outside of the tubes and condenser cooling water is circulated through the inside of the tubes.

The passive core cooling system provides protection of the facility against RCS leaks and ruptures. The passive containment cooling system provides for an inherently safe heat sink for the facility. The passive containment cooling system cools the containment following a loss of coolant accident by rapidly reducing the reactor coolant system pressure and promoting the natural circulation of air supplemented by water evaporation to transfer heat through the steel containment vessel and away from critical core components that may be subject to decay heat. The advantage of a passive core system is that less safety related equipment (e.g., pumping systems) is required to remove the decay heat.

Numerous other systems are needed to support and provide redundancy for the cycle process described herein. These include the residual heat removal system, the HP core flooders system, and the LP core flooders system which are redundant systems and are designed to remove heat from the reactor core in the event the normal core cooling system fails. Other support systems include the liquid and solid radioactive waste systems which handle, control, and process radioactive waste from the plant. The reactor containment ventilation system controls and filters airborne radiation. Figure 12-1 presents a simplified process flow diagram for a PWR AN plant.

FIGURE 12-1 – AN DESIGN CONFIGURATION



12.2 Electrical and Control Systems

The AN Facility has one ST electric generator for each reactor. Each generator is a 60 Hz machine rated at approximately 1,250 MVA with an output voltage of 24 kV. The ST electric generator is connected through a generator circuit breaker to a GSU that is in turn connected between two circuit breakers in the high-voltage bus in the facility switchyard through a disconnect switch. The GSU increases the voltage from the electric generator from 24 kV to interconnected transmission system high voltage.

The AN Facility is controlled using a DCS. The DCS provides centralized control of the facility by integrating the control systems provided with the reactor, ST and associated electric generator and the control of BOP systems and equipment.

12.3 Off-Site Requirements

Water for all processes at the AN Facility is obtained from one of several available water supply options; however, water is typically sourced from a nearby water source (e.g., river, lake, or ocean), when possible. The AN Facility uses a water treatment system and a high-efficiency reverse osmosis system to reduce the dissolved solids from the cooling water and to provide distilled water. Non-radioactive wastewater is sent to an adjacent river or other approved wastewater delivery point. Further, the electrical interconnection from the AN on-site switchyard is typically connected to the transmission line through an adjacent utility substation.

12.4 Capital Cost Estimate

The base Cost Estimate for the AN Facility with a nominal capacity of 2,234 MW is \$5,945/kW. Table 12-1 summarizes the Cost Estimate categories for the AN Facility.

TABLE 12-1 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR AN

| Technology: AN | | |
|---|-------------|-----------------------------------|
| Nominal Capacity (ISO): 2,234,000 kW | | |
| Nominal Heat Rate (ISO): N/A Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | | <u>(000s) (January 1, 2016\$)</u> |
| Civil Structural Material and Installation | | 1,927,067 |
| Mechanical Equipment Supply and Installation | | 3,782,925 |
| Electrical / I&C Supply and Installation | | 700,954 |
| Project Indirects ⁽¹⁾ | | 3,029,122 |
| EPC Cost before Contingency and Fee | | 9,440,067 |
| Fee and Contingency | | 1,446,413 |
| Total Project EPC | | 10,886,479 |
| Owner Costs (excluding project finance) | | 2,395,025 |
| Total Project Cost (excluding finance) | | 13,281,504 |
| Total Project EPC | / kW | 4,873 |
| Owner Costs 22% (excluding project finance) | / kW | 1,072 |
| Total Project Cost (excluding project finance) | / kW | 5,945 |

(2) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: seismic design differences, remote location issues, labor wage and productivity differences, location adjustments, owner cost differences, and the increase in overheads associated with these five adjustments.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the Advanced Nuclear Facility include Fairbanks, Alaska; Albuquerque, New Mexico; and Cheyenne, Wyoming.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the AN Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Illinois, Indiana, Maine, Maryland, Massachusetts, Minnesota, New York, Ohio, Oregon, Virginia, Washington, Wisconsin, and Wyoming.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 12-2 in the Appendix presents the AN Facility capital cost variations for alternative U.S. plant locations.

12.5 O&M Estimate

In addition to the general items discussed in the section of this report entitled O&M Estimate, the AN Facility includes provisions for major maintenance on the steam generators, STs, electric generators, BOP systems, and the reactor (beyond refueling). Table 12-3 presents typical O&M expenses for the AN Facility.

TABLE 12-3 – O&M EXPENSES FOR AN

| Technology: | AN |
|---------------------------------|-------------------------|
| Fixed O&M Expense | \$100.28/kW-year |
| Variable O&M Expense | \$2.30/MWh |

12.6 Environmental Compliance Information

Environmental compliance with respect to air emissions is effectively not necessary for the AN Facility, as this technology does not combust a fuel as is the case for other non-renewable power technologies. While there are environmental compliance considerations for a given nuclear facility (e.g., spent nuclear fuel), only air emissions were considered in this report. Table 12-4 presents environmental emissions for the AN Facility.

TABLE 12-4 – ENVIRONMENTAL EMISSIONS FOR AN

| Technology: | AN |
|-----------------------|-------------------|
| NO_x | 0 lb/MMBtu |
| SO₂ | 0 lb/MMBtu |
| CO₂ | 0 lb/MMBtu |


13. Biomass Bubbling Fluidized Bed (BBFB)

13.1 Mechanical Equipment and Systems

The Biomass BFB (“BBFB”) Facility utilizes approximately 2,000 tons per day of wood (at 50 percent maximum moisture) for the production of 50 MW net of electricity. The BBFB Facility consists of a BFB boiler, which will flow to the ST. Steam leaving the ST will be condensed to water in a shell and tube surface condenser. The water will be pumped from the “hotwell” of the condenser through a series of feedwater heaters for purposes of pre-heating the water with ST extraction steam. The combination of feedwater heating and waste heat flowing through the economizer is included to improve cycle efficiency. The water will enter the first feedwater heater where it will be heated using extraction steam from the ST. The water will then flow to the deaerating feedwater heater and into an electric-driven boiler feed pump where the pressure of the water will be increased to approximately 1,800 psia. After leaving the boiler feed pump, the water will flow through two more feedwater heaters. After exiting the last feedwater heater, the water will flow to the economizer section of the BFB boiler for delivery to the combustion section where it will be converted back to steam and the cycle will be repeated. The cooling tower is to be used to cool the circulating water that is used to condense the steam inside the condenser.

In a BFB boiler, a portion of air is introduced through the bottom of the combustor. The bottom of the bed is supported by refractory walls or water-cooled membrane with specially designed air nozzles which distribute the air uniformly. The fuel and limestone are fed into the lower bed. In the presence of fluidizing air, the fuel and limestone quickly and uniformly mix under the turbulent environment and behave like a fluid. Carbon particles in the fuel are exposed to the combustion air. The balance of combustion air is introduced at the top of the lower, dense bed. This staged combustion limits the formation of NO_x. The advantages of BFB boiler technology include fuel flexibility, low SO₂ emissions, low NO_x emissions, and high combustion efficiency. Figure 13-1 presents the BBFB process flow diagram.

FIGURE 13-1 – BBFB DESIGN CONFIGURATION



13.2 Electrical and Control Systems

The BBFB Facility has one ST electric generator. The generator for the ST is a 60 Hz machine rated at approximately 65 MVA with an output voltage of 13.8 kV. The generator breakers for the ST electric generator are bussed together in 15 kV class switchgear that is connected to a high-voltage transmission system at the facility switchyard via a circuit breaker, GSU, and a disconnect switch. The GSU increases the voltage from the electric generators from 13.8 kV to interconnected transmission system high voltage.

The BBFB Facility is controlled using a DCS. The DCS provides centralized control of the facility by integrating the control systems provided with the ST and associated electric generator and the control of BOP systems and equipment.

13.3 Off-Site Requirements

Biomass is delivered to the BBFB Facility by rail, truck or barge. Water for all processes at the BBFB Facility is obtained from one of several available water sources. The BBFB Facility uses a water treatment system and a high-efficiency reverse osmosis system to reduce the dissolved solids from the cooling water and to provide distilled water for HRSG makeup. Wastewater is sent to a municipal wastewater system or other available wastewater delivery point. Further, the electrical interconnection from the BBFB Facility on-site switchyard is effectuated by a connection to an adjacent utility substation.

13.4 Capital Cost Estimate

The base Cost Estimate for the BBFB Facility with a nominal capacity of 50 MW is \$4,985/kW. Table 13-1 summarizes the Cost Estimate categories for the BBFB Facility.

TABLE 13-1 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR BBFB

| Technology: BBFB | | |
|---|-----------------------------------|----------------|
| Nominal Capacity (ISO): 50,000 kW | | |
| Nominal Heat Rate (ISO): 13,500 Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> | |
| Civil Structural Material and Installation | | 15,349 |
| Mechanical Equipment Supply and Installation | | 100,992 |
| Electrical / I&C Supply and Installation | | 22,897 |
| Project Indirects ⁽¹⁾ | | 49,598 |
| EPC Cost before Contingency and Fee | | 188,836 |
| Fee and Contingency | | 18,884 |
| Total Project EPC | | 207,720 |
| Owner Costs (excluding project finance) | | 41,544 |
| Total Project Cost (excluding finance) | | 249,264 |
| Total Project EPC | / kW | 4,154 |
| Owner Costs 20% (excluding project finance) | / kW | 831 |
| Total Project Cost (excluding project finance) | / kW | 4,985 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: outdoor installation considerations, seismic design differences, remote location issues, labor wage and productivity differences, location adjustments, owner cost differences, and the increase in overheads associated with these six adjustments.

Outdoor installation locations are considered in geographic areas where enclosed structures for the boilers would not be required due to the low probability of freezing. The locations that included outdoor installation are Alabama, Arkansas, Florida, Georgia, Hawaii, Louisiana, Mississippi, South Carolina, and Puerto Rico.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to

construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the BBFB include Fairbanks, Alaska; Honolulu, Hawaii; Great Falls, Montana; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the BBFB Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Hawaii, Illinois, Indiana, Maine, Maryland, Massachusetts, Minnesota, New York, Ohio, Oregon, Virginia, Washington, Wisconsin, and Puerto Rico.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 13-2 in the Appendix presents the BBFB Facility capital cost variations for alternative U.S. plant locations.

13.5 O&M Estimate

In addition to the general items discussed in the section of this report entitled O&M Estimate, the BBFB Facility includes the major maintenance for the ST and associated electric generator, as well as the BOP. These major maintenance expenses are included with the VOM expense for this technology and are given on an average basis across the MWhs incurred. Typically, significant overhauls on a BBFB Facility occur no less frequently than 6 to 8 years. Table 13-3 presents the O&M expenses for the BBFB Facility.

TABLE 13-3 – O&M EXPENSES FOR BBFB

| Technology: | BBFB |
|---------------------------------|-------------------------|
| Fixed O&M Expense | \$110.00/kW-year |
| Variable O&M Expense | \$4.20/MWh |

13.6 Environmental Compliance Information

The BBFB Facility utilizes BFB combustion to control NO_x and CO. SO₂ in the BFB is managed through the use of low-sulfur biomass feedstocks. The BBFB Facility does not include any control devices for CO₂, which is proportional to the heat rate (inversely proportional to the efficiency) of the technology. Water, wastewater, and solid waste compliance are achieved through traditional on-site and off-site methods, and the costs for such compliance are included in the O&M Estimate for the BBFB Facility. Table 13-4 presents environmental emissions for the BBFB Facility.

TABLE 13-4 – ENVIRONMENTAL EMISSIONS FOR BBFB

| Technology: | BBFB |
|-----------------------|-------------------------------------|
| NO_x | 0.08 lb/MMBtu |
| SO₂ | 0 lb/MMBtu |
| CO₂ | 195 lb/ MMBtu ⁽¹⁾ |

(1) Does not account for the life-cycle fate of CO₂ after emission from power generation unit.

14. Onshore Wind (WN)

14.1 Mechanical Equipment and Systems


The Onshore Wind (“WN”) Facility is based on 56 wind turbine generators (“WTGs”), each with a rated capacity of 1.79 MW. The total design capacity is 100 MW.

The turbines are each supported by a conical steel tower, which is widest at the base and tapers in diameter just below the nacelle. A foundation provides the tower with a firm anchor to the ground. The nacelle is attached to the top of the tower and contains the main mechanical components of the wind turbine, which include a variable-speed generator, transmission, and yaw drive. The rotor hub connects to the transmission through one end of the nacelle, and the rotor is then connected to the hub. Each WTG has a three-bladed rotor with a diameter of 100 meters and hub height of 80 meters. The WTG has an active yaw system in the nacelle to keep the rotor facing into the wind.

Power is generated by the wind turbines, then converted using an onboard transformer to 34.5 kV AC. It is then delivered to a collection system at the base of each turbine. Power from all turbines will be collected by the underground collection circuit.

The collection system supplies power to a new substation designed to step up the voltage to 115 kV for interconnection with the transmission system. Other facility components include access roads, an O&M building and electrical interconnection facilities. Figure 14-1 presents a picture of a typical WN Facility.

FIGURE 14-1 – WN DESIGN CONFIGURATION



14.2 Electrical and Control Systems

The WN Facility has 56 wind turbine-driven electric generators. Each generator is a doubly-fed induction generator that feeds an AC/DC/AC power converter that provides an output of three-phase, 60 Hz electrical power. The power output available is approximately 1.75 MVA with an output voltage of 575 V stepped up to 34.5 kV using a pad-mounted transformer at the base of the wind turbine. The wind turbine transformers are interconnected on one or more underground

collector circuits that are connected to a collector bus through a circuit breaker for each circuit. The collector bus is connected to a high-voltage transmission system through the facility substation, which includes a 34.5 kV switch or circuit breaker, GSU, high-voltage circuit breaker, and a disconnect switch. The GSU increases the voltage from the electric generator from 34.5 kV to interconnected transmission system high voltage.

The WN Facility is controlled using a control system generally referred to as the wind farm supervisory control and data acquisition (“SCADA”) system. The SCADA system provides centralized control of the facility by integrating the control systems provided with each of the wind turbines and the control of BOP systems and equipment.

14.3 Off-Site Requirements

Since wind uses a renewable fuel, the most significant off-site requirements are the construction of and interconnection to roads and the electrical interconnection to the utility high-voltage transmission system, as discussed in Section 14.2.

14.4 Capital Cost Estimate

The base Cost Estimate for the WN Facility with a nominal capacity of 100 MW is \$1,877/kW. Table 14-1 summarizes the Cost Estimate categories for the WN Facility.

TABLE 14-1 – LOCATION-BASED COSTS FOR WN

| Technology: WN | | |
|---|-----------------------------------|----------------|
| Nominal Capacity (ISO): 100,000 kW | | |
| Nominal Heat Rate (ISO): N/A Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> | |
| Civil Structural Material and Installation | | 19,690 |
| Mechanical Equipment Supply and Installation | | 122,924 |
| Electrical / I&C Supply and Installation | | 15,450 |
| Project Indirects ⁽¹⁾ | | 6,480 |
| EPC Cost before Contingency and Fee | | 164,544 |
| Fee and Contingency | | 12,500 |
| Total Project EPC | | 177,044 |
| Owner Costs (excluding project finance) | | 10,623 |
| Total Project Cost (excluding finance) | | 187,667 |
| Total Project EPC | / kW | 1,770 |
| Owner Costs 6% (excluding project finance) | / kW | 106 |
| Total Project Cost (excluding project finance) | / kW | 1,877 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.
(2) Total Project Costs excludes any transmission lines or utility interconnection facilities.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: seismic design differences, remote location issues, labor wage and productivity differences, location adjustments, and owner cost differences and the increase in overheads associated with these five adjustments.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Although wind energy projects are typically in remote locations, the

following locations are considered very remote and require additional costs due to their locations. These remote locations related to the WN Facility include Fairbanks, Alaska; Honolulu, Hawaii; Great Falls, Montana; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the WN Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Hawaii, Illinois, Indiana, Maine, Maryland, Massachusetts, Michigan, Minnesota, Montana, New Hampshire, New Jersey, New York, North Dakota, and Virginia.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs.

Table 14-2 in the Appendix presents the WN Facility capital cost variations for alternative U.S. plant locations.

14.5 O&M Estimate

In addition to the general items discussed in the section of the report entitled O&M Estimate, the major areas for O&M for an Onshore Wind Facility include periodic gearbox, WTG, electric generator, and associated electric conversion (e.g., GSU) technology repairs and replacement. These devices typically undergo major maintenance every five to seven years. Based on recent experience, most WN operators do not treat O&M on a variable basis, and consequently, all O&M expenses are shown below on a fixed basis. Table 14-3 presents the O&M expenses for the WN Facility.

TABLE 14-3 – O&M EXPENSES FOR WN

| Technology: | WN |
|---------------------------------|------------------------|
| Fixed O&M Expense | \$39.70/kW-year |
| Variable O&M Expense | \$0/MWh |

14.6 Environmental Compliance Information

Since wind utilizes a renewable energy source and no fuel is combusted to make power from an Onshore Wind Facility, air emissions are not created. Table 14-4 presents environmental emissions for the WN Facility.

TABLE 14-4 – ENVIRONMENTAL EMISSIONS FOR WN

| Technology: | WN |
|-----------------------|--------------------|
| NO_x | 0 lb/ MMBtu |
| SO₂ | 0 lb/MMBtu |
| CO₂ | 0 lb/MMBtu |

15. Utility-Scale Photovoltaic (PV) Facility

15.1 Mechanical Equipment and Systems

The following describes a nominal 20 MW-AC Fixed Photovoltaic (“PV”) Facility. An analysis is also provided for a nominal 20 MW-AC PV Tracker Facility and a 150 MW-AC PV Tracker Facility, which is essentially a significant expansion of the 20 MW Facility; however, a detailed technical description (due to the similarities with the 20 MW Facility and the technology associated therewith) is not provided herein. The PV Facility uses numerous arrays of ground-mounted, single-axis tracking PV modules which directly convert incident solar radiation into DC electricity, which can then be inverted to AC. Additional BOP components include metal racks mounted to tracker components (drive motors, gearboxes, linkages, etc.) supported by foundations, DC wiring, combiner boxes where individual series circuits (“strings”) of panels are connected prior to being fed into the inverters, DC-to-AC inverters, AC wiring, various switchgear and step-up transformers, and a control system (partly incorporated into the inverter control electronics) to monitor plant output and adjust the balance of voltage and current to yield maximum power. Figure 15-1 presents a picture of a typical PV Facility.

FIGURE 15-1 – TYPICAL PV FACILITY



15.2 Electrical and Control Systems

The 20 MW-AC PV Facility is comprised of 40 half-megawatt building blocks, each block consisting of groups of PV modules connected to a 500 kW-AC inverter. While the ratio of DC module capacity to AC inverter capacity varies, for this analysis we have assumed a ratio of 1.3:1 for the fixed option and 1.2:1 for the tracker option. The project is set up so that the fixed option will have 650 kW-DC of modules per 500 kW-AC inverter, and the tracker option will have 600 kW-DC of modules per 500 kW-AC inverter. Such a ratio is typical of current systems, though higher ratios are becoming more common. Groups of PV modules produce DC electricity and are connected in series to form series “strings” which are then connected in parallel in a combiner box which contains a fuse for each string. The cables are routed from the modules to combiner boxes and a number of combiner boxes are connected to the input of a 500 kW-AC inverter, which converts the aggregate power from DC to three-phase AC electricity at an output voltage of typically 265 V-AC to 420 V-AC. The output voltage of an inverter (or sometimes several inverters connected together) is stepped up to a higher voltage level, typically in the range of 13.8 kV (or 34.5 kV for larger systems) through a GSU connected to the inverter output terminals. The output of two or more inverters is frequently combined into a shared transformer, each of which is rated 1 MVA (or higher for larger groups of inverters). The transformers are connected in groups to form circuits on an underground collection system. The circuits are connected to a 13.8 kV circuit breaker and then to the local utility distribution grid.

Each inverter has its own integral control system. The aggregate of all the inverters and associated DC arrays are monitored through a SCADA system, sometimes provided by the inverter manufacturer.

15.3 Off-Site Requirements

Unlike other power technologies discussed in this report, the essential off-site requirements for which provisions must be made on a PV Facility are water supply (generally in limited quantities for purposes of module washing once or twice annually) and an electrical interconnection between the PV Facility switchyard and the local utility distribution system. With regard to water supply, we note that some PV facilities purchase water off-site for purposes of module washing.

15.4 Capital Cost Estimate

The base Cost Estimate for the PV Facility with a nominal capacity of 20 MW-AC Fixed is 2,671/kW-AC, with a nominal capacity of 20 MW-AC Tracker is 2,644/kW-AC, and with a nominal capacity of 150 MW is \$2,534/kW-AC. Table 15-1, Table 15-2, and Table 15-3 summarize the Cost Estimate categories for the PV Facility.

TABLE 15-1 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR PV

| Technology: PV Fixed | | |
|---|-------------|-----------------------------------|
| Nominal Capacity (ISO): 20,000 kW/AC – 26,000 kW/DC | | |
| Nominal Heat Rate (ISO): N/A Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | | <u>(000s) (January 1, 2016\$)</u> |
| Civil Structural Material and Installation | | 5,239 |
| Mechanical Equipment Supply and Installation | | 23,987 |
| Electrical / I&C Supply and Installation | | 8,994 |
| Project Indirects ⁽¹⁾ | | 2,244 |
| EPC Cost before Contingency and Fee | | 40,464 |
| Fee and Contingency | | 4,046 |
| Total Project EPC | | 44,511 |
| Owner Costs (excluding project finance) | | 8,902 |
| Total Project Cost (excluding finance) | | 53,413 |
| Total Project EPC | / kW | 2,226 |
| Owner Costs 20% (excluding project finance) | / kW | 445 |
| Total Project Cost (excluding project finance) | / kW | 2,671 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

TABLE 15-2 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR PV

| Technology: PV - Tracker Nominal Capacity (ISO): 20,000 kW/AC – 24,000 kW/DC Nominal Heat Rate (ISO): N/A Btu/kWh-HHV | | |
|--|-------------|--|
| <u>Capital Cost Category</u> | | <u>(000s) (January 1, 2016\$)</u> |
| Civil Structural Material and Installation | | 4,837 |
| Mechanical Equipment Supply and Installation | | 24,608 |
| Electrical / I&C Supply and Installation | | 8,366 |
| Project Indirects ⁽¹⁾ | | 2,244 |
| EPC Cost before Contingency and Fee | | 40,055 |
| Fee and Contingency | | 4,005 |
| Total Project EPC | | 44,060 |
| Owner Costs (excluding project finance) | | 8,812 |
| Total Project Cost (excluding finance) | | 52,872 |
| Total Project EPC | / kW | 2,203 |
| Owner Costs 12% (excluding project finance) | / kW | 441 |
| Total Project Cost (excluding project finance) | / kW | 2,644 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

TABLE 15-3 – BASE PLANT SITE CAPITAL COST ESTIMATE FOR PV

| Technology: PV - Tracker | | |
|---|-------------|-----------------------------------|
| Nominal Capacity (ISO): 150,000 kW/AC – 180,000 kW/DC | | |
| Nominal Heat Rate (ISO): N/A Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | | <u>(000s) (January 1, 2016\$)</u> |
| Civil Structural Material and Installation | | 36,304 |
| Mechanical Equipment Supply and Installation | | 193,336 |
| Electrical / I&C Supply and Installation | | 53,818 |
| Project Indirects ⁽¹⁾ | | 13,991 |
| EPC Cost before Contingency and Fee | | 297,449 |
| Fee and Contingency | | 45,000 |
| Total Project EPC | | 342,449 |
| Owner Costs (excluding project finance) | | 37,669 |
| Total Project Cost (excluding finance) | | 380,118 |
| Total Project EPC | / kW | 2,283 |
| Owner Costs 12% (excluding project finance) | / kW | 251 |
| Total Project Cost (excluding project finance) | / kW | 2,534 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: seismic design differences, remote location issues, labor wage and productivity differences, location adjustments, owner cost differences, and the increase in overheads associated with these five location adjustments.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the Photovoltaic Facility include Fairbanks,

Alaska; Honolulu, Hawaii; Great Falls, Montana; Albuquerque, New Mexico; Cheyenne, Wyoming; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the PV Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Hawaii, Illinois, Indiana, Maine, Maryland, Massachusetts, Minnesota, Montana, New York, North Dakota, South Dakota, West Virginia, Wisconsin, and Wyoming.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Tables 15-4, 15-5, and 15-6 in the Appendix present the PV Facility capital cost variations for alternative U.S. plant locations.

15.5 O&M Estimate

The significant O&M items for a PV Facility include periodic inverter maintenance and periodic panel water washing. In general, most PV facility operators do not treat O&M on a variable basis, and consequently, all O&M expenses are shown below on a fixed basis. Table 15-7, Table 15-8, and Table 15-9 present the O&M expenses for the PV Facility. The O&M cost variance listed in the below tables are primarily due to economies of scale and the higher O&M costs associated with the tracking facility.

TABLE 15-7 – O&M EXPENSES FOR PV FIXED FACILITY (20 MW)

| Technology: | PV-Fixed |
|---------------------------------|---------------------------|
| Fixed O&M Expense | \$23.40/kW-AC-year |
| Variable O&M Expense | \$0/MWh |

TABLE 15-8 – O&M EXPENSES FOR PV-TRACKER FACILITY (20 MW)

| Technology: | PV - Tracker |
|---------------------------------|---------------------------|
| Fixed O&M Expense | \$23.90/kW-AC-year |
| Variable O&M Expense | \$0/MWh |

TABLE 15-9 – O&M EXPENSES FOR PV-TRACKING FACILITY (150 MW)

| Technology: | PV – Tracking |
|---------------------------------|---------------------------|
| Fixed O&M Expense | \$21.80/kW-AC-year |
| Variable O&M Expense | \$0/MWh |

15.6 Environmental Compliance Information

Table 15-10 presents environmental emissions for the PV Facility.

TABLE 15-10 – ENVIRONMENTAL EMISSIONS FOR PV

| Technology: | Photovoltaic |
|-----------------------|---------------------|
| NO_x | 0 lb/ MMBtu |
| SO₂ | 0 lb/MMBtu |
| CO₂ | 0 lb/MMBtu |

16. Reciprocating Internal Combustion Engine (RICE)

16.1 Mechanical Equipment and Systems

The Reciprocating Internal Combustion Engine (“RICE”) Electric Generating Facility is based on five Wärtsilä Engines, each with a net rated output capacity of 17 MW. The total design capacity is 85 MW.


The RICE generating facility is comprised of the engine generating sets which are fired on natural gas; medium voltage generators coupled to each engine; the engine auxiliary systems; and the electrical and control system. The engine auxiliary systems include fuel gas, lubricating oil, compressed air, cooling water, air intake, and exhaust gas systems.

Each engine is a four-stroke, spark-ignited gas engine that operates on the Otto cycle. The engines are comprised of 18 cylinders in a “V” configuration with two inlet valves and two exhaust valves per cylinder. Each engine includes a turbocharger with an intercooler that uses the expansion of hot exhaust gases to drive a compressor that raises the pressure and density of the inlet air to each cylinder. The turbocharger is an axial turbine/compressor with the turbine and the centrifugal compressor mounted on the same shaft. Heat generated by compressing the inlet air is removed by a water cooled “intercooler”. Turbocharging increases the engine output due to the denser air/fuel mixture.

The engine block is nodular cast iron and is cast in one piece. The block includes water passages for engine cooling and oil passages for engine lubrication. The crankshaft is forged in one piece and is balanced by counter weights. The engine uses a lean burn gas injection system where the air-fuel mixture contains more air than required for combustion. In this process, ignition of the gas by a spark plug is initiated in a pre-chamber where a richer fuel mixture is used. The flame from the pre-chamber ignites the lean air/fuel mixture in the cylinder.

The engines are cooled using a water/glycol mixture that circulates through the engine block, cylinder heads and the charge air coolers. The cooling system is a closed-loop system and is divided into a high temperature and a low temperature circuit. The high temperature circuit cools the engine block, cylinder heads and the first stage of the charge air cooler. The low temperature cooler cools the second stage of the charge air cooler. Heat is rejected from the cooling water system by air cooled radiators. Figure 16-1 represents a simplified process flow diagram for a RICE facility.

FIGURE 16-1 – RICE SCHEMATIC CONFIGURATION



16.2 Electrical and Control Systems

The electrical generator is coupled to the engine flywheel using a flexible coupling. The generator is a medium voltage, synchronous AC generator with a brushless excitation system. The generators are air-cooled using a fan mounted on the generator shaft to provide ambient air for cooling. The generator uses current and voltage measurement transformers to monitor the generator for control and protection.

A generator step-up transformer (“GSU”) is used to raise the voltage from the generator to the transmission line voltage. Output from the GSU passes through the Facility switchyard, which provides breaker protection for the Facility and the transmission line as well as disconnect capability so that the Facility can be disconnected from the transmission system when needed. The switchyard also includes metering, a supervisory control and data acquisition system, and communication systems.

The RICE Facility uses a distributed control system that provides plant control, alarms, and safety functions. The control room is located on the Facility site, but the Facility can also be controlled and monitored remotely. The system can be operated in automatic or manual modes. The control system uses the “Wärtsilä Operator Interface System” (“WOIS”) for operating the Facility and the “Wärtsilä Information System Environment” (“WISE”) for recording and storing information.

16.3 Off-Site Requirements

Natural gas is delivered to the Facility through a gas lateral connected to the local natural gas trunk line. The natural gas line pressure is reduced at the Facility by a gas regulating system. Water for the limited processes that utilize water is obtained from the municipal water supply. The RICE Facility does not require water treatment for engine cooling unless the water supply contains high levels of solids or dissolved solids. Wastewater is treated using an oil-water separator and then is directed to a municipal wastewater system. The RICE Facility’s on-site switchyard is connected to the transmission system through an adjacent utility substation.

16.4 Capital Cost Estimate

The base Cost Estimate for the RICE Facility with a nominal capacity of 85 MW is \$1,342/kW. Table 16-1 summarizes the Cost Estimate categories for the RICE Facility.

TABLE 16-1 – LOCATION-BASED COSTS FOR RICE

| Technology: RICE | |
|---|--|
| Nominal Capacity (ISO): 85,000 kW | |
| Nominal Heat Rate (ISO): 8,500 Btu/kWh-HHV | |
| <u>Capital Cost Category</u> | <u>(000s) (January 1, 2016\$)</u> |
| Civil Structural Material and Installation | 9,473 |
| Mechanical Equipment Supply and Installation | 49,716 |
| Electrical / I&C Supply and Installation | 10,827 |
| Project Indirects ⁽¹⁾ | 16,070 |
| EPC Cost before Contingency and Fee | 86,086 |
| Fee and Contingency | 9,000 |
| Total Project EPC | 95,086 |
| Owner Costs (excluding project finance) | 19,017 |
| Total Project Cost (excluding finance) | 114,103 |
| Total Project EPC | / kW |
| Owner Costs 20% (excluding project finance) | 1,119 |
| Total Project Cost (excluding project finance) | / kW |
| | 224 |
| | 1,342 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: seismic design differences, remote location issues, labor wage and productivity differences, location adjustments, and owner cost differences and the increase in overheads associated with these five adjustments.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the RICE Facility include Fairbanks, Alaska; Honolulu, Hawaii; Great Falls, Montana; Albuquerque, New Mexico; Cheyenne, Wyoming; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the RICE Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Hawaii, Illinois, Indiana, Iowa, Kansas, Maine, Maryland, Massachusetts, Michigan, Minnesota, Montana, Nebraska, New York, North Dakota, Ohio, Pennsylvania, South Dakota, West Virginia, Wisconsin, and Wyoming.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 16-2 in the Appendix presents the RICE Facility capital cost variations for alternative U.S. plant locations.

16.5 O&M Estimate

In addition to the general items discussed in the section of the report entitled O&M Estimate, the major areas for O&M for the RICE Facility include engine and generator minor and major maintenance which are based on hours of operation. The maintenance range is from 3,500 hours of operation for typical maintenance items, 12,000 hours of operation for a minor overhaul, and 16,000 hours of operation for a major overhaul. Additionally O&M maintenance and repair includes balance of plant systems such as the compressed air system, fire water system, lube oil system, and the emission control system. Table 16-3 presents the O&M expenses for the RICE Facility, which is based on the RICE Facility operating as a peaking plant.

TABLE 16-3 – O&M EXPENSES FOR RICE

| Technology: | RICE |
|---------------------------------|-----------------------|
| Fixed O&M Expense | \$6.90/kW-year |
| Variable O&M Expense | \$5.85/MWh |

16.6 Environmental Compliance Information

Each RICE engine generator set utilizes an SCR and oxidation catalyst located in the exhaust system to control NO_x and CO emission from the Facility. Sulfur oxide emissions from the RICE Facility are managed through the natural gas fuel quality, which in the U.S. is generally very low in sulfur. The RICE Facility does not include any control devices for CO₂. Additionally water, wastewater, and solid waste compliance are achieved through traditional on-site and off-site

methods, and the costs for such compliance are included in the O&M estimate for the Facility. Table 16-4 presents environmental emissions for the RICE Facility.

TABLE 16-4 – ENVIRONMENTAL EMISSIONS FOR RICE

| Technology: | RICE |
|-----------------------|-----------------------|
| NO_x | 0.07 g/bhp-hr |
| SO₂ | 0.001 lb/MMBtu |
| CO₂ | 117 lb/MMBtu |

17. Battery Storage (BES)

17.1 Mechanical Equipment and Systems


The Battery Storage (“BES”) Facility is based on two energy storage modules in 8’ x 40’ containers, each with a rated capacity of 2.0 MW and 1.0 MWh. The total design capacity is 4.0 MW and 2.0 MWh.

The containers are delivered to the site fully assembled and placed on piers or a pad for their foundation. These are then anchored to their foundations.

Within each container, energy is stored in the battery modules, which are direct current (“DC”) elements. They are connected into series strings to form the input voltage for the bi-directional inverter which is called the Power Conversion System (“PCS”). Multiple strings of batteries are connected to the PCS DC input side in parallel to form the container’s energy storage capacity. The PCS maintains AC output power quality while the DC input varies with battery string’s state of charge and operating current. The output of the PCS is 480 VAC, three phase. Multiple containers are paralleled on the PCS AC output side to form the energy storage capacity of the BES. Each container incorporates the needed internal space conditioning, fans and HVAC; as well as battery modules and the PCS, which consists of multiple paralleled units.

The BES, including its step up transformer and BOP equipment, connect to the grid distribution system. Other facility components include access roads, an O&M building and electrical interconnection facilities. Figure 17-1 presents a picture of a typical BES Facility.

FIGURE 17-1 – BES DESIGN CONFIGURATION



17.2 Electrical and Control Systems

The BES Facility has two energy storage containers. Within each container are appropriate current limiters, sensors, and disconnect switches to isolate faults and facilitate servicing of modules while allowing for continued operation of unaffected elements. Each container’s output voltage of 480 VAC is stepped up to 34.5 kV using a pad-mounted transformer located near the BES

containers. The output of the 34.5 kV transformer is connected to the grid through appropriate switchgear, current limiters, disconnect switches, and meters.

Each BES container has multiple levels of internal controls. The individual battery modules are each monitored and controlled by a Battery Management Unit (“BMU”). Each battery string is controlled by a Battery String Management Unit (“BSMU”) and each container is controlled by a Battery Control Management Unit (“BCMUs”). Additionally, each PCS has its own controller to support the many operational use cases of the smart inverters. Each container has its own fire detection and suppression system with its dedicated sensors, annunciators, and controller.

The BES Facility is controlled using a control system generally referred to as its supervisory control and data acquisition (“SCADA”) system. The SCADA system provides centralized control of the facility by integrating the control systems provided with each of the PCSs and BCMUs and the control of the BOP systems and equipment. The SCADA may also be connected to the grid’s control and dispatch center located remotely from the BES.

17.3 Off-Site Requirements

The most significant off-site requirements are the construction of and interconnection to roads and the electrical interconnection to the utility transmission & distribution system, as discussed in Section 17.2. A BES requires a bi-directional power flow interface to the grid. During BES discharge, it acts as a generation source (or load reduction at its point of interconnection (“POI”)) and during charge, it acts as an increased load to the grid at its POI.

17.4 Capital Cost Estimate

The base Cost Estimate for the BES Facility with a nominal capacity of 4.0 MW 2.0 MWh is \$2,813/kW. Table 17-1 summarizes the Cost Estimate categories for the BES Facility.

TABLE 17-1 – LOCATION-BASED COSTS FOR BES

| Technology: BES | | |
|---|-------------|-----------------------------------|
| Nominal Capacity (ISO): 4,000 kW 2,000 kWh | | |
| Nominal Heat Rate (ISO): N/A Btu/kWh-HHV | | |
| <u>Capital Cost Category</u> | | <u>(000s) (January 1, 2016\$)</u> |
| Civil Structural Material and Installation | | 434 |
| Mechanical Equipment Supply and Installation | | 5,857 |
| Electrical / I&C Supply and Installation | | 1,251 |
| Project Indirects ⁽¹⁾ | | 1,718 |
| EPC Cost before Contingency and Fee | | 9,260 |
| Fee and Contingency | | 787 |
| Total Project EPC | | 10,047 |
| Owner Costs (excluding project finance) | | 1,206 |
| Total Project Cost (excluding finance) | | 11,253 |
| Total Project EPC | / kW | 2,512 |
| Owner Costs 6% (excluding project finance) | / kW | 302 |
| Total Project Cost (excluding project finance) | / kW | 2,813 |

(1) Includes engineering, distributable costs, scaffolding, construction management, and start-up.

For this type of technology and power plant configuration, our regional adjustments took into consideration the following: seismic design differences, remote location issues, labor wage and productivity differences, location adjustments, and owner cost differences and the increase in overheads associated with these five adjustments.

Seismic design differences among the various locations were based on U.S. seismic map information that detailed the various seismic zones throughout the U.S. No cost increases were associated with seismic Zone 0 and cost step increases were considered for Zones 1, 2, 3 and 4.

Remote location issues are related to geographic areas that typically require installation of man camps, higher craft incentives, and higher per diems are generally required with respect to construction, due to the fact that such areas are long distances from urban areas, where labor is generally abundant. Remote location designations were also considered in locations where higher equipment freight costs are typically incurred, which for example are regions not near established rail or highway access. Remote locations related to the BES Facility include Fairbanks, Alaska; Honolulu, Hawaii; Great Falls, Montana; and Cayey, Puerto Rico.

Labor wage and productivity differences were handled as discussed in Section 2.6.1, taking into consideration the amount of labor we estimated for the BES Facility.

Location adjustments were made to locations where higher cost of living levels are incurred and/or where population density generally correlates to higher construction costs for power and other infrastructure projects. These locations include, but are not limited to, Alaska, California, Connecticut, Delaware, District of Columbia, Hawaii, Illinois, Indiana, Maine, Maryland, Massachusetts, Minnesota, Montana, New York, North Dakota, South Dakota, West Virginia, Wisconsin, and Wyoming.

Owner costs were reviewed based on the need for utility upgrades and/or infrastructure costs such as new facility transmission lines to tie to existing utility transmission substations or existing transmission lines.

Table 17-2 in the Appendix presents the BES Facility capital cost variations for alternative U.S. plant locations.

17.5 O&M Estimate

In addition to the general items discussed in the section of the report entitled O&M Estimate, the major areas for O&M for a BES include visual inspection, maintaining: torque values of connections, the PCS, the fire protection system, and the HVAC for the containers. These are all considered fixed O&M expenses. Battery modules themselves are maintained by the automated controls and require no additional maintenance unless there is a failure, which the controls will announce with an alarm. Variable O&M consists of augmentation of the energy storage elements (battery modules) as their capacity degrades with usage (combination of cyclic and calendar aging). This is necessary to make sure the BES can continue to support its rated output throughout the BES operational life. Table 17-3 presents the O&M expenses for the BES Facility.

TABLE 17-3 – O&M EXPENSES FOR BES

| Technology: | BES |
|---------------------------------|------------------------|
| Fixed O&M Expense | \$40.00/kW-year |
| Variable O&M Expense | \$8.00/MWh |

17.6 Environmental Compliance Information

The BES Facility produces no emissions on discharge. However, during charge the ascribed emissions would be those of the charging generation source. The BES requires 1.18 kWh of recharge for each 1.0 kWh discharged.

TABLE 17-4 – ENVIRONMENTAL EMISSIONS FOR BES

| Technology: | BES |
|-----------------------|-------------------|
| NO_x | 0 lb/MMBtu |
| SO₂ | 0 lb/MMBtu |
| CO₂ | 0 lb/MMBtu |

APPENDIX 1 – STATE INFORMATION

TABLE 3-2 – LOCATION-BASED COSTS FOR USC (650,000 KW)

(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Alaska | Anchorage | 3,636 | 30% | 1,074 | 4,710 |
| Alaska | Fairbanks | 3,636 | 31% | 1,129 | 4,765 |
| Alabama | Huntsville | 3,636 | -11% | (389) | 3,247 |
| Arizona | Phoenix | 3,636 | -8% | (284) | 3,352 |
| Arkansas | Little Rock | 3,636 | -7% | (268) | 3,368 |
| California | Los Angeles | 3,636 | 16% | 585 | 4,221 |
| California | Redding | 3,636 | 9% | 329 | 3,965 |
| California | Bakersfield | 3,636 | 9% | 328 | 3,964 |
| California | Sacramento | 3,636 | 9% | 337 | 3,973 |
| California | San Francisco | 3,636 | 31% | 1,133 | 4,769 |
| Colorado | Denver | 3,636 | -9% | (312) | 3,324 |
| Connecticut | Hartford | 3,636 | 23% | 854 | 4,490 |
| Delaware | Dover | 3,636 | 20% | 738 | 4,374 |
| District of Columbia | Washington | 3,636 | 35% | 1,277 | 4,913 |
| Florida | Tallahassee | 3,636 | -8% | (308) | 3,328 |
| Florida | Tampa | 3,636 | -7% | (244) | 3,392 |
| Georgia | Atlanta | 3,636 | -11% | (387) | 3,249 |
| Hawaii | Honolulu | N/A | N/A | N/A | N/A |
| Idaho | Boise | 3,636 | -4% | (162) | 3,474 |
| Illinois | Chicago | 3,636 | 14% | 526 | 4,162 |
| Indiana | Indianapolis | 3,636 | 0% | (7) | 3,629 |
| Iowa | Davenport | 3,636 | -1% | (53) | 3,583 |
| Iowa | Waterloo | 3,636 | -6% | (217) | 3,419 |
| Kansas | Wichita | 3,636 | -7% | (269) | 3,367 |
| Kentucky | Louisville | 3,636 | -7% | (271) | 3,365 |
| Louisiana | New Orleans | 3,636 | -13% | (473) | 3,163 |
| Maine | Portland | 3,636 | -5% | (190) | 3,446 |
| Maryland | Baltimore | 3,636 | 1% | 30 | 3,666 |
| Massachusetts | Boston | 3,636 | 32% | 1,147 | 4,783 |
| Michigan | Detroit | 3,636 | 2% | 78 | 3,714 |
| Michigan | Grand Rapids | 3,636 | -4% | (133) | 3,503 |
| Minnesota | Saint Paul | 3,636 | 6% | 212 | 3,848 |
| Mississippi | Jackson | 3,636 | -7% | (270) | 3,366 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 3,636 | 2% | 76 | 3,712 |
| Missouri | Kansas City | 3,636 | 0% | (15) | 3,621 |
| Montana | Great Falls | 3,636 | -4% | (132) | 3,504 |
| Nebraska | Omaha | 3,636 | -4% | (159) | 3,477 |
| New Hampshire | Concord | 3,636 | -1% | (30) | 3,606 |
| New Jersey | Newark | 3,636 | 11% | 406 | 4,042 |
| New Mexico | Albuquerque | 3,636 | -6% | (200) | 3,436 |
| New York | New York | 3,636 | 36% | 1,307 | 4,943 |
| New York | Syracuse | 3,636 | -3% | (93) | 3,543 |
| Nevada | Las Vegas | 3,636 | 4% | 144 | 3,780 |
| North Carolina | Charlotte | 3,636 | -12% | (430) | 3,206 |
| North Dakota | Bismarck | 3,636 | -7% | (248) | 3,388 |
| Ohio | Cincinnati | 3,636 | -4% | (133) | 3,503 |
| Oregon | Portland | 3,636 | 4% | 153 | 3,789 |
| Pennsylvania | Philadelphia | 3,636 | 15% | 537 | 4,173 |
| Pennsylvania | Wilkes-Barre | 3,636 | -5% | (164) | 3,472 |
| Rhode Island | Providence | 3,636 | 4% | 159 | 3,795 |
| South Carolina | Spartanburg | 3,636 | -14% | (519) | 3,117 |
| South Dakota | Rapid City | 3,636 | -9% | (333) | 3,303 |
| Tennessee | Knoxville | 3,636 | -10% | (381) | 3,255 |
| Texas | Houston | 3,636 | -12% | (419) | 3,217 |
| Utah | Salt Lake City | 3,636 | -5% | (186) | 3,450 |
| Vermont | Burlington | 3,636 | -3% | (124) | 3,512 |
| Virginia | Alexandria | 3,636 | 9% | 313 | 3,949 |
| Virginia | Lynchburg | 3,636 | -4% | (139) | 3,497 |
| Washington | Seattle | 3,636 | 7% | 247 | 3,883 |
| Washington | Spokane | 3,636 | -3% | (123) | 3,513 |
| West Virginia | Charleston | 3,636 | 0% | (11) | 3,625 |
| Wisconsin | Green Bay | 3,636 | -1% | (19) | 3,617 |
| Wyoming | Cheyenne | 3,636 | 2% | 72 | 3,708 |
| Puerto Rico | Cayey | N/A | N/A | N/A | N/A |

TABLE 4-2 – LOCATION-BASED COSTS FOR USC/CCS FACILITY (650,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 5,084 | 22% | 1,124 | 6,208 |
| Alaska | Fairbanks | 5,084 | 23% | 1,190 | 6,274 |
| Alabama | Huntsville | 5,084 | -10% | (489) | 4,595 |
| Arizona | Phoenix | 5,084 | -7% | (359) | 4,725 |
| Arkansas | Little Rock | 5,084 | -7% | (364) | 4,720 |
| California | Los Angeles | 5,084 | 12% | 609 | 5,693 |
| California | Redding | 5,084 | 7% | 332 | 5,416 |
| California | Bakersfield | 5,084 | 7% | 333 | 5,417 |
| California | Sacramento | 5,084 | 7% | 378 | 5,462 |
| California | San Francisco | 5,084 | 24% | 1,233 | 6,317 |
| Colorado | Denver | 5,084 | -8% | (397) | 4,687 |
| Connecticut | Hartford | 5,084 | 17% | 866 | 5,950 |
| Delaware | Dover | 5,084 | 15% | 743 | 5,827 |
| District of Columbia | Washington | 5,084 | 24% | 1,235 | 6,319 |
| Florida | Tallahassee | 5,084 | -9% | (444) | 4,640 |
| Florida | Tampa | 5,084 | -4% | (206) | 4,878 |
| Georgia | Atlanta | 5,084 | -10% | (487) | 4,597 |
| Hawaii | Honolulu | N/A | N/A | N/A | N/A |
| Idaho | Boise | 5,084 | -5% | (267) | 4,817 |
| Illinois | Chicago | 5,084 | 12% | 630 | 5,714 |
| Indiana | Indianapolis | 5,084 | -1% | (45) | 5,039 |
| Iowa | Davenport | 5,084 | -2% | (100) | 4,984 |
| Iowa | Waterloo | 5,084 | -6% | (290) | 4,794 |
| Kansas | Wichita | 5,084 | -7% | (364) | 4,720 |
| Kentucky | Louisville | 5,084 | -7% | (345) | 4,739 |
| Louisiana | New Orleans | 5,084 | -12% | (592) | 4,492 |
| Maine | Portland | 5,084 | -5% | (279) | 4,805 |
| Maryland | Baltimore | 5,084 | -1% | (33) | 5,051 |
| Massachusetts | Boston | 5,084 | 24% | 1,238 | 6,322 |
| Michigan | Detroit | 5,084 | 2% | 116 | 5,200 |
| Michigan | Grand Rapids | 5,084 | -3% | (177) | 4,907 |
| Minnesota | Saint Paul | 5,084 | 5% | 263 | 5,347 |
| Mississippi | Jackson | 5,084 | -7% | (380) | 4,704 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 5,084 | 2% | 83 | 5,167 |
| Missouri | Kansas City | 5,084 | 0% | (25) | 5,059 |
| Montana | Great Falls | 5,084 | -4% | (198) | 4,886 |
| Nebraska | Omaha | 5,084 | -4% | (206) | 4,878 |
| New Hampshire | Concord | 5,084 | -3% | (163) | 4,921 |
| New Jersey | Newark | 5,084 | 10% | 510 | 5,594 |
| New Mexico | Albuquerque | 5,084 | -5% | (245) | 4,839 |
| New York | New York | 5,084 | 30% | 1,543 | 6,627 |
| New York | Syracuse | 5,084 | -2% | (120) | 4,964 |
| Nevada | Las Vegas | 5,084 | 3% | 159 | 5,243 |
| North Carolina | Charlotte | 5,084 | -11% | (548) | 4,536 |
| North Dakota | Bismarck | 5,084 | -7% | (371) | 4,713 |
| Ohio | Cincinnati | 5,084 | -4% | (205) | 4,879 |
| Oregon | Portland | 5,084 | 3% | 146 | 5,230 |
| Pennsylvania | Philadelphia | 5,084 | 12% | 604 | 5,688 |
| Pennsylvania | Wilkes-Barre | 5,084 | -4% | (213) | 4,871 |
| Rhode Island | Providence | 5,084 | 3% | 137 | 5,221 |
| South Carolina | Spartanburg | 5,084 | -13% | (656) | 4,428 |
| South Dakota | Rapid City | 5,084 | -9% | (473) | 4,611 |
| Tennessee | Knoxville | 5,084 | -10% | (484) | 4,600 |
| Texas | Houston | 5,084 | -10% | (529) | 4,555 |
| Utah | Salt Lake City | 5,084 | -5% | (277) | 4,807 |
| Vermont | Burlington | 5,084 | -7% | (340) | 4,744 |
| Virginia | Alexandria | 5,084 | 5% | 254 | 5,338 |
| Virginia | Lynchburg | 5,084 | -5% | (239) | 4,845 |
| Washington | Seattle | 5,084 | 5% | 264 | 5,348 |
| Washington | Spokane | 5,084 | -3% | (160) | 4,924 |
| West Virginia | Charleston | 5,084 | -2% | (99) | 4,985 |
| Wisconsin | Green Bay | 5,084 | -1% | (58) | 5,026 |
| Wyoming | Cheyenne | 5,084 | -1% | (29) | 5,055 |
| Puerto Rico | Cayey | N/A | N/A | N/A | N/A |

TABLE 5-2 – LOCATION-BASED COSTS FOR CTNG FACILITY (300,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Alaska | Anchorage | 226 | 117% | 264 | 490 |
| Alaska | Fairbanks | 226 | 136% | 307 | 533 |
| Alabama | Huntsville | 226 | -13% | (30) | 196 |
| Arizona | Phoenix | 226 | -7% | (16) | 210 |
| Arkansas | Little Rock | 226 | -6% | (14) | 212 |
| California | Los Angeles | 226 | 73% | 164 | 390 |
| California | Redding | 226 | 17% | 39 | 265 |
| California | Bakersfield | 226 | 27% | 61 | 287 |
| California | Sacramento | 226 | 29% | 66 | 292 |
| California | San Francisco | 226 | 119% | 269 | 495 |
| Colorado | Denver | 226 | 7% | 15 | 241 |
| Connecticut | Hartford | 226 | 69% | 157 | 383 |
| Delaware | Dover | 226 | 69% | 155 | 381 |
| District of Columbia | Washington | 226 | 110% | 249 | 475 |
| Florida | Tallahassee | 226 | -12% | (26) | 200 |
| Florida | Tampa | 226 | -9% | (21) | 205 |
| Georgia | Atlanta | 226 | -1% | (3) | 223 |
| Hawaii | Honolulu | N/A | N/A | N/A | N/A |
| Idaho | Boise | 226 | -3% | (6) | 220 |
| Illinois | Chicago | 226 | 25% | 56 | 282 |
| Indiana | Indianapolis | 226 | 5% | 11 | 237 |
| Iowa | Davenport | 226 | 7% | 15 | 241 |
| Iowa | Waterloo | 226 | 0% | - | 226 |
| Kansas | Wichita | 226 | 0% | (1) | 225 |
| Kentucky | Louisville | 226 | -9% | (21) | 205 |
| Louisiana | New Orleans | 226 | 11% | 24 | 250 |
| Maine | Portland | 226 | 0% | (1) | 225 |
| Maryland | Baltimore | 226 | 56% | 126 | 352 |
| Massachusetts | Boston | 226 | 93% | 211 | 437 |
| Michigan | Detroit | 226 | 14% | 31 | 257 |
| Michigan | Grand Rapids | 226 | 3% | 7 | 233 |
| Minnesota | Saint Paul | 226 | 15% | 35 | 261 |
| Mississippi | Jackson | 226 | -8% | (19) | 207 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 226 | 12% | 28 | 254 |
| Missouri | Kansas City | 226 | 3% | 7 | 233 |
| Montana | Great Falls | 226 | 23% | 51 | 277 |
| Nebraska | Omaha | 226 | 4% | 9 | 235 |
| New Hampshire | Concord | 226 | 3% | 6 | 232 |
| New Jersey | Newark | 226 | 53% | 119 | 345 |
| New Mexico | Albuquerque | 226 | 10% | 23 | 249 |
| New York | New York | 226 | 167% | 378 | 604 |
| New York | Syracuse | 226 | 35% | 80 | 306 |
| Nevada | Las Vegas | 226 | 7% | 16 | 242 |
| North Carolina | Charlotte | 226 | -14% | (31) | 195 |
| North Dakota | Bismarck | 226 | -1% | (3) | 223 |
| Ohio | Cincinnati | 226 | 0% | - | 226 |
| Oregon | Portland | 226 | 10% | 23 | 249 |
| Pennsylvania | Philadelphia | 226 | 41% | 92 | 318 |
| Pennsylvania | Wilkes-Barre | 226 | 6% | 13 | 239 |
| Rhode Island | Providence | 226 | 50% | 114 | 340 |
| South Carolina | Spartanburg | 226 | -16% | (37) | 189 |
| South Dakota | Rapid City | 226 | -5% | (11) | 215 |
| Tennessee | Knoxville | 226 | -14% | (31) | 195 |
| Texas | Houston | 226 | -17% | (38) | 188 |
| Utah | Salt Lake City | 226 | 2% | 4 | 230 |
| Vermont | Burlington | 226 | 22% | 49 | 275 |
| Virginia | Alexandria | 226 | 39% | 88 | 314 |
| Virginia | Lynchburg | 226 | -9% | (20) | 206 |
| Washington | Seattle | 226 | 14% | 32 | 258 |
| Washington | Spokane | 226 | -1% | (3) | 223 |
| West Virginia | Charleston | 226 | 10% | 23 | 249 |
| Wisconsin | Green Bay | 226 | 3% | 6 | 232 |
| Wyoming | Cheyenne | 226 | 17% | 38 | 264 |
| Puerto Rico | Cayey | 226 | 29% | 66 | 292 |

TABLE 6-2 – LOCATION-BASED COSTS FOR GCBC FACILITY (300,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 4,620 | 25% | 1,138 | 5,758 |
| Alaska | Fairbanks | 4,620 | 27% | 1,246 | 5,866 |
| Alabama | Huntsville | 4,620 | -13% | (608) | 4,012 |
| Arizona | Phoenix | 4,620 | -10% | (450) | 4,170 |
| Arkansas | Little Rock | 4,620 | -9% | (424) | 4,196 |
| California | Los Angeles | 4,620 | 16% | 719 | 5,339 |
| California | Redding | 4,620 | 9% | 393 | 5,013 |
| California | Bakersfield | 4,620 | 7% | 334 | 4,954 |
| California | Sacramento | 4,620 | 9% | 406 | 5,026 |
| California | San Francisco | 4,620 | 31% | 1,445 | 6,065 |
| Colorado | Denver | 4,620 | -11% | (515) | 4,105 |
| Connecticut | Hartford | 4,620 | 21% | 956 | 5,576 |
| Delaware | Dover | 4,620 | 17% | 780 | 5,400 |
| District of Columbia | Washington | 4,620 | 21% | 991 | 5,611 |
| Florida | Tallahassee | 4,620 | -10% | (466) | 4,154 |
| Florida | Tampa | 4,620 | -8% | (362) | 4,258 |
| Georgia | Atlanta | 4,620 | -13% | (605) | 4,015 |
| Hawaii | Honolulu | N/A | N/A | N/A | N/A |
| Idaho | Boise | 4,620 | -6% | (285) | 4,335 |
| Illinois | Chicago | 4,620 | 17% | 769 | 5,389 |
| Indiana | Indianapolis | 4,620 | -5% | (232) | 4,388 |
| Iowa | Davenport | 4,620 | -2% | (85) | 4,535 |
| Iowa | Waterloo | 4,620 | -8% | (350) | 4,270 |
| Kansas | Wichita | 4,620 | -10% | (447) | 4,173 |
| Kentucky | Louisville | 4,620 | -10% | (449) | 4,171 |
| Louisiana | New Orleans | 4,620 | -16% | (732) | 3,888 |
| Maine | Portland | 4,620 | -9% | (409) | 4,211 |
| Maryland | Baltimore | 4,620 | -3% | (123) | 4,497 |
| Massachusetts | Boston | 4,620 | 26% | 1,219 | 5,839 |
| Michigan | Detroit | 4,620 | 2% | 114 | 4,734 |
| Michigan | Grand Rapids | 4,620 | -5% | (215) | 4,405 |
| Minnesota | Saint Paul | 4,620 | 7% | 317 | 4,937 |
| Mississippi | Jackson | 4,620 | -9% | (416) | 4,204 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 4,620 | 1% | 65 | 4,685 |
| Missouri | Kansas City | 4,620 | -1% | (48) | 4,572 |
| Montana | Great Falls | 4,620 | -6% | (260) | 4,360 |
| Nebraska | Omaha | 4,620 | -6% | (268) | 4,352 |
| New Hampshire | Concord | 4,620 | -2% | (72) | 4,548 |
| New Jersey | Newark | 4,620 | 17% | 774 | 5,394 |
| New Mexico | Albuquerque | 4,620 | -8% | (367) | 4,253 |
| New York | New York | 4,620 | 34% | 1,588 | 6,208 |
| New York | Syracuse | 4,620 | -1% | (32) | 4,588 |
| Nevada | Las Vegas | 4,620 | 2% | 104 | 4,724 |
| North Carolina | Charlotte | 4,620 | -16% | (717) | 3,903 |
| North Dakota | Bismarck | 4,620 | -9% | (400) | 4,220 |
| Ohio | Cincinnati | 4,620 | -7% | (306) | 4,314 |
| Oregon | Portland | 4,620 | 2% | 110 | 4,730 |
| Pennsylvania | Philadelphia | 4,620 | 9% | 424 | 5,044 |
| Pennsylvania | Wilkes-Barre | 4,620 | -6% | (288) | 4,332 |
| Rhode Island | Providence | 4,620 | 11% | 494 | 5,114 |
| South Carolina | Spartanburg | 4,620 | -18% | (829) | 3,791 |
| South Dakota | Rapid City | 4,620 | -12% | (538) | 4,082 |
| Tennessee | Knoxville | 4,620 | -14% | (627) | 3,993 |
| Texas | Houston | 4,620 | -15% | (676) | 3,944 |
| Utah | Salt Lake City | 4,620 | -8% | (358) | 4,262 |
| Vermont | Burlington | 4,620 | -5% | (223) | 4,397 |
| Virginia | Alexandria | 4,620 | 5% | 254 | 4,874 |
| Virginia | Lynchburg | 4,620 | -7% | (315) | 4,305 |
| Washington | Seattle | 4,620 | 6% | 260 | 4,880 |
| Washington | Spokane | 4,620 | -5% | (221) | 4,399 |
| West Virginia | Charleston | 4,620 | -1% | (29) | 4,591 |
| Wisconsin | Green Bay | 4,620 | -2% | (111) | 4,509 |
| Wyoming | Cheyenne | 4,620 | -10% | (441) | 4,179 |
| Puerto Rico | Cayey | 4,620 | -8% | (348) | 4,272 |

TABLE 7-2 – LOCATION-BASED COSTS FOR CTCB FACILITY (300,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Alaska | Anchorage | 537 | 66% | 352 | 889 |
| Alaska | Fairbanks | 537 | 74% | 400 | 937 |
| Alabama | Huntsville | 537 | -14% | (74) | 463 |
| Arizona | Phoenix | 537 | -9% | (49) | 488 |
| Arkansas | Little Rock | 537 | -9% | (46) | 491 |
| California | Los Angeles | 537 | 62% | 331 | 868 |
| California | Redding | 537 | 35% | 187 | 724 |
| California | Bakersfield | 537 | 38% | 202 | 739 |
| California | Sacramento | 537 | 35% | 188 | 725 |
| California | San Francisco | 537 | 97% | 521 | 1,058 |
| Colorado | Denver | 537 | -12% | (62) | 475 |
| Connecticut | Hartford | 537 | 58% | 309 | 846 |
| Delaware | Dover | 537 | 52% | 281 | 818 |
| District of Columbia | Washington | 537 | 72% | 388 | 925 |
| Florida | Tallahassee | 537 | -11% | (60) | 477 |
| Florida | Tampa | 537 | -9% | (47) | 490 |
| Georgia | Atlanta | 537 | -14% | (74) | 463 |
| Hawaii | Honolulu | N/A | N/A | N/A | N/A |
| Idaho | Boise | 537 | -5% | (28) | 509 |
| Illinois | Chicago | 537 | 40% | 213 | 750 |
| Indiana | Indianapolis | 537 | -5% | (26) | 511 |
| Iowa | Davenport | 537 | -2% | (11) | 526 |
| Iowa | Waterloo | 537 | -8% | (45) | 492 |
| Kansas | Wichita | 537 | -10% | (53) | 484 |
| Kentucky | Louisville | 537 | -10% | (54) | 483 |
| Louisiana | New Orleans | 537 | -18% | (95) | 442 |
| Maine | Portland | 537 | 1% | 4 | 541 |
| Maryland | Baltimore | 537 | 16% | 85 | 622 |
| Massachusetts | Boston | 537 | 88% | 473 | 1,010 |
| Michigan | Detroit | 537 | 4% | 19 | 556 |
| Michigan | Grand Rapids | 537 | -5% | (28) | 509 |
| Minnesota | Saint Paul | 537 | 14% | 75 | 612 |
| Mississippi | Jackson | 537 | -9% | (49) | 488 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 537 | 6% | 31 | 568 |
| Missouri | Kansas City | 537 | 1% | 3 | 540 |
| Montana | Great Falls | 537 | 2% | 9 | 546 |
| Nebraska | Omaha | 537 | -6% | (30) | 507 |
| New Hampshire | Concord | 537 | 0% | - | 537 |
| New Jersey | Newark | 537 | 16% | 88 | 625 |
| New Mexico | Albuquerque | 537 | -8% | (43) | 494 |
| New York | New York | 537 | 37% | 198 | 735 |
| New York | Syracuse | 537 | -3% | (16) | 521 |
| Nevada | Las Vegas | 537 | 4% | 23 | 560 |
| North Carolina | Charlotte | 537 | -16% | (84) | 453 |
| North Dakota | Bismarck | 537 | -10% | (52) | 485 |
| Ohio | Cincinnati | 537 | -10% | (52) | 485 |
| Oregon | Portland | 537 | 28% | 150 | 687 |
| Pennsylvania | Philadelphia | 537 | 12% | 64 | 601 |
| Pennsylvania | Wilkes-Barre | 537 | -5% | (28) | 509 |
| Rhode Island | Providence | 537 | 7% | 39 | 576 |
| South Carolina | Spartanburg | 537 | -18% | (98) | 439 |
| South Dakota | Rapid City | 537 | -13% | (70) | 467 |
| Tennessee | Knoxville | 537 | -14% | (77) | 460 |
| Texas | Houston | 537 | -16% | (88) | 449 |
| Utah | Salt Lake City | 537 | -4% | (24) | 513 |
| Vermont | Burlington | 537 | -4% | (20) | 517 |
| Virginia | Alexandria | 537 | 46% | 247 | 784 |
| Virginia | Lynchburg | 537 | -10% | (53) | 484 |
| Washington | Seattle | 537 | 20% | 105 | 642 |
| Washington | Spokane | 537 | -4% | (20) | 517 |
| West Virginia | Charleston | 537 | 0% | 1 | 538 |
| Wisconsin | Green Bay | 537 | -6% | (31) | 506 |
| Wyoming | Cheyenne | 537 | -10% | (53) | 484 |
| Puerto Rico | Cayey | 537 | 6% | 34 | 571 |

**TABLE 8-2 – LOCATION-BASED COSTS FOR NGCC FACILITY (702,000 KW)
(JANUARY 1, 2016 DOLLARS)**

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Alaska | Anchorage | 978 | 30% | 296 | 1,274 |
| Alaska | Fairbanks | 978 | 35% | 346 | 1,324 |
| Alabama | Huntsville | 978 | -11% | (112) | 866 |
| Arizona | Phoenix | 978 | 1% | 8 | 986 |
| Arkansas | Little Rock | 978 | -9% | (84) | 894 |
| California | Los Angeles | 978 | 28% | 270 | 1,248 |
| California | Redding | 978 | 15% | 148 | 1,126 |
| California | Bakersfield | 978 | 17% | 163 | 1,141 |
| California | Sacramento | 978 | 19% | 183 | 1,161 |
| California | San Francisco | 978 | 43% | 423 | 1,401 |
| Colorado | Denver | 978 | 1% | 10 | 988 |
| Connecticut | Hartford | 978 | 28% | 271 | 1,249 |
| Delaware | Dover | 978 | 26% | 256 | 1,234 |
| District of Columbia | Washington | 978 | 34% | 328 | 1,306 |
| Florida | Tallahassee | 978 | -11% | (106) | 872 |
| Florida | Tampa | 978 | -6% | (58) | 920 |
| Georgia | Atlanta | 978 | -9% | (86) | 892 |
| Hawaii | Honolulu | N/A | N/A | N/A | N/A |
| Idaho | Boise | 978 | -5% | (48) | 930 |
| Illinois | Chicago | 978 | 12% | 122 | 1,100 |
| Indiana | Indianapolis | 978 | -1% | (13) | 965 |
| Iowa | Davenport | 978 | 0% | (1) | 977 |
| Iowa | Waterloo | 978 | -4% | (40) | 938 |
| Kansas | Wichita | 978 | -5% | (52) | 926 |
| Kentucky | Louisville | 978 | -7% | (67) | 911 |
| Louisiana | New Orleans | 978 | -14% | (137) | 841 |
| Maine | Portland | 978 | -6% | (58) | 920 |
| Maryland | Baltimore | 978 | 18% | 177 | 1,155 |
| Massachusetts | Boston | 978 | 37% | 360 | 1,338 |
| Michigan | Detroit | 978 | 5% | 46 | 1,024 |
| Michigan | Grand Rapids | 978 | -2% | (17) | 961 |
| Minnesota | Saint Paul | 978 | 7% | 65 | 1,043 |
| Mississippi | Jackson | 978 | -9% | (90) | 888 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 978 | 3% | 32 | 1,010 |
| Missouri | Kansas City | 978 | 0% | 1 | 979 |
| Montana | Great Falls | 978 | 2% | 16 | 994 |
| Nebraska | Omaha | 978 | -2% | (20) | 958 |
| New Hampshire | Concord | 978 | 7% | 64 | 1,042 |
| New Jersey | New ark | 978 | 19% | 185 | 1,163 |
| New Mexico | Albuquerque | 978 | -3% | (32) | 946 |
| New York | New York | 978 | 63% | 619 | 1,597 |
| New York | Syracuse | 978 | 16% | 154 | 1,132 |
| Nevada | Las Vegas | 978 | 3% | 25 | 1,003 |
| North Carolina | Charlotte | 978 | -11% | (106) | 872 |
| North Dakota | Bismarck | 978 | -6% | (56) | 922 |
| Ohio | Cincinnati | 978 | -5% | (46) | 932 |
| Oregon | Portland | 978 | 11% | 110 | 1,088 |
| Pennsylvania | Philadelphia | 978 | 23% | 226 | 1,204 |
| Pennsylvania | Wilkes-Barre | 978 | -2% | (18) | 960 |
| Rhode Island | Providence | 978 | 22% | 216 | 1,194 |
| South Carolina | Spartanburg | 978 | -15% | (143) | 835 |
| South Dakota | Rapid City | 978 | -8% | (77) | 901 |
| Tennessee | Knoxville | 978 | -10% | (96) | 882 |
| Texas | Houston | 978 | -11% | (108) | 870 |
| Utah | Salt Lake City | 978 | -4% | (41) | 937 |
| Vermont | Burlington | 978 | -1% | (11) | 967 |
| Virginia | Alexandria | 978 | 16% | 157 | 1,135 |
| Virginia | Lynchburg | 978 | -7% | (72) | 906 |
| Washington | Seattle | 978 | 4% | 43 | 1,021 |
| Washington | Spokane | 978 | -3% | (26) | 952 |
| West Virginia | Charleston | 978 | 0% | 2 | 980 |
| Wisconsin | Green Bay | 978 | -2% | (19) | 959 |
| Wyoming | Cheyenne | 978 | 5% | 52 | 1,030 |
| Puerto Rico | Cayey | 978 | 9% | 92 | 1,070 |

TABLE 9-2 – LOCATION-BASED COSTS FOR AG-NGCC FACILITY (429,000 KW)**(JANUARY 1, 2016 DOLLARS)**

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 1,104 | 28% | 314 | 1,418 |
| Alaska | Fairbanks | 1,104 | 32% | 349 | 1,453 |
| Alabama | Huntsville | 1,104 | -8% | (93) | 1,011 |
| Arizona | Phoenix | 1,104 | 5% | 52 | 1,156 |
| Arkansas | Little Rock | 1,104 | -6% | (61) | 1,043 |
| California | Los Angeles | 1,104 | 29% | 318 | 1,422 |
| California | Redding | 1,104 | 17% | 187 | 1,291 |
| California | Bakersfield | 1,104 | 19% | 215 | 1,319 |
| California | Sacramento | 1,104 | 19% | 215 | 1,319 |
| California | San Francisco | 1,104 | 41% | 458 | 1,562 |
| Colorado | Denver | 1,104 | 2% | 17 | 1,121 |
| Connecticut | Hartford | 1,104 | 27% | 302 | 1,406 |
| Delaware | Dover | 1,104 | 26% | 284 | 1,388 |
| District of Columbia | Washington | 1,104 | 33% | 365 | 1,469 |
| Florida | Tallahassee | 1,104 | -7% | (81) | 1,023 |
| Florida | Tampa | 1,104 | -6% | (67) | 1,037 |
| Georgia | Atlanta | 1,104 | -6% | (67) | 1,037 |
| Hawaii | Honolulu | 1,104 | 44% | 486 | 1,590 |
| Idaho | Boise | 1,104 | -2% | (24) | 1,080 |
| Illinois | Chicago | 1,104 | 9% | 104 | 1,208 |
| Indiana | Indianapolis | 1,104 | 0% | (4) | 1,100 |
| Iowa | Davenport | 1,104 | 1% | 8 | 1,112 |
| Iowa | Waterloo | 1,104 | -2% | (27) | 1,077 |
| Kansas | Wichita | 1,104 | -3% | (32) | 1,072 |
| Kentucky | Louisville | 1,104 | 2% | 26 | 1,130 |
| Louisiana | New Orleans | 1,104 | -11% | (116) | 988 |
| Maine | Portland | 1,104 | -3% | (38) | 1,066 |
| Maryland | Baltimore | 1,104 | 20% | 216 | 1,320 |
| Massachusetts | Boston | 1,104 | 34% | 376 | 1,480 |
| Michigan | Detroit | 1,104 | 4% | 42 | 1,146 |
| Michigan | Grand Rapids | 1,104 | -1% | (9) | 1,095 |
| Minnesota | Saint Paul | 1,104 | 5% | 56 | 1,160 |
| Mississippi | Jackson | 1,104 | -6% | (67) | 1,037 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 1,104 | 4% | 44 | 1,148 |
| Missouri | Kansas City | 1,104 | 1% | 8 | 1,112 |
| Montana | Great Falls | 1,104 | 10% | 111 | 1,215 |
| Nebraska | Omaha | 1,104 | -1% | (9) | 1,095 |
| New Hampshire | Concord | 1,104 | 11% | 122 | 1,226 |
| New Jersey | Newark | 1,104 | 15% | 170 | 1,274 |
| New Mexico | Albuquerque | 1,104 | -2% | (22) | 1,082 |
| New York | New York | 1,104 | 55% | 610 | 1,714 |
| New York | Syracuse | 1,104 | 17% | 187 | 1,291 |
| Nevada | Las Vegas | 1,104 | 8% | 93 | 1,197 |
| North Carolina | Charlotte | 1,104 | -7% | (81) | 1,023 |
| North Dakota | Bismarck | 1,104 | -3% | (33) | 1,071 |
| Ohio | Cincinnati | 1,104 | -3% | (31) | 1,073 |
| Oregon | Portland | 1,104 | 14% | 150 | 1,254 |
| Pennsylvania | Philadelphia | 1,104 | 22% | 246 | 1,350 |
| Pennsylvania | Wilkes-Barre | 1,104 | 0% | (4) | 1,100 |
| Rhode Island | Providence | 1,104 | 23% | 253 | 1,357 |
| South Carolina | Spartanburg | 1,104 | -10% | (115) | 989 |
| South Dakota | Rapid City | 1,104 | -5% | (52) | 1,052 |
| Tennessee | Knoxville | 1,104 | -7% | (76) | 1,028 |
| Texas | Houston | 1,104 | -8% | (89) | 1,015 |
| Utah | Salt Lake City | 1,104 | -1% | (12) | 1,092 |
| Vermont | Burlington | 1,104 | 3% | 37 | 1,141 |
| Virginia | Alexandria | 1,104 | 18% | 197 | 1,301 |
| Virginia | Lynchburg | 1,104 | -5% | (52) | 1,052 |
| Washington | Seattle | 1,104 | 5% | 53 | 1,157 |
| Washington | Spokane | 1,104 | -1% | (15) | 1,089 |
| West Virginia | Charleston | 1,104 | 2% | 23 | 1,127 |
| Wisconsin | Green Bay | 1,104 | -1% | (12) | 1,092 |
| Wyoming | Cheyenne | 1,104 | 7% | 72 | 1,176 |
| Puerto Rico | Cayey | 1,104 | 13% | 143 | 1,247 |

**TABLE 10-2 – LOCATION-BASED COSTS FOR CT FACILITY (100,000 KW)
(JANUARY 1, 2016 DOLLARS)**

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 1,101 | 26% | 286 | 1,387 |
| Alaska | Fairbanks | 1,101 | 30% | 334 | 1,435 |
| Alabama | Huntsville | 1,101 | -7% | (73) | 1,028 |
| Arizona | Phoenix | 1,101 | -4% | (48) | 1,053 |
| Arkansas | Little Rock | 1,101 | -4% | (45) | 1,056 |
| California | Los Angeles | 1,101 | 16% | 175 | 1,276 |
| California | Redding | 1,101 | 5% | 56 | 1,157 |
| California | Bakersfield | 1,101 | 6% | 71 | 1,172 |
| California | Sacramento | 1,101 | 8% | 84 | 1,185 |
| California | San Francisco | 1,101 | 28% | 312 | 1,413 |
| Colorado | Denver | 1,101 | -2% | (22) | 1,079 |
| Connecticut | Hartford | 1,101 | 16% | 178 | 1,279 |
| Delaware | Dover | 1,101 | 15% | 164 | 1,265 |
| District of Columbia | Washington | 1,101 | 22% | 245 | 1,346 |
| Florida | Tallahassee | 1,101 | -5% | (60) | 1,041 |
| Florida | Tampa | 1,101 | -4% | (46) | 1,055 |
| Georgia | Atlanta | 1,101 | -4% | (47) | 1,054 |
| Hawaii | Honolulu | 1,101 | 45% | 499 | 1,600 |
| Idaho | Boise | 1,101 | -2% | (27) | 1,074 |
| Illinois | Chicago | 1,101 | 9% | 101 | 1,202 |
| Indiana | Indianapolis | 1,101 | -1% | (6) | 1,095 |
| Iowa | Davenport | 1,101 | 1% | 9 | 1,110 |
| Iowa | Waterloo | 1,101 | -2% | (25) | 1,076 |
| Kansas | Wichita | 1,101 | -3% | (33) | 1,068 |
| Kentucky | Louisville | 1,101 | -5% | (53) | 1,048 |
| Louisiana | New Orleans | 1,101 | -8% | (93) | 1,008 |
| Maine | Portland | 1,101 | -4% | (40) | 1,061 |
| Maryland | Baltimore | 1,101 | 9% | 99 | 1,200 |
| Massachusetts | Boston | 1,101 | 23% | 251 | 1,352 |
| Michigan | Detroit | 1,101 | 4% | 39 | 1,140 |
| Michigan | Grand Rapids | 1,101 | -1% | (8) | 1,093 |
| Minnesota | Saint Paul | 1,101 | 5% | 55 | 1,156 |
| Mississippi | Jackson | 1,101 | -4% | (49) | 1,052 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 1,101 | 3% | 31 | 1,132 |
| Missouri | Kansas City | 1,101 | 0% | 3 | 1,104 |
| Montana | Great Falls | 1,101 | 1% | 16 | 1,117 |
| Nebraska | Omaha | 1,101 | -1% | (10) | 1,091 |
| New Hampshire | Concord | 1,101 | 0% | - | 1,101 |
| New Jersey | Newark | 1,101 | 15% | 165 | 1,266 |
| New Mexico | Albuquerque | 1,101 | 0% | (3) | 1,098 |
| New York | New York | 1,101 | 44% | 481 | 1,582 |
| New York | Syracuse | 1,101 | 6% | 68 | 1,169 |
| Nevada | Las Vegas | 1,101 | 8% | 87 | 1,188 |
| North Carolina | Charlotte | 1,101 | -7% | (82) | 1,019 |
| North Dakota | Bismarck | 1,101 | -3% | (32) | 1,069 |
| Ohio | Cincinnati | 1,101 | -3% | (32) | 1,069 |
| Oregon | Portland | 1,101 | 2% | 20 | 1,121 |
| Pennsylvania | Philadelphia | 1,101 | 11% | 122 | 1,223 |
| Pennsylvania | Wilkes-Barre | 1,101 | -1% | (8) | 1,093 |
| Rhode Island | Providence | 1,101 | 12% | 130 | 1,231 |
| South Carolina | Spartanburg | 1,101 | -9% | (97) | 1,004 |
| South Dakota | Rapid City | 1,101 | -4% | (49) | 1,052 |
| Tennessee | Knoxville | 1,101 | -7% | (75) | 1,026 |
| Texas | Houston | 1,101 | -8% | (86) | 1,015 |
| Utah | Salt Lake City | 1,101 | -2% | (23) | 1,078 |
| Vermont | Burlington | 1,101 | 3% | 33 | 1,134 |
| Virginia | Alexandria | 1,101 | 7% | 78 | 1,179 |
| Virginia | Lynchburg | 1,101 | -5% | (52) | 1,049 |
| Washington | Seattle | 1,101 | 4% | 39 | 1,140 |
| Washington | Spokane | 1,101 | -2% | (19) | 1,082 |
| West Virginia | Charleston | 1,101 | 2% | 20 | 1,121 |
| Wisconsin | Green Bay | 1,101 | -1% | (11) | 1,090 |
| Wyoming | Cheyenne | 1,101 | 7% | 72 | 1,173 |
| Puerto Rico | Cayey | 1,101 | 3% | 35 | 1,136 |

TABLE 11-2 – LOCATION-BASED COSTS FOR ACT FACILITY (237,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 678 | 40% | 268 | 946 |
| Alaska | Fairbanks | 678 | 46% | 311 | 989 |
| Alabama | Huntsville | 678 | -5% | (36) | 642 |
| Arizona | Phoenix | 678 | -3% | (21) | 657 |
| Arkansas | Little Rock | 678 | -3% | (19) | 659 |
| California | Los Angeles | 678 | 24% | 166 | 844 |
| California | Redding | 678 | 6% | 42 | 720 |
| California | Bakersfield | 678 | 9% | 62 | 740 |
| California | Sacramento | 678 | 10% | 69 | 747 |
| California | San Francisco | 678 | 41% | 275 | 953 |
| Colorado | Denver | 678 | 1% | 9 | 687 |
| Connecticut | Hartford | 678 | 24% | 160 | 838 |
| Delaware | Dover | 678 | 23% | 157 | 835 |
| District of Columbia | Washington | 678 | 37% | 248 | 926 |
| Florida | Tallahassee | 678 | -5% | (32) | 646 |
| Florida | Tampa | 678 | -4% | (25) | 653 |
| Georgia | Atlanta | 678 | -1% | (10) | 668 |
| Hawaii | Honolulu | 678 | 71% | 483 | 1,161 |
| Idaho | Boise | 678 | -1% | (10) | 668 |
| Illinois | Chicago | 678 | 9% | 63 | 741 |
| Indiana | Indianapolis | 678 | 1% | 9 | 687 |
| Iowa | Davenport | 678 | 2% | 14 | 692 |
| Iowa | Waterloo | 678 | -1% | (4) | 674 |
| Kansas | Wichita | 678 | -1% | (6) | 672 |
| Kentucky | Louisville | 678 | -4% | (26) | 652 |
| Louisiana | New Orleans | 678 | -7% | (50) | 628 |
| Maine | Portland | 678 | -1% | (7) | 671 |
| Maryland | Baltimore | 678 | 18% | 122 | 800 |
| Massachusetts | Boston | 678 | 32% | 217 | 895 |
| Michigan | Detroit | 678 | 5% | 32 | 710 |
| Michigan | Grand Rapids | 678 | 1% | 5 | 683 |
| Minnesota | Saint Paul | 678 | 6% | 38 | 716 |
| Mississippi | Jackson | 678 | -3% | (23) | 655 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 678 | 4% | 29 | 707 |
| Missouri | Kansas City | 678 | 1% | 6 | 684 |
| Montana | Great Falls | 678 | 7% | 48 | 726 |
| Nebraska | Omaha | 678 | 1% | 6 | 684 |
| New Hampshire | Concord | 678 | 1% | 5 | 683 |
| New Jersey | Newark | 678 | 19% | 126 | 804 |
| New Mexico | Albuquerque | 678 | 3% | 19 | 697 |
| New York | New York | 678 | 58% | 394 | 1,072 |
| New York | Syracuse | 678 | 12% | 78 | 756 |
| Nevada | Las Vegas | 678 | 12% | 82 | 760 |
| North Carolina | Charlotte | 678 | -6% | (39) | 639 |
| North Dakota | Bismarck | 678 | -1% | (8) | 670 |
| Ohio | Cincinnati | 678 | -1% | (5) | 673 |
| Oregon | Portland | 678 | 3% | 23 | 701 |
| Pennsylvania | Philadelphia | 678 | 14% | 97 | 775 |
| Pennsylvania | Wilkes-Barre | 678 | 1% | 10 | 688 |
| Rhode Island | Providence | 678 | 17% | 117 | 795 |
| South Carolina | Spartanburg | 678 | -7% | (46) | 632 |
| South Dakota | Rapid City | 678 | -3% | (17) | 661 |
| Tennessee | Knoxville | 678 | -6% | (38) | 640 |
| Texas | Houston | 678 | -7% | (46) | 632 |
| Utah | Salt Lake City | 678 | 0% | - | 678 |
| Vermont | Burlington | 678 | 7% | 47 | 725 |
| Virginia | Alexandria | 678 | 13% | 87 | 765 |
| Virginia | Lynchburg | 678 | -4% | (25) | 653 |
| Washington | Seattle | 678 | 5% | 33 | 711 |
| Washington | Spokane | 678 | -1% | (5) | 673 |
| West Virginia | Charleston | 678 | 3% | 22 | 700 |
| Wisconsin | Green Bay | 678 | 0% | 3 | 681 |
| Wyoming | Cheyenne | 678 | 43% | 293 | 971 |
| Puerto Rico | Cayey | 678 | 9% | 61 | 739 |

**TABLE 12-2 – LOCATION-BASED COSTS FOR AN FACILITY (2,234,000 KW)
(JANUARY 1, 2016 DOLLARS)**

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Alaska | Anchorage | 5,945 | 13% | 787 | 6,732 |
| Alaska | Fairbanks | 5,945 | 13% | 799 | 6,744 |
| Alabama | Huntsville | 5,945 | -4% | (227) | 5,718 |
| Arizona | Phoenix | 5,945 | -3% | (156) | 5,789 |
| Arkansas | Little Rock | 5,945 | -3% | (158) | 5,787 |
| California | Los Angeles | 5,945 | 8% | 470 | 6,415 |
| California | Redding | 5,945 | 5% | 278 | 6,223 |
| California | Bakersfield | 5,945 | 6% | 332 | 6,277 |
| California | Sacramento | 5,945 | 5% | 299 | 6,244 |
| California | San Francisco | 5,945 | 17% | 1,029 | 6,974 |
| Colorado | Denver | 5,945 | -3% | (173) | 5,772 |
| Connecticut | Hartford | 5,945 | 13% | 772 | 6,717 |
| Delaware | Dover | 5,945 | 12% | 704 | 6,649 |
| District of Columbia | Washington | 5,945 | 22% | 1,281 | 7,226 |
| Florida | Tallahassee | 5,945 | -4% | (216) | 5,729 |
| Florida | Tampa | 5,945 | -2% | (106) | 5,839 |
| Georgia | Atlanta | 5,945 | -4% | (226) | 5,719 |
| Hawaii | Honolulu | N/A | N/A | N/A | N/A |
| Idaho | Boise | 5,945 | -2% | (102) | 5,843 |
| Illinois | Chicago | 5,945 | 6% | 362 | 6,307 |
| Indiana | Indianapolis | 5,945 | 1% | 59 | 6,004 |
| Iowa | Davenport | 5,945 | -1% | (46) | 5,899 |
| Iowa | Waterloo | 5,945 | -2% | (134) | 5,811 |
| Kansas | Wichita | 5,945 | -3% | (158) | 5,787 |
| Kentucky | Louisville | 5,945 | -3% | (149) | 5,796 |
| Louisiana | New Orleans | 5,945 | -5% | (285) | 5,660 |
| Maine | Portland | 5,945 | -1% | (38) | 5,907 |
| Maryland | Baltimore | 5,945 | 2% | 135 | 6,080 |
| Massachusetts | Boston | 5,945 | 15% | 884 | 6,829 |
| Michigan | Detroit | 5,945 | 1% | 65 | 6,010 |
| Michigan | Grand Rapids | 5,945 | -1% | (82) | 5,863 |
| Minnesota | Saint Paul | 5,945 | 2% | 143 | 6,088 |
| Mississippi | Jackson | 5,945 | -3% | (176) | 5,769 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 5,945 | 2% | 92 | 6,037 |
| Missouri | Kansas City | 5,945 | 0% | 10 | 5,955 |
| Montana | Great Falls | 5,945 | -1% | (88) | 5,857 |
| Nebraska | Omaha | 5,945 | -1% | (85) | 5,860 |
| New Hampshire | Concord | 5,945 | -1% | (54) | 5,891 |
| New Jersey | Newark | 5,945 | 4% | 248 | 6,193 |
| New Mexico | Albuquerque | 5,945 | -2% | (93) | 5,852 |
| New York | New York | 5,945 | 9% | 557 | 6,502 |
| New York | Syracuse | 5,945 | 6% | 345 | 6,290 |
| Nevada | Las Vegas | 5,945 | 2% | 130 | 6,075 |
| North Carolina | Charlotte | 5,945 | -4% | (233) | 5,712 |
| North Dakota | Bismarck | 5,945 | -3% | (172) | 5,773 |
| Ohio | Cincinnati | 5,945 | 0% | (15) | 5,930 |
| Oregon | Portland | 5,945 | 3% | 191 | 6,136 |
| Pennsylvania | Philadelphia | 5,945 | 3% | 182 | 6,127 |
| Pennsylvania | Wilkes-Barre | 5,945 | -1% | (77) | 5,868 |
| Rhode Island | Providence | 5,945 | 1% | 85 | 6,030 |
| South Carolina | Spartanburg | 5,945 | -5% | (293) | 5,652 |
| South Dakota | Rapid City | 5,945 | -4% | (220) | 5,725 |
| Tennessee | Knoxville | 5,945 | -4% | (214) | 5,731 |
| Texas | Houston | 5,945 | -4% | (245) | 5,700 |
| Utah | Salt Lake City | 5,945 | -1% | (75) | 5,870 |
| Vermont | Burlington | 5,945 | -2% | (136) | 5,809 |
| Virginia | Alexandria | 5,945 | 6% | 338 | 6,283 |
| Virginia | Lynchburg | 5,945 | -1% | (31) | 5,914 |
| Washington | Seattle | 5,945 | 4% | 246 | 6,191 |
| Washington | Spokane | 5,945 | -1% | (52) | 5,893 |
| West Virginia | Charleston | 5,945 | -1% | (35) | 5,910 |
| Wisconsin | Green Bay | 5,945 | 1% | 43 | 5,988 |
| Wyoming | Cheyenne | 5,945 | 3% | 178 | 6,123 |
| Puerto Rico | Cayey | N/A | N/A | N/A | N/A |

TABLE 13-2– LOCATION-BASED COSTS FOR BBFB FACILITY (50,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 4,985 | 19% | 956 | 5,941 |
| Alaska | Fairbanks | 4,985 | 22% | 1,101 | 6,086 |
| Alabama | Huntsville | 4,985 | -15% | (729) | 4,256 |
| Arizona | Phoenix | 4,985 | -10% | (523) | 4,462 |
| Arkansas | Little Rock | 4,985 | -10% | (512) | 4,473 |
| California | Los Angeles | 4,985 | 10% | 510 | 5,495 |
| California | Redding | 4,985 | 9% | 447 | 5,432 |
| California | Bakersfield | 4,985 | 8% | 386 | 5,371 |
| California | Sacramento | 4,985 | 9% | 461 | 5,446 |
| California | San Francisco | 4,985 | 29% | 1,445 | 6,430 |
| Colorado | Denver | 4,985 | -12% | (601) | 4,384 |
| Connecticut | Hartford | 4,985 | 20% | 1,012 | 5,997 |
| Delaware | Dover | 4,985 | 16% | 804 | 5,789 |
| District of Columbia | Washington | 4,985 | 25% | 1,244 | 6,229 |
| Florida | Tallahassee | 4,985 | -11% | (565) | 4,420 |
| Florida | Tampa | 4,985 | -9% | (444) | 4,541 |
| Georgia | Atlanta | 4,985 | -15% | (726) | 4,259 |
| Hawaii | Honolulu | 4,985 | 46% | 2,318 | 7,303 |
| Idaho | Boise | 4,985 | -7% | (331) | 4,654 |
| Illinois | Chicago | 4,985 | 18% | 877 | 5,862 |
| Indiana | Indianapolis | 4,985 | -3% | (140) | 4,845 |
| Iowa | Davenport | 4,985 | -2% | (100) | 4,885 |
| Iowa | Waterloo | 4,985 | -8% | (410) | 4,575 |
| Kansas | Wichita | 4,985 | -10% | (521) | 4,464 |
| Kentucky | Louisville | 4,985 | -10% | (523) | 4,462 |
| Louisiana | New Orleans | 4,985 | -18% | (876) | 4,109 |
| Maine | Portland | 4,985 | -10% | (497) | 4,488 |
| Maryland | Baltimore | 4,985 | -4% | (186) | 4,799 |
| Massachusetts | Boston | 4,985 | 26% | 1,319 | 6,304 |
| Michigan | Detroit | 4,985 | 3% | 136 | 5,121 |
| Michigan | Grand Rapids | 4,985 | -5% | (251) | 4,734 |
| Minnesota | Saint Paul | 4,985 | 7% | 365 | 5,350 |
| Mississippi | Jackson | 4,985 | -10% | (504) | 4,481 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 4,985 | 2% | 85 | 5,070 |
| Missouri | Kansas City | 4,985 | -1% | (53) | 4,932 |
| Montana | Great Falls | 4,985 | -6% | (307) | 4,678 |
| Nebraska | Omaha | 4,985 | -6% | (312) | 4,673 |
| New Hampshire | Concord | 4,985 | -2% | (81) | 4,904 |
| New Jersey | Newark | 4,985 | 15% | 755 | 5,740 |
| New Mexico | Albuquerque | 4,985 | -9% | (427) | 4,558 |
| New York | New York | 4,985 | 42% | 2,099 | 7,084 |
| New York | Syracuse | 4,985 | -4% | (187) | 4,798 |
| Nevada | Las Vegas | 4,985 | 3% | 125 | 5,110 |
| North Carolina | Charlotte | 4,985 | -17% | (836) | 4,149 |
| North Dakota | Bismarck | 4,985 | -9% | (468) | 4,517 |
| Ohio | Cincinnati | 4,985 | -8% | (379) | 4,606 |
| Oregon | Portland | 4,985 | 2% | 115 | 5,100 |
| Pennsylvania | Philadelphia | 4,985 | 10% | 500 | 5,485 |
| Pennsylvania | Wilkes-Barre | 4,985 | -7% | (333) | 4,652 |
| Rhode Island | Providence | 4,985 | 6% | 278 | 5,263 |
| South Carolina | Spartanburg | 4,985 | -20% | (986) | 3,999 |
| South Dakota | Rapid City | 4,985 | -13% | (630) | 4,355 |
| Tennessee | Knoxville | 4,985 | -15% | (732) | 4,253 |
| Texas | Houston | 4,985 | -16% | (791) | 4,194 |
| Utah | Salt Lake City | 4,985 | -8% | (410) | 4,575 |
| Vermont | Burlington | 4,985 | -5% | (257) | 4,728 |
| Virginia | Alexandria | 4,985 | 5% | 233 | 5,218 |
| Virginia | Lynchburg | 4,985 | -8% | (389) | 4,596 |
| Washington | Seattle | 4,985 | 6% | 291 | 5,276 |
| Washington | Spokane | 4,985 | -5% | (256) | 4,729 |
| West Virginia | Charleston | 4,985 | -1% | (33) | 4,952 |
| Wisconsin | Green Bay | 4,985 | -3% | (152) | 4,833 |
| Wyoming | Cheyenne | 4,985 | -10% | (515) | 4,470 |
| Puerto Rico | Cayey | 4,985 | -3% | (169) | 4,816 |

TABLE 14-2 – LOCATION-BASED COSTS FOR WN FACILITY (100,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 1,877 | 30% | 559 | 2,436 |
| Alaska | Fairbanks | 1,877 | 56% | 1,042 | 2,919 |
| Alabama | Huntsville | 1,877 | -5% | (95) | 1,782 |
| Arizona | Phoenix | 1,877 | -3% | (59) | 1,818 |
| Arkansas | Little Rock | 1,877 | -3% | (55) | 1,822 |
| California | Los Angeles | 1,877 | 15% | 279 | 2,156 |
| California | Redding | 1,877 | 12% | 219 | 2,096 |
| California | Bakersfield | 1,877 | 13% | 253 | 2,130 |
| California | Sacramento | 1,877 | 12% | 222 | 2,099 |
| California | San Francisco | 1,877 | 20% | 384 | 2,261 |
| Colorado | Denver | 1,877 | 3% | 51 | 1,928 |
| Connecticut | Hartford | 1,877 | 8% | 155 | 2,032 |
| Delaware | Dover | 1,877 | 6% | 109 | 1,986 |
| District of Columbia | Washington | 1,877 | 10% | 195 | 2,072 |
| Florida | Tallahassee | 1,877 | -4% | (80) | 1,797 |
| Florida | Tampa | 1,877 | -3% | (62) | 1,815 |
| Georgia | Atlanta | 1,877 | -5% | (95) | 1,782 |
| Hawaii | Honolulu | 1,877 | 35% | 649 | 2,526 |
| Idaho | Boise | 1,877 | 5% | 99 | 1,976 |
| Illinois | Chicago | 1,877 | 14% | 259 | 2,136 |
| Indiana | Indianapolis | 1,877 | -1% | (11) | 1,866 |
| Iowa | Davenport | 1,877 | 6% | 115 | 1,992 |
| Iowa | Waterloo | 1,877 | 4% | 70 | 1,947 |
| Kansas | Wichita | 1,877 | 3% | 62 | 1,939 |
| Kentucky | Louisville | 1,877 | -4% | (68) | 1,809 |
| Louisiana | New Orleans | 1,877 | -7% | (125) | 1,752 |
| Maine | Portland | 1,877 | 7% | 140 | 2,017 |
| Maryland | Baltimore | 1,877 | 1% | 28 | 1,905 |
| Massachusetts | Boston | 1,877 | 11% | 200 | 2,077 |
| Michigan | Detroit | 1,877 | 3% | 48 | 1,925 |
| Michigan | Grand Rapids | 1,877 | -1% | (17) | 1,860 |
| Minnesota | Saint Paul | 1,877 | 10% | 197 | 2,074 |
| Mississippi | Jackson | 1,877 | -3% | (62) | 1,815 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 1,877 | 3% | 55 | 1,932 |
| Missouri | Kansas City | 1,877 | 0% | 9 | 1,886 |
| Montana | Great Falls | 1,877 | 8% | 155 | 2,032 |
| Nebraska | Omaha | 1,877 | 5% | 93 | 1,970 |
| New Hampshire | Concord | 1,877 | 8% | 155 | 2,032 |
| New Jersey | Newark | 1,877 | 10% | 184 | 2,061 |
| New Mexico | Albuquerque | 1,877 | 4% | 76 | 1,953 |
| New York | New York | 1,877 | 25% | 462 | 2,339 |
| New York | Syracuse | 1,877 | 0% | 1 | 1,878 |
| Nevada | Las Vegas | 1,877 | 9% | 165 | 2,042 |
| North Carolina | Charlotte | 1,877 | -6% | (105) | 1,772 |
| North Dakota | Bismarck | 1,877 | 4% | 81 | 1,958 |
| Ohio | Cincinnati | 1,877 | -4% | (66) | 1,811 |
| Oregon | Portland | 1,877 | 9% | 171 | 2,048 |
| Pennsylvania | Philadelphia | 1,877 | 5% | 90 | 1,967 |
| Pennsylvania | Wilkes-Barre | 1,877 | -2% | (32) | 1,845 |
| Rhode Island | Providence | 1,877 | 3% | 58 | 1,935 |
| South Carolina | Spartanburg | 1,877 | -7% | (124) | 1,753 |
| South Dakota | Rapid City | 1,877 | 2% | 38 | 1,915 |
| Tennessee | Knoxville | 1,877 | -5% | (98) | 1,779 |
| Texas | Houston | 1,877 | -6% | (116) | 1,761 |
| Utah | Salt Lake City | 1,877 | 6% | 113 | 1,990 |
| Vermont | Burlington | 1,877 | 6% | 110 | 1,987 |
| Virginia | Alexandria | 1,877 | 3% | 64 | 1,941 |
| Virginia | Lynchburg | 1,877 | -4% | (67) | 1,810 |
| Washington | Seattle | 1,877 | 4% | 67 | 1,944 |
| Washington | Spokane | 1,877 | 6% | 110 | 1,987 |
| West Virginia | Charleston | 1,877 | 0% | 4 | 1,881 |
| Wisconsin | Green Bay | 1,877 | -2% | (41) | 1,836 |
| Wyoming | Cheyenne | 1,877 | 3% | 63 | 1,940 |
| Puerto Rico | Cayey | 1,877 | 9% | 169 | 2,046 |

TABLE 15-4 – LOCATION-BASED COSTS FOR PV FIXED FACILITY (20,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 2,671 | 22% | 593 | 3,264 |
| Alaska | Fairbanks | 2,671 | 43% | 1,154 | 3,825 |
| Alabama | Huntsville | 2,671 | -14% | (368) | 2,303 |
| Arizona | Phoenix | 2,671 | -10% | (276) | 2,395 |
| Arkansas | Little Rock | 2,671 | -10% | (261) | 2,410 |
| California | Los Angeles | 2,671 | 9% | 244 | 2,915 |
| California | Redding | 2,671 | 10% | 272 | 2,943 |
| California | Bakersfield | 2,671 | 8% | 221 | 2,892 |
| California | Sacramento | 2,671 | 10% | 280 | 2,951 |
| California | San Francisco | 2,671 | 21% | 549 | 3,220 |
| Colorado | Denver | 2,671 | -7% | (182) | 2,489 |
| Connecticut | Hartford | 2,671 | 10% | 262 | 2,933 |
| Delaware | Dover | 2,671 | 6% | 153 | 2,824 |
| District of Columbia | Washington | 2,671 | 6% | 162 | 2,833 |
| Florida | Tallahassee | 2,671 | -10% | (280) | 2,391 |
| Florida | Tampa | 2,671 | -8% | (217) | 2,454 |
| Georgia | Atlanta | 2,671 | -14% | (366) | 2,305 |
| Hawaii | Honolulu | 2,671 | 62% | 1,652 | 4,323 |
| Idaho | Boise | 2,671 | -7% | (177) | 2,494 |
| Illinois | Chicago | 2,671 | 20% | 533 | 3,204 |
| Indiana | Indianapolis | 2,671 | -5% | (123) | 2,548 |
| Iowa | Davenport | 2,671 | -2% | (51) | 2,620 |
| Iowa | Waterloo | 2,671 | -8% | (210) | 2,461 |
| Kansas | Wichita | 2,671 | -10% | (271) | 2,400 |
| Kentucky | Louisville | 2,671 | -10% | (272) | 2,399 |
| Louisiana | New Orleans | 2,671 | -16% | (439) | 2,232 |
| Maine | Portland | 2,671 | -7% | (180) | 2,491 |
| Maryland | Baltimore | 2,671 | -6% | (148) | 2,523 |
| Massachusetts | Boston | 2,671 | 16% | 419 | 3,090 |
| Michigan | Detroit | 2,671 | 2% | 66 | 2,737 |
| Michigan | Grand Rapids | 2,671 | -5% | (129) | 2,542 |
| Minnesota | Saint Paul | 2,671 | 7% | 187 | 2,858 |
| Mississippi | Jackson | 2,671 | -9% | (253) | 2,418 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 2,671 | 1% | 24 | 2,695 |
| Missouri | Kansas City | 2,671 | -1% | (35) | 2,636 |
| Montana | Great Falls | 2,671 | -5% | (127) | 2,544 |
| Nebraska | Omaha | 2,671 | -6% | (164) | 2,507 |
| New Hampshire | Concord | 2,671 | 3% | 80 | 2,751 |
| New Jersey | Newark | 2,671 | 14% | 383 | 3,054 |
| New Mexico | Albuquerque | 2,671 | -3% | (74) | 2,597 |
| New York | New York | 2,671 | 42% | 1,128 | 3,799 |
| New York | Syracuse | 2,671 | -2% | (61) | 2,610 |
| Nevada | Las Vegas | 2,671 | 2% | 56 | 2,727 |
| North Carolina | Charlotte | 2,671 | -16% | (436) | 2,235 |
| North Dakota | Bismarck | 2,671 | -8% | (220) | 2,451 |
| Ohio | Cincinnati | 2,671 | -10% | (265) | 2,406 |
| Oregon | Portland | 2,671 | -1% | (28) | 2,643 |
| Pennsylvania | Philadelphia | 2,671 | 9% | 248 | 2,919 |
| Pennsylvania | Wilkes-Barre | 2,671 | -7% | (179) | 2,492 |
| Rhode Island | Providence | 2,671 | 5% | 134 | 2,805 |
| South Carolina | Spartanburg | 2,671 | -19% | (504) | 2,167 |
| South Dakota | Rapid City | 2,671 | -11% | (303) | 2,368 |
| Tennessee | Knoxville | 2,671 | -14% | (379) | 2,292 |
| Texas | Houston | 2,671 | -15% | (405) | 2,266 |
| Utah | Salt Lake City | 2,671 | -9% | (230) | 2,441 |
| Vermont | Burlington | 2,671 | -5% | (140) | 2,531 |
| Virginia | Alexandria | 2,671 | -3% | (85) | 2,586 |
| Virginia | Lynchburg | 2,671 | -10% | (270) | 2,401 |
| Washington | Seattle | 2,671 | 2% | 63 | 2,734 |
| Washington | Spokane | 2,671 | -5% | (139) | 2,532 |
| West Virginia | Charleston | 2,671 | 0% | (1) | 2,670 |
| Wisconsin | Green Bay | 2,671 | -5% | (125) | 2,546 |
| Wyoming | Cheyenne | 2,671 | -8% | (209) | 2,462 |
| Puerto Rico | Cayey | 2,671 | -3% | (68) | 2,603 |

**TABLE 15-5 – LOCATION-BASED COSTS FOR PV TRACKER FACILITY
(20,000 KW)**

(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 2,644 | 23% | 599 | 3,243 |
| Alaska | Fairbanks | 2,644 | 44% | 1,161 | 3,805 |
| Alabama | Huntsville | 2,644 | -14% | (378) | 2,266 |
| Arizona | Phoenix | 2,644 | -11% | (284) | 2,360 |
| Arkansas | Little Rock | 2,644 | -10% | (268) | 2,376 |
| California | Los Angeles | 2,644 | 9% | 247 | 2,891 |
| California | Redding | 2,644 | 10% | 276 | 2,920 |
| California | Bakersfield | 2,644 | 8% | 224 | 2,868 |
| California | Sacramento | 2,644 | 11% | 284 | 2,928 |
| California | San Francisco | 2,644 | 21% | 560 | 3,204 |
| Colorado | Denver | 2,644 | -7% | (191) | 2,453 |
| Connecticut | Hartford | 2,644 | 10% | 267 | 2,911 |
| Delaware | Dover | 2,644 | 6% | 155 | 2,799 |
| District of Columbia | Washington | 2,644 | 6% | 161 | 2,805 |
| Florida | Tallahassee | 2,644 | -11% | (288) | 2,356 |
| Florida | Tampa | 2,644 | -8% | (224) | 2,420 |
| Georgia | Atlanta | 2,644 | -14% | (377) | 2,267 |
| Hawaii | Honolulu | 2,644 | 63% | 1,657 | 4,301 |
| Idaho | Boise | 2,644 | -7% | (183) | 2,461 |
| Illinois | Chicago | 2,644 | 21% | 544 | 3,188 |
| Indiana | Indianapolis | 2,644 | -5% | (127) | 2,517 |
| Iowa | Davenport | 2,644 | -2% | (53) | 2,591 |
| Iowa | Waterloo | 2,644 | -8% | (216) | 2,428 |
| Kansas | Wichita | 2,644 | -11% | (279) | 2,365 |
| Kentucky | Louisville | 2,644 | -11% | (280) | 2,364 |
| Louisiana | New Orleans | 2,644 | -17% | (452) | 2,192 |
| Maine | Portland | 2,644 | -7% | (190) | 2,454 |
| Maryland | Baltimore | 2,644 | -6% | (155) | 2,489 |
| Massachusetts | Boston | 2,644 | 16% | 429 | 3,073 |
| Michigan | Detroit | 2,644 | 3% | 67 | 2,711 |
| Michigan | Grand Rapids | 2,644 | -5% | (132) | 2,512 |
| Minnesota | Saint Paul | 2,644 | 7% | 191 | 2,835 |
| Mississippi | Jackson | 2,644 | -10% | (260) | 2,384 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 2,644 | 1% | 24 | 2,668 |
| Missouri | Kansas City | 2,644 | -1% | (36) | 2,608 |
| Montana | Great Falls | 2,644 | -5% | (132) | 2,512 |
| Nebraska | Omaha | 2,644 | -6% | (169) | 2,475 |
| New Hampshire | Concord | 2,644 | 3% | 79 | 2,723 |
| New Jersey | Newark | 2,644 | 15% | 394 | 3,038 |
| New Mexico | Albuquerque | 2,644 | -3% | (80) | 2,564 |
| New York | New York | 2,644 | 44% | 1,153 | 3,797 |
| New York | Syracuse | 2,644 | -2% | (64) | 2,580 |
| Nevada | Las Vegas | 2,644 | 2% | 58 | 2,702 |
| North Carolina | Charlotte | 2,644 | -17% | (449) | 2,195 |
| North Dakota | Bismarck | 2,644 | -9% | (227) | 2,417 |
| Ohio | Cincinnati | 2,644 | -10% | (273) | 2,371 |
| Oregon | Portland | 2,644 | 4% | 102 | 2,746 |
| Pennsylvania | Philadelphia | 2,644 | 10% | 255 | 2,899 |
| Pennsylvania | Wilkes-Barre | 2,644 | -7% | (184) | 2,460 |
| Rhode Island | Providence | 2,644 | 5% | 138 | 2,782 |
| South Carolina | Spartanburg | 2,644 | -20% | (518) | 2,126 |
| South Dakota | Rapid City | 2,644 | -12% | (313) | 2,331 |
| Tennessee | Knoxville | 2,644 | -15% | (390) | 2,254 |
| Texas | Houston | 2,644 | -16% | (417) | 2,227 |
| Utah | Salt Lake City | 2,644 | -4% | (107) | 2,537 |
| Vermont | Burlington | 2,644 | -1% | (14) | 2,630 |
| Virginia | Alexandria | 2,644 | -3% | (87) | 2,557 |
| Virginia | Lynchburg | 2,644 | -11% | (278) | 2,366 |
| Washington | Seattle | 2,644 | 2% | 64 | 2,708 |
| Washington | Spokane | 2,644 | -5% | (143) | 2,501 |
| West Virginia | Charleston | 2,644 | 0% | (2) | 2,642 |
| Wisconsin | Green Bay | 2,644 | -5% | (129) | 2,515 |
| Wyoming | Cheyenne | 2,644 | -8% | (217) | 2,427 |
| Puerto Rico | Cayey | 2,644 | -3% | (76) | 2,568 |

**TABLE 15-6 – LOCATION-BASED COSTS FOR PV TRACKER FACILITY
(150,000 KW)**

(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 2,534 | 22% | 569 | 3,103 |
| Alaska | Fairbanks | 2,534 | 44% | 1,124 | 3,658 |
| Alabama | Huntsville | 2,534 | -13% | (319) | 2,215 |
| Arizona | Phoenix | 2,534 | -9% | (239) | 2,295 |
| Arkansas | Little Rock | 2,534 | -9% | (226) | 2,308 |
| California | Los Angeles | 2,534 | 9% | 232 | 2,766 |
| California | Redding | 2,534 | 10% | 253 | 2,787 |
| California | Bakersfield | 2,534 | 8% | 209 | 2,743 |
| California | Sacramento | 2,534 | 10% | 260 | 2,794 |
| California | San Francisco | 2,534 | 20% | 500 | 3,034 |
| Colorado | Denver | 2,534 | -8% | (206) | 2,328 |
| Connecticut | Hartford | 2,534 | 9% | 238 | 2,772 |
| Delaware | Dover | 2,534 | 6% | 143 | 2,677 |
| District of Columbia | Washington | 2,534 | 7% | 167 | 2,701 |
| Florida | Tallahassee | 2,534 | -10% | (242) | 2,292 |
| Florida | Tampa | 2,534 | -7% | (188) | 2,346 |
| Georgia | Atlanta | 2,534 | -13% | (317) | 2,217 |
| Hawaii | Honolulu | 2,534 | 64% | 1,631 | 4,165 |
| Idaho | Boise | 2,534 | -4% | (89) | 2,445 |
| Illinois | Chicago | 2,534 | 16% | 417 | 2,951 |
| Indiana | Indianapolis | 2,534 | -4% | (104) | 2,430 |
| Iowa | Davenport | 2,534 | 1% | 21 | 2,555 |
| Iowa | Waterloo | 2,534 | -5% | (117) | 2,417 |
| Kansas | Wichita | 2,534 | -7% | (170) | 2,364 |
| Kentucky | Louisville | 2,534 | -9% | (236) | 2,298 |
| Louisiana | New Orleans | 2,534 | -15% | (380) | 2,154 |
| Maine | Portland | 2,534 | -8% | (201) | 2,333 |
| Maryland | Baltimore | 2,534 | -5% | (117) | 2,417 |
| Massachusetts | Boston | 2,534 | 15% | 375 | 2,909 |
| Michigan | Detroit | 2,534 | 2% | 57 | 2,591 |
| Michigan | Grand Rapids | 2,534 | -4% | (112) | 2,422 |
| Minnesota | Saint Paul | 2,534 | 9% | 229 | 2,763 |
| Mississippi | Jackson | 2,534 | -9% | (219) | 2,315 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 2,534 | 1% | 20 | 2,554 |
| Missouri | Kansas City | 2,534 | -1% | (30) | 2,504 |
| Montana | Great Falls | 2,534 | -1% | (37) | 2,497 |
| Nebraska | Omaha | 2,534 | -3% | (77) | 2,457 |
| New Hampshire | Concord | 2,534 | 1% | 22 | 2,556 |
| New Jersey | Newark | 2,534 | 13% | 332 | 2,866 |
| New Mexico | Albuquerque | 2,534 | -4% | (109) | 2,425 |
| New York | New York | 2,534 | 40% | 1,012 | 3,546 |
| New York | Syracuse | 2,534 | -2% | (48) | 2,486 |
| Nevada | Las Vegas | 2,534 | 4% | 114 | 2,648 |
| North Carolina | Charlotte | 2,534 | -15% | (378) | 2,156 |
| North Dakota | Bismarck | 2,534 | -5% | (123) | 2,411 |
| Ohio | Cincinnati | 2,534 | -9% | (229) | 2,305 |
| Oregon | Portland | 2,534 | 2% | 41 | 2,575 |
| Pennsylvania | Philadelphia | 2,534 | 8% | 215 | 2,749 |
| Pennsylvania | Wilkes-Barre | 2,534 | -6% | (155) | 2,379 |
| Rhode Island | Providence | 2,534 | 5% | 116 | 2,650 |
| South Carolina | Spartanburg | 2,534 | -17% | (436) | 2,098 |
| South Dakota | Rapid City | 2,534 | -8% | (195) | 2,339 |
| Tennessee | Knoxville | 2,534 | -13% | (329) | 2,205 |
| Texas | Houston | 2,534 | -14% | (351) | 2,183 |
| Utah | Salt Lake City | 2,534 | -5% | (135) | 2,399 |
| Vermont | Burlington | 2,534 | -2% | (56) | 2,478 |
| Virginia | Alexandria | 2,534 | -3% | (73) | 2,461 |
| Virginia | Lynchburg | 2,534 | -9% | (234) | 2,300 |
| Washington | Seattle | 2,534 | 2% | 54 | 2,588 |
| Washington | Spokane | 2,534 | -2% | (56) | 2,478 |
| West Virginia | Charleston | 2,534 | 0% | 1 | 2,535 |
| Wisconsin | Green Bay | 2,534 | -4% | (106) | 2,428 |
| Wyoming | Cheyenne | 2,534 | -4% | (109) | 2,425 |
| Puerto Rico | Cayey | 2,534 | -1% | (33) | 2,501 |

TABLE 16-2 – LOCATION-BASED COSTS FOR RICE FACILITY (85,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|----------------------------------|---------------------------|--------------------------------------|--|
| Alaska | Anchorage | 1,342 | 23% | 308 | 1,650 |
| Alaska | Fairbanks | 1,342 | 27% | 361 | 1,703 |
| Alabama | Huntsville | 1,342 | -10% | (136) | 1,206 |
| Arizona | Phoenix | 1,342 | -8% | (101) | 1,241 |
| Arkansas | Little Rock | 1,342 | -7% | (96) | 1,246 |
| California | Los Angeles | 1,342 | 14% | 185 | 1,527 |
| California | Redding | 1,342 | 5% | 73 | 1,415 |
| California | Bakersfield | 1,342 | 6% | 82 | 1,424 |
| California | Sacramento | 1,342 | 8% | 102 | 1,444 |
| California | San Francisco | 1,342 | 27% | 356 | 1,698 |
| Colorado | Denver | 1,342 | -4% | (60) | 1,282 |
| Connecticut | Hartford | 1,342 | 15% | 199 | 1,541 |
| Delaware | Dover | 1,342 | 13% | 173 | 1,515 |
| District of Columbia | Washington | 1,342 | 18% | 241 | 1,583 |
| Florida | Tallahassee | 1,342 | -8% | (112) | 1,230 |
| Florida | Tampa | 1,342 | -7% | (92) | 1,250 |
| Georgia | Atlanta | 1,342 | -8% | (110) | 1,232 |
| Hawaii | Honolulu | 1,342 | 37% | 498 | 1,840 |
| Idaho | Boise | 1,342 | -4% | (49) | 1,293 |
| Illinois | Chicago | 1,342 | 11% | 147 | 1,489 |
| Indiana | Indianapolis | 1,342 | -2% | (23) | 1,319 |
| Iowa | Davenport | 1,342 | 0% | 3 | 1,345 |
| Iowa | Waterloo | 1,342 | -4% | (50) | 1,292 |
| Kansas | Wichita | 1,342 | -5% | (65) | 1,277 |
| Kentucky | Louisville | 1,342 | -6% | (85) | 1,257 |
| Louisiana | New Orleans | 1,342 | -7% | (100) | 1,242 |
| Maine | Portland | 1,342 | -6% | (80) | 1,262 |
| Maryland | Baltimore | 1,342 | 5% | 71 | 1,413 |
| Massachusetts | Boston | 1,342 | 22% | 291 | 1,633 |
| Michigan | Detroit | 1,342 | 3% | 46 | 1,388 |
| Michigan | Grand Rapids | 1,342 | -2% | (23) | 1,319 |
| Minnesota | Saint Paul | 1,342 | 6% | 75 | 1,417 |
| Mississippi | Jackson | 1,342 | -7% | (98) | 1,244 |

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 1,342 | 3% | 34 | 1,376 |
| Missouri | Kansas City | 1,342 | 0% | (1) | 1,341 |
| Montana | Great Falls | 1,342 | 1% | 7 | 1,349 |
| Nebraska | Omaha | 1,342 | -2% | (30) | 1,312 |
| New Hampshire | Concord | 1,342 | 0% | (6) | 1,336 |
| New Jersey | Newark | 1,342 | 16% | 211 | 1,553 |
| New Mexico | Albuquerque | 1,342 | -4% | (49) | 1,293 |
| New York | New York | 1,342 | 44% | 585 | 1,927 |
| New York | Syracuse | 1,342 | 4% | 56 | 1,398 |
| Nevada | Las Vegas | 1,342 | 2% | 29 | 1,371 |
| North Carolina | Charlotte | 1,342 | -10% | (135) | 1,207 |
| North Dakota | Bismarck | 1,342 | -4% | (60) | 1,282 |
| Ohio | Cincinnati | 1,342 | -5% | (63) | 1,279 |
| Oregon | Portland | 1,342 | 1% | 17 | 1,359 |
| Pennsylvania | Philadelphia | 1,342 | 11% | 151 | 1,493 |
| Pennsylvania | Wilkes-Barre | 1,342 | -2% | (30) | 1,312 |
| Rhode Island | Providence | 1,342 | 11% | 146 | 1,488 |
| South Carolina | Spartanburg | 1,342 | -13% | (176) | 1,166 |
| South Dakota | Rapid City | 1,342 | -7% | (88) | 1,254 |
| Tennessee | Knoxville | 1,342 | -9% | (121) | 1,221 |
| Texas | Houston | 1,342 | -10% | (135) | 1,207 |
| Utah | Salt Lake City | 1,342 | -4% | (50) | 1,292 |
| Vermont | Burlington | 1,342 | 1% | 16 | 1,358 |
| Virginia | Alexandria | 1,342 | 5% | 68 | 1,410 |
| Virginia | Lynchburg | 1,342 | -6% | (85) | 1,257 |
| Washington | Seattle | 1,342 | 4% | 47 | 1,389 |
| Washington | Spokane | 1,342 | -3% | (36) | 1,306 |
| West Virginia | Charleston | 1,342 | 1% | 18 | 1,360 |
| Wisconsin | Green Bay | 1,342 | -2% | (28) | 1,314 |
| Wyoming | Cheyenne | 1,342 | -2% | (25) | 1,317 |
| Puerto Rico | Cayey | 1,342 | -1% | (16) | 1,326 |

TABLE 17-2 – LOCATION-BASED COSTS FOR BES FACILITY (4,000 KW)
(JANUARY 1, 2016 DOLLARS)

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------------|---------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Alaska | Anchorage | 2,813 | 19% | 525 | 3,338 |
| Alaska | Fairbanks | 2,813 | 32% | 903 | 3,716 |
| Alabama | Huntsville | 2,813 | -4% | (122) | 2,691 |
| Arizona | Phoenix | 2,813 | -3% | (85) | 2,728 |
| Arkansas | Little Rock | 2,813 | -3% | (79) | 2,734 |
| California | Los Angeles | 2,813 | 8% | 212 | 3,025 |
| California | Redding | 2,813 | 3% | 75 | 2,888 |
| California | Bakersfield | 2,813 | 3% | 83 | 2,896 |
| California | Sacramento | 2,813 | 3% | 78 | 2,891 |
| California | San Francisco | 2,813 | 11% | 309 | 3,122 |
| Colorado | Denver | 2,813 | -4% | (102) | 2,711 |
| Connecticut | Hartford | 2,813 | 6% | 156 | 2,969 |
| Delaware | Dover | 2,813 | 4% | 109 | 2,922 |
| District of Columbia | Washington | 2,813 | 7% | 189 | 3,002 |
| Florida | Tallahassee | 2,813 | -3% | (96) | 2,717 |
| Florida | Tampa | 2,813 | -3% | (75) | 2,738 |
| Georgia | Atlanta | 2,813 | -4% | (121) | 2,692 |
| Hawaii | Honolulu | 2,813 | 32% | 910 | 3,723 |
| Idaho | Boise | 2,813 | -2% | (51) | 2,762 |
| Illinois | Chicago | 2,813 | 5% | 152 | 2,965 |
| Indiana | Indianapolis | 2,813 | -1% | (24) | 2,789 |
| Iowa | Davenport | 2,813 | -1% | (18) | 2,795 |
| Iowa | Waterloo | 2,813 | -3% | (72) | 2,741 |
| Kansas | Wichita | 2,813 | -3% | (88) | 2,725 |
| Kentucky | Louisville | 2,813 | -3% | (89) | 2,724 |
| Louisiana | New Orleans | 2,813 | -5% | (151) | 2,662 |
| Maine | Portland | 2,813 | -3% | (84) | 2,729 |
| Maryland | Baltimore | 2,813 | 0% | 9 | 2,822 |
| Massachusetts | Boston | 2,813 | 7% | 210 | 3,023 |
| Michigan | Detroit | 2,813 | 1% | 28 | 2,841 |
| Michigan | Grand Rapids | 2,813 | -2% | (44) | 2,769 |
| Minnesota | Saint Paul | 2,813 | 3% | 77 | 2,890 |
| Mississippi | Jackson | 2,813 | -3% | (82) | 2,731 |

12

| State | City | Base Project Cost (\$/kW) | Location Variation | Delta Cost Difference (\$/kW) | Total Location Project Cost (\$/kW) |
|----------------|----------------|---------------------------|--------------------|-------------------------------|-------------------------------------|
| Missouri | St. Louis | 2,813 | 1% | 34 | 2,847 |
| Missouri | Kansas City | 2,813 | 0% | (2) | 2,811 |
| Montana | Great Falls | 2,813 | 0% | 5 | 2,818 |
| Nebraska | Omaha | 2,813 | -2% | (51) | 2,762 |
| New Hampshire | Concord | 2,813 | 0% | (7) | 2,806 |
| New Jersey | Newark | 2,813 | 5% | 137 | 2,950 |
| New Mexico | Albuquerque | 2,813 | -3% | (72) | 2,741 |
| New York | New York | 2,813 | 25% | 700 | 3,513 |
| New York | Syracuse | 2,813 | -1% | (29) | 2,784 |
| Nevada | Las Vegas | 2,813 | 1% | 30 | 2,843 |
| North Carolina | Charlotte | 2,813 | -5% | (140) | 2,673 |
| North Dakota | Bismarck | 2,813 | -2% | (63) | 2,750 |
| Ohio | Cincinnati | 2,813 | -3% | (86) | 2,727 |
| Oregon | Portland | 2,813 | 1% | 16 | 2,829 |
| Pennsylvania | Philadelphia | 2,813 | 3% | 96 | 2,909 |
| Pennsylvania | Wilkes-Barre | 2,813 | -2% | (51) | 2,762 |
| Rhode Island | Providence | 2,813 | 2% | 57 | 2,870 |
| South Carolina | Spartanburg | 2,813 | -6% | (163) | 2,650 |
| South Dakota | Rapid City | 2,813 | -3% | (92) | 2,721 |
| Tennessee | Knoxville | 2,813 | -4% | (126) | 2,687 |
| Texas | Houston | 2,813 | -5% | (140) | 2,673 |
| Utah | Salt Lake City | 2,813 | -2% | (53) | 2,760 |
| Vermont | Burlington | 2,813 | -1% | (38) | 2,775 |
| Virginia | Alexandria | 2,813 | -1% | (24) | 2,789 |
| Virginia | Lynchburg | 2,813 | -3% | (88) | 2,725 |
| Washington | Seattle | 2,813 | 2% | 48 | 2,861 |
| Washington | Spokane | 2,813 | -1% | (38) | 2,775 |
| West Virginia | Charleston | 2,813 | 1% | 18 | 2,831 |
| Wisconsin | Green Bay | 2,813 | -1% | (30) | 2,783 |
| Wyoming | Cheyenne | 2,813 | -2% | (68) | 2,745 |
| Puerto Rico | Cayey | 2,813 | 5% | 130 | 2,943 |