

CAC  
IURC Cause No. 38707-FAC123 S1  
Data Request Set No. 13  
Received: September 15, 2020

CAC 13.9

**Request:**

Refer to Mr. Swez's Rebuttal testimony at page 39 lines 17 to 20. With regards to the 606 MW operating level assumed therein:

- a. State whether Edwardsport operated at a level of 606 MWs at any time during the FAC 123 reconciliation period.
- b. If so, identify each day and hour during that period that Edwardsport operated at 606 MWs.
- c. If not, identify the maximum level in MWs that Edwardsport actually operated at during the FAC 123 reconciliation period.

**Response:**

- a. The station did not operate at an hourly integrated amount of 606 MW (net) or greater during the FAC 123 period.
- b. N/A
- c. The maximum hourly generation amount for Edwardsport Station was 578 MW (net) during the FAC 123 period on November 27, 2019 during HE2100 EST.

**Witness:** John Swez

OFFICIAL  
EXHIBITS

IURC  
INTERVENOR'S - CAC  
EXHIBIT NO. CX-6  
10-30-20  
DATE REPORTER