FILED November 23, 2021 INDIANA UTILITY REGULATORY COMMISSION

# **STATE OF INDIANA**

# INDIANA UTILITY REGULATORY COMMISSION

VERIFIED PETITION OF DUKE ENERGY	)
INDIANA, INC. FOR; (1) APPROVAL OF	)
PETITIONER'S 6-YEAR PLAN FOR	)
ELIGIBLE TRANSMISSION,	)
DISTRIBUTION AND STORAGE SYSTEM	)
IMPROVEMENTS, PURSUANT TO	) CAUSE NO. 45647
IND. CODE § 8-1-39-10; (2) APPROVAL OF A	)
TRANSMISSION AND DISTRIBUTION	)
INFRASTRUCTURE IMPROVEMENT COST	)
RATE ADJUSTMENT AND DEFERRALS,	)
PURSUANT TO IND. CODE §§ 8-1-2-10, 8-1-2-	)
12, 8-1-2-14, AND 8-1-39-1 ET SEQ; AND (3)	)
APPROVAL OF A TARGETED ECONOMIC	)
DEVELOPMENT PROJECT AND	)
<b>RECOVERY OF COSTS ASSOCIATED WITH</b>	)
THE PROJECT, PURSUANT TO IND. CODE	)
§§ 8-1-39-10 AND 8-1-39-11	)

# VERIFIED DIRECT TESTIMONY OF JEREMY K. LEWIS

# On Behalf of Petitioner, DUKE ENERGY INDIANA, LLC

**Petitioner's Exhibit 2** 

November 23, 2021

DUKE ENERGY INDIANA TDSIC 2.0 DIRECT TESTIMONY OF JEREMY K. LEWIS FILED NOVEMBER 23, 2021

# DIRECT TESTIMONY OF JEREMY K. LEWIS DIRECTOR OF CUSTOMER DELIVERY PROJECT MANAGEMENT DUKE ENERGY BUSINESS SERVICES, LLC ON BEHALF OF DUKE ENERGY INDIANA, LLC <u>BEFORE THE INDIANA UTILITY REGULATORY COMMISSION</u>

1		I. <u>INTRODUCTION</u>
2	Q.	PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.
3	А.	My name is Jeremy K. Lewis, and my business address is 100 South Mill Creek
4		Road, Noblesville, Indiana 46062.
5	Q.	BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?
6	А.	I am employed as Director of Customer Delivery Project Management by Duke
7		Energy Business Services, LLC, a service company subsidiary of Duke Energy
8		Corporation, and a non-utility affiliate of Duke Energy Indiana, LLC ("Duke
9		Energy Indiana" or "Company").
10	Q.	PLEASE BRIEFLY DESCRIBE YOUR EDUCATIONAL AND
11		PROFESSIONAL BACKGROUND.
12	А.	I started my career at PSI Energy, Inc. (a predecessor to Duke Energy Indiana) in
13		2001 and have worked with increasing levels of responsibility in the Distribution
14		group. I was promoted to my current position in June 2019. I received my
15		Bachelor of Science Degree in Organizational Leadership and Supervision in
16		2003.
17	Q.	PLEASE BRIEFLY DESCRIBE YOUR DUTIES AND
18		<b>RESPONSIBILITIES AS DIRECTOR OF CUSTOMER DELIVERY</b>
19		PROJECT MANAGEMENT.

1	А.	My current responsibilities include direction and project management for the
2		portfolio of all major customer delivery or distribution projects for Duke Energy
3		Indiana, including TDSIC and non-TDSIC projects.
4	Q.	WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS
5		PROCEEDING?
6	A.	My testimony will provide an overview of Duke Energy Indiana's Transmission,
7		Distribution, and Storage System Improvement Charge investment plan for 2023-
8		2028 ("TDSIC 2.0"). Specifically, I will review the overall TDSIC 2.0
9		investment plan for Duke Energy Indiana for both transmission and distribution
10		investments, as well as provide specific details regarding the distribution circuit
11		portions of TDSIC 2.0. I will also highlight: (1) the customer benefits of TDSIC
12		2.0; (2) Duke Energy Indiana's rigorous cost estimating process used in TDSIC
13		2.0; (3) the transmission and distribution projects selected for TDSIC 2.0 and the
14		basis for their selection; (4) the specific cost estimates for each of the distribution
15		projects; (5) an overview of the Black & Veatch ("B&V") evaluations and results
16		for this proceeding; and (6) how the projects selected for TDSIC 2.0 meet the
17		statutory requirements of Indiana Code 8-1-39.
18		II. <u>TDSIC 2.0 OVERVIEW</u>
19	Q.	PLEASE DESCRIBE DUKE ENERGY INDIANA'S HISTORY OF
20		TRANSMISSION AND DISTRIBUTION INVESTMENTS THROUGH ITS
21		FIRST TDSIC, WHICH WAS APPROVED BY THE COMMISSION IN
22		CAUSE NO. 44720.

22		INVESTMENT PLAN.
21	Q.	PLEASE PROVIDE AN OVERVIEW OF THE COMPANY'S TDSIC 2.0
20		improvements, and enablement of distributed energy.
19		each project emphasizing reliability prioritization, hardening and resiliency
18		evaluate risk as in TDSIC 1.0, but further extend a value to benefit proposition of
17		and modernization of the grid. The project selections for TDSIC 2.0 not only
16		condition, with goals of replacing aging infrastructure, improving functionality,
15		service life. Project selections for TDSIC 1.0 were primarily based on asset
14		distribution assets that were approaching or had exceeded their estimated physical
13		initial TDSIC 1.0 plan targeted a significant number of transmission and
12		risk of grid asset failure, based on the last update from the B&V risk model. The
11		Since TDSIC 1.0 began, Duke Energy Indiana has achieved a 27% reduction in
10		TDSIC 1.0 has been very successful for both the Company and our customers.
9		across key segments of work plan execution. Duke Energy Indiana believes that
8		in TDSIC 1.0 have led to positive insights and driven performance improvements
7		The rigor and scrutiny behind the Company's proposal and update filings
6		within the \$1.4 billion cap.
5		seven-year plan (2016-2022) and is on track to complete the committed scope
4		estimates, as well as the TDSIC Rider. Currently, TDSIC 1.0 is in year six of the
3		also approved semi-annual filings to update the TDSIC projects and cost
2		Commission on June 29, 2016. Along with that initial approval, the Commission
1	A.	The Company's first TDSIC investment plan ("TDSIC 1.0") was approved by the

1	A.	As stated above, the TDSIC 2.0 Investment Plan analyzes risk and emphasizes
2		value in the programs selected. The 2.0 strategy will help Duke Energy Indiana
3		meet its customers' growing expectations. Those expectations include proactive
4		communication, regarding service needs and outages, the expectation that
5		restoration times will be minimized after major storms, and the reduction of
6		momentary interruptions that are much more impactful to customers' lives and
7		digital interfaces than when the system was originally built. TDSIC 2.0 is a six-
8		year, \$2.0 billion plan including an estimated \$158 million of Targeted Economic
9		Development ("TED") investments. The recommended capital transmission
10		investments total approximately \$815 million, while the distribution investments
11		total \$1 billion over TDSIC 2.0's six-year investment horizon. The TDSIC 2.0
12		Investment Plan is designed to achieve cost-effective improvements in grid
13		reliability, safety, grid modernization, and economic development, as established
14		in the TDSIC statute, Indiana Code 8-1-39.
15		Duke Energy Indiana's plan addresses our defined grid investment planning
16		objectives, including the following areas of investment prioritization, which were
17		introduced in the testimony of Mr. Pinegar:
18 19		<ul> <li>Improve reliability for Indiana customers</li> <li>Advance grid hardening and resiliency</li> </ul>
20		<ul> <li>Enable expansion of renewable and distributed generation</li> <li>Enable expansion development growth</li> </ul>
21		• Facilitate economic development growth
22		The TDSIC 2.0 Investment Plan's distribution programs include: Circuit
23		Backbone Uplift, Overhead Lateral Uplift, Underground System Uplift, 4kV

1	Conversions, Inspection Based Programs, and Substation investments. At a high
2	level, these categories are focused on system capacity and technology designed to
3	isolate faults and automatically reconfigure the system to reduce and shorten
4	customer outages. In addition, these programs involve upgrading equipment to
5	address the leading cause of outages, momentary interruptions, and enhancing
6	controls around distribution lines and substation equipment to optimize power
7	delivery to customers. An overview of each distribution line program can be
8	found later in my testimony.
9	The TDSIC 2.0 Investment Plan's transmission investments include: 1)
10	Line Hardening and Resiliency; and 2) Substation Hardening and Resiliency. The
11	Line Hardening and Resiliency programs are targeted at hardening transmission
12	circuits against interruptions from both internal (end of life failures) and external
13	(storms and vegetation) sources, as well as reducing the duration and impact of
14	customer outages. The Substation Hardening and Resiliency programs are
15	targeted towards upgrades to transmission and distribution substations to improve
16	reliability, resiliency, and technical functionality. These programs, including the
17	specifics of the investment in distribution substations, are explained in greater
18	detail in the testimony of witness Mr. Martin Dickey.
19	The targeted economic development projects are focused on building out
20	infrastructure in areas that are of high interest to new and existing customers,
21	and/or have been marketed by state and local economic development agencies.

1 These projects are explained in greater detail in the testimony of witness Ms. Erin 2 Schneider.

#### 3 Q. MR. LEWIS, YOU PREVIOUSLY MENTIONED THAT ONE OF THE

#### **OBJECTIVES ASSOCIATED WITH TDSIC 2.0 WAS IMPROVING** 4

#### 5 **RELIABILITY FOR INDIANA CUSTOMERS. PLEASE EXPLAIN.**

6 A. Reliability can be defined as the ability of our power grid to deliver electric 7 service to the consumer in the quantity and quality of system demand. This can 8 be improved through proactively reducing the frequency and duration of outages 9 via programs in TDSIC 2.0. Greater than 80% of TDSIC 2.0 programs will 10 influence reliability. Looking retroactively at our past five-year average, if Duke 11 Energy Indiana would have had all of the proposed TDSIC 2.0 investments in 12 place, we would have avoided approximately 23% of Customer Interruptions 13 ("CI") and approximately 28% of Customer Minutes Interrupted ("CMI"). 14 The proposed TDSIC 2.0 investments will improve reliability. For 15 example, circuit rebuilds and upgrading from aged infrastructure to newer 16 standards helps maintain and improve reliability to our customers. The Company 17 intends to improve reliability through the utilization of new programs in the 18

19 smart-thinking and self-healing grid that will reroute power around faults, help to 20 quickly locate faults and restore power more quickly to our customers, thus 21 avoiding CI and CMI both on Major Event Days ("MED") and non-MED. These

TDSIC 2.0 Investment Plan that will help transform the system to a dynamic

#### DUKE ENERGY INDIANA TDSIC 2.0 DIRECT TESTIMONY OF JEREMY K. LEWIS FILED NOVEMBER 23, 2021

programs and TDSIC 2.0 benefits will be discussed in greater detail further in my
 testimony.

3 It is important to state that variables outside of TDSIC projects have an 4 impact on reliability. Major storms, vegetation management, cellular 5 advancement, and vehicle accidents are examples of non-TDSIC variables that 6 influence direct measurements of reliability and impact project performance 7 metrics. These variables can fluctuate significantly from year to year and have a 8 great impact to overall system performance. System needs and assets will mature 9 through the duration of this program and as such, Duke Energy Indiana believes it 10 is most appropriate to measure the success of TDSIC 2.0 following the full 11 execution of the investment plan. 12 Q. **ANOTHER OBJECTIVE OF TDSIC 2.0 IS TO ADVANCE GRID** 13 HARDENING AND RESILIENCY. WHAT DO THESE TERMS MEAN?

14 A. Duke Energy Indiana defines hardening as physically improving the durability 15 and stability of energy infrastructure to make it less susceptible to and to better 16 withstand damage from even extreme events. While hardening is making the 17 asset or grid stronger, Duke Energy Indiana believes resiliency makes the grid 18 smarter and better able to react to events. We define resiliency as the ability of a 19 transmission and distribution grid system to recover quickly from damage to any 20 of its components or to any of the external systems on which it depends. 21 Resiliency measures do not prevent damage; rather, they enable grid systems to 22 continue operating despite damage and/or promote a more rapid return to normal

1		operations when damages or outages do occur. Twenty-four of the thirty-five
2		sub-programs in the TDSIC 2.0 Investment Plan contribute to resiliency and
3		hardening of the grid.
4		Duke Energy Indiana's proposed TDSIC 2.0 Investment Plan is designed
5		to harden the grid and make it more resilient in several ways. Sub-programs
6		related to hardening and resiliency will help eliminate outdated grid architectures,
7		target vulnerable assets with high consequence of failure, solve asset conditions
8		that contribute to extending outages, and maintain or improve customer safety.
9		Inspection-based programs invest in the future performance of our system and are
10		often examples of programs that harden the grid. Inspection-based programs are
11		geared towards proactively replacing grid hardware and equipment based on their
12		effective age, condition, and historical failure rates. Proactively targeting these
13		assets reduces customer outages and improves customer satisfaction.
14	Q.	TDSIC 2.0 WAS ALSO DESIGNED TO FACILITATE THE EXPANSION
15		OF RENEWABLES AND DISTRIBUTED GENERATION. PLEASE
16		EXPLAIN.
17	A.	As described in the testimony of Mr. Pinegar, customers are venturing into
18		distributed generation and are excited about new advancements in renewable
19		energy. To properly balance energy supplies from distributed energy resources
20		like roof-top solar, new technology and grid strategies must be deployed over the
21		Duke Energy Indiana infrastructure. An optimal way of doing this is through

1		optimizing grid ties more circuits together and installs devices that allow power to
2		be shared and rerouted as well as areas to be isolated to adapt for outage
3		conditions. The self-optimizing grid essentially prepares the distribution
4		backbone circuits to accommodate a two-way power flow capability needed for
5		distributed energy resources. A self-optimizing grid also helps manage and
6		accept customer-generated and stored energy resources, such as wind, solar, and
7		battery storage from customer systems.
8		Another key component of enabling distributed energy resources is
9		voltage control. Integrated Volt-Var Control ("IVVC") allows the distribution
10		system to optimize voltage and react to power needs through remotely operated
11		substation and distribution line devices such as voltage regulators and capacitors.
12		Ultimately, this creates efficiencies that flatten the voltage which, allows
13		generation resources to travel further on the grid while using less energy. Further
14		aiding this objective are our TDSIC 2.0 programs such as SCADA
15		communication, substation relay replacements, circuit visibility and control, and
16		circuit rebuilds. Together, these help to create a future state more conducive to
17		both sides of the meter, which will better integrate renewables.
18	Q.	TDSIC 2.0 INCLUDES TARGETED ECONOMIC DEVELOPMENT
19		PROJECTS. WHY IS THIS IMPORTANT TO DUKE ENERGY
20		INDIANA?
21	A.	Duke Energy Indiana has included in its proposal, targeted economic
22		development projects at key sites that are of high interest to prospective customers

1		and existing Indiana businesses looking to grow. Investing in our infrastructure
2		now will help Indiana attract and retain companies and improve the lives of our
3		customers through new jobs and local investment. These projects seek to make
4		improvements in areas that have the greatest potential to attract economic growth
5		to Indiana. Facilitating business growth leads to more job opportunities for
6		Hoosiers and more investments in our local communities. These programs are
7		further explained in the testimony of witness Ms. Erin Schneider.
8	Q.	DUKE ENERGY INDIANA WITNESS MR. PINEGAR STATED THAT
9		TDSIC 2.0 IS EXPECTED TO REDUCE AND SHORTEN OUTAGES.
10		CAN YOU PLEASE PROVIDE MORE DETAIL?
11	A.	Today's utility customers have higher expectations of electric service. With
12		technology-infused lifestyles, they value outage communication and expect
13		24/7/365 power. A self-healing distribution system is the best strategy for
14		satisfying these requirements. While not all outages can be prevented, new
15		technology affords utilities with an opportunity to reduce many outages and
16		shorten them when they inevitably occur. TDSIC 2.0 utilizes a target set of
17		programs that advances our system allowing the grid to adjust the power flow to
18		self-heal when an event occurs, thus avoiding CI and CMI. Hardening and
19		resiliency programs are imperative to a strong sustainable grid, and they are the
20		foundation for system integrity and automation improvements. TDSIC 1.0 and
21		80% of the 2.0 programs focus on maintaining or improving foundational
22		components such as poles, transformers, conductors, etc. After ensuring a strong,

1	hardened system for all our customers, Duke Energy Indiana expects the
2	following programs will provide the most benefit to the customer interruptions
3	and outage minutes avoided: Self Optimizing Grid ("SOG"), which will isolate
4	faults on the backbones of circuits from approximately 1,000 customers per
5	segment to 400 customers per segment, allowing service to be restored to other
6	portions of the circuit; Targeted Underground ("TUG"), which places strategic
7	infrastructure underground to eliminate the source of overhead outages; and
8	Automated Lateral Device ("ALD"), which is targeted to the lateral lines of
9	distribution systems to reclose on temporary faults and isolate those temporary
10	faults to eliminate customer outages. I will discuss each of these programs in
11	greater detail later in my testimony.
12	We expect these programs to improve the experience of Duke Energy
13	Indiana's commercial and industrial customers. Currently, 11% of our Duke
14	Energy Indiana customers are part of a circuit with automation. After the
15	completion of the TDSIC 2.0 Investment Plan, the Company estimates that over
16	65% of customers will be served by automated circuits. These programs focus on
17	fault isolation that will result in less customers impacted and enhanced
18	troubleshooting efficiencies to improve restoration times. Through the planned
19	investments within TDSIC 2.0, customers on these targeted circuits will
20	experience fewer interruptions and reduced outage durations.
21	The TDSIC 2.0 Investment Plan also includes additional installation of
22	technology with near real-time two-way data communication, data collection, and

1		remote operations capability. This will improve Duke Energy Indiana's ability to
2		acquire near real-time system status, pinpoint the location of system trouble,
3		automatically isolate the trouble in many cases, and restore service to our
4		customers more quickly.
5		Further, TDSIC 2.0 programs utilize an Investment Plan Analysis that
6		focuses on project cost benefit ratio to select high value circuits and assets for
7		proactive replacement, which directly correlates to improved system integrity and
8		reduced risk of those assets causing an outage due to failure.
9		With these investments in our infrastructure, we expect that system
10		performance will improve, customer satisfaction will increase, and Duke Energy
11		Indiana will be able to effectively leverage future grid advancements, such as
12		distributed energy resources and storage.
13	Q.	DOES THE TDSIC 2.0 INVESTMENT PLAN BENEFIT FROM ANY
14		LESSONS LEARNED FROM DUKE ENERGY INDIANA'S TDSIC 1.0
15		PLAN?
16	A.	Yes. Every segment of our transmission and distribution business has improved
17		with our TDSIC 1.0 execution. Even with that improvement, we intend to
18		continue the advancement of our work efficiencies. As stated above, we value the
19		rigor and scrutiny involved in TDSIC 1.0 as it has led to positive changes and
20		maturity in both transmission and distribution planning and execution for Duke
21		Energy Indiana. Duke Energy Indiana's supply chain partners have also
22		improved due to the longer lead-time items being engineered in advance. Work

1		planning groups have had the advantage of seeing planned projects and work in
2		advance with greater detail, which is a great advantage when bundling work in the
3		most efficient way for construction resources. Labor contracts have been
4		improved with our ability to commit earlier and communicate longer project work
5		plans for multiple years. Estimating has also improved by building a solid
6		tracking history and a team that understands the impact of changes in standards,
7		contracts, and work methods. Estimating and planning projects in advance also
8		helps strengthen communications with customers and stakeholders. Proactive
9		communications with our customers provide better insight as to when they can
10		expect to see Duke Energy Indiana in the area making improvements to the
11		system. If planned outages are necessary, the upfront communication allows
12		customers the chance to adjust their busy schedules to minimize the temporary
13		impacts of advancing our grid.
14		III. TDSIC 2.0 INVESTMENT PLAN
15	Q.	PLEASE PROVIDE AN OVERVIEW OF THE TDSIC 2.0 INVESTMENT
16		PLAN.
17	A.	TDSIC 2.0 consists of investments in our transmission and distribution systems
18		with a focus on improving reliability, advancing grid hardening and resiliency,
19		enabling expansion of renewable and distributed generation, facilitating economic
20		development, and providing value to our customers. Following is a table that
21		depicts the primary areas of investment and how those investments match up to
22		the overall objectives of TDSIC 2.0.

Distribution Program Categories	Sub-Program	Reliability	Hardening Resiliency	DER Enablement
	Self Optimizing Grid (SOG)	$\checkmark$	✓	✓
	Circuit Visibility & Control (CVC)	√		√
	Capacitor Automation	$\checkmark$		✓
Circuit Backbone	Declared Protection Zone	$\checkmark$	✓	
Reliability Uplift	Integrated Volt Var Control (IVVC)			$\checkmark$
	Inaccessible Right of Way	$\checkmark$	✓	
	Circuit Segmentation	$\checkmark$		
	Limited Access Road Crossing		✓	
	Deteriorated Conductor	$\checkmark$	✓	✓
Overhead Lateral	Automated Lateral Device (ALD)	$\checkmark$		
Reliability Uplift	Targeted Undergrounding (TUG)	$\checkmark$	$\checkmark$	
	Circuit Sectionalization	$\checkmark$		
Inderground System Uplift	Underground System Uplift	$\checkmark$		
4KV Conversion	4kV Conversion	✓	✓	
	GLT Pole Inspect & Replace		✓	
	Switchgear Inspect & Replace		✓	
Inspection Based	Surface Mounted Equipment		✓	
	Inspect & Replace (SMEI)			
	Recloser Replacements	$\checkmark$	$\checkmark$	
Transmission	Sub Brogrom		Hardening	DER
Program Categories	Sub-Program	Reliability	Resiliency	Enablement
	Upgrade T&D Transformers	√	✓	
	SCADA Communications	✓	✓	✓
	Remote Line Sectionalizing	/	1	
	Leaning Chart Dadials Through Evisting	$\checkmark$	✓	
	- LOODING SHORT RADIAIS INFOUGH EXISTING			
	Looping Short Radials Through Existing Transmission Relay Replacements		✓	√
Substation	Transmission Relay Replacements	✓ ✓	✓ ✓	√
Substation Hardening & Resiliency	Transmission Relay Replacements         T&D Transformer Replacements	•		✓ ✓
	Transmission Relay Replacements	√	✓	✓ ✓
	Transmission Relay Replacements         T&D Transformer Replacements         Substation Small Asset Replacements         Replace T&D Circuit Breakers	√ √	√ √	✓ ✓
	Transmission Relay Replacements T&D Transformer Replacements Substation Small Asset Replacements Replace T&D Circuit Breakers Substation Reconfiguration for Improved Reliability	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓	✓ ✓
	Transmission Relay Replacements T&D Transformer Replacements Substation Small Asset Replacements Replace T&D Circuit Breakers Substation Reconfiguration for Improved Reliability Condition Based Monitoring	✓ ✓ ✓	√ √ √	✓ ✓
	Transmission Relay Replacements T&D Transformer Replacements Substation Small Asset Replacements Replace T&D Circuit Breakers Substation Reconfiguration for Improved Reliability Condition Based Monitoring - Transformers and Circuit Breakers	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓	
	Transmission Relay Replacements T&D Transformer Replacements Substation Small Asset Replacements Replace T&D Circuit Breakers Substation Reconfiguration for Improved Reliability Condition Based Monitoring	✓ ✓ ✓ ✓ ✓		✓ 
	Transmission Relay Replacements         T&D Transformer Replacements         Substation Small Asset Replacements         Replace T&D Circuit Breakers         Substation Reconfiguration for Improved Reliability         Condition Based Monitoring         - Transformers and Circuit Breakers         Wood Structures - Wood to Non-Wood         Circuit Rebuilds			
Hardening & Resiliency	Transmission Relay Replacements T&D Transformer Replacements Substation Small Asset Replacements Replace T&D Circuit Breakers Substation Reconfiguration for Improved Reliability Condition Based Monitoring - Transformers and Circuit Breakers Wood Structures - Wood to Non-Wood			
Hardening & Resiliency	Transmission Relay Replacements         T&D Transformer Replacements         Substation Small Asset Replacements         Replace T&D Circuit Breakers         Substation Reconfiguration for Improved Reliability         Condition Based Monitoring         - Transformers and Circuit Breakers         Wood Structures - Wood to Non-Wood         Circuit Rebuilds         Remote Line Sectionalizing - SCADA to Switches         356kV Towers			
Hardening & Resiliency	Transmission Relay Replacements         T&D Transformer Replacements         Substation Small Asset Replacements         Replace T&D Circuit Breakers         Substation Reconfiguration for Improved Reliability         Condition Based Monitoring         - Transformers and Circuit Breakers         Wood Structures - Wood to Non-Wood         Circuit Rebuilds         Remote Line Sectionalizing - SCADA to Switches			
Hardening & Resiliency	Transmission Relay Replacements         T&D Transformer Replacements         Substation Small Asset Replacements         Replace T&D Circuit Breakers         Substation Reconfiguration for Improved Reliability         Condition Based Monitoring         - Transformers and Circuit Breakers         Wood Structures - Wood to Non-Wood         Circuit Rebuilds         Remote Line Sectionalizing - SCADA to Switches         356kV Towers         - Install Intermediate Deadend Structures			
Hardening & Resiliency	Transmission Relay Replacements T&D Transformer Replacements Substation Small Asset Replacements Replace T&D Circuit Breakers Substation Reconfiguration for Improved Reliability Condition Based Monitoring - Transformers and Circuit Breakers Wood Structures - Wood to Non-Wood Circuit Rebuilds Remote Line Sectionalizing - SCADA to Switches 356kV Towers - Install Intermediate Deadend Structures Overhead Ground Wire Replacement			

# 1 Table 1 – TDSIC 2.0 Investment Plan Overview

2

3

The transmission program categories above are represented by sub-

programs for ease of understanding and alignment with TDSIC 2.0 objectives.

1		Please refer to testimony of witness Mr. Martin Dickey for further description of
2		the transmission investment plan. In addition, Ms. Erin Schneider discusses the
3		proposed TED projects.
4		IV. TDSIC 2.0 DISTRIBUTION INVESTMENTS
5	Q.	CAN YOU COMMENT GENERALLY ON THE CHOSEN
6		DISTRIBUTION CAPITAL INVESTMENTS AND THEIR BENEFIT TO
7		INDIANA CUSTOMERS?
8	A.	Yes. First, let me provide some background on Duke Energy Indiana's
9		distribution system. Duke Energy Indiana's distribution system serves over
10		860,000 customers through approximately 22,000 miles of distribution lines,
11		which includes 16,000 miles of overhead lines, 6,000 miles of underground lines,
12		600,000 distribution poles, and 240,000 distribution transformers. Nearly half of
13		the Duke Energy Indiana system assets, such as poles, conductor, and
14		transformers were constructed prior to 1980. This infrastructure is approaching
15		its life expectancy and to sustain the Company's reliability, a portion of this
16		infrastructure will be replaced or rebuilt through this plan. Additionally, there
17		have been significant advancements in technology that can now be deployed to
18		improve system monitoring, operations, and optimization.
19		Through TDSIC 2.0, we chose investments that focus on value to the
20		customer through replacement of the aging assets and expansion of technology.
21		As with most products on the market, the technology available today is simply
22		better than the technology that was available 30-50 years ago. Replacing these

1		first and second-generation technologies with today's advanced technology
2		enables real-time, two-way communications with transmission and distribution
3		assets. This allows Duke Energy Indiana to enable the Distribution Management
4		System ("DMS") and leverage IVVC and Self-Optimizing Grid. It is our
5		experience that these technologies increase the reliability of the system, while also
6		giving Duke Energy Indiana operators visibility into current system conditions.
7		These attributes were not available with older technologies.
8		Duke Energy Indiana will continue to invest in programs that improve the
9		overall state of the grid through reliability, hardening, resiliency, and distributed
10		energy resource enablement. These reliability improvements are designed to
11		proactively reduce the number of outages, minimize the number of customers
12		affected by an outage, improve outage response, as well as, expedite service
13		restoration, all of which contribute to a reduction in the total number of customer
14		minutes interrupted. Some examples of these investments include Self-
15		Optimizing Grid, Targeted Undergrounding, Circuit Sectionalization, Circuit
16		Segmentation, ALD and 4kV Conversion.
17	Q.	HAVE YOU PROVIDED A WORKPLAN THAT SUMMARIZES THE
18		<b>DISTRIBUTION PROJECTS WITHIN TDSIC 2.0?</b>
19	A.	Yes. The TDISIC 2.0 Workplan is broken down into a hierarchy of several
20		exhibits. My first exhibit, Petitioner's Exhibit 2-A (JKL), is the Duke Energy
21		Indiana TDSIC 2.0 Plan Overview, which includes a six-year summary of the
22		TDSIC 2.0 projects and their associated cost estimates. Summary descriptions of

1		the distribution projects can be found later in my testimony. Additional cost
2		detail for the distribution plan projects is found in Petitioner's Confidential
3		Exhibits 2-B (JKL) and 2-C (JKL). I am also providing the distribution workplan
4		in excel format as Confidential Workpaper 1-JKL.
5	Q.	HOW DID DUKE ENERGY INDIANA DETERMINE WHAT PROJECTS
6		TO INCLUDE IN ITS DISTRIBUTION WORKPLAN?
7	A.	Projects were selected based on a variety of engineering analysis and asset data
8		aligning with our TDSIC 2.0 objectives and focused on their improvement to
9		system integrity, reliability, and benefit to our customers. Initial project analysis
10		was developed by first reviewing, at a high-level, all current and future projects,
11		programs, asset types, failure records, outage information, and engineering
12		studies. This aggregation of detail is a result of our internal Asset Management
13		department's ongoing evaluation of system characteristics and advancements in
14		grid technology. A Class 5 estimate was assigned to each potential project. This
15		initial list of investments was then provided to B&V to run through the
16		Investment Plan Analysis and be scored through a cost to benefit ratio by
17		substation. The investment plan in TDSIC 2.0 will be executed by substation and
18		circuit to gain labor resource efficiencies. To align with the execution strategy,
19		projects were evaluated through the Investment Plan Analysis, and with Asset and
20		Project Management teams. Their efforts broke down the work plan model to
21		spread work appropriately, while working to not saturate a given region with too
22		many projects in a given year. This bundling of projects provides our distribution

#### JEREMY K. LEWIS - 17 -

1		workplan as presented in Petitioner's Confidential Exhibit 2-C (JKL), as well as
2		the excel version in Confidential Workpaper 1-JKL.
3	Q.	YOU MENTIONED THE INVESTMENT PLAN ANALYSIS ABOVE,
4		WHAT IS THAT AND HOW DOES THAT SUPPORT THE
5		DISTRIBUTION PROJECTS INCLUDED IN THE TDSIC 2.0
6		INVESTMENT PLAN?
7	A.	The Investment Plan Analysis is the accumulation of all Duke Energy, B&V,
8		Copperleaf, value models, risk models, and optimization efforts together. Projects
9		were identified by Duke Energy Indiana to address known conditions and
10		performance issues on the system, which were then evaluated for consequence
11		and likelihood of failure. Further, opportunities to improve these conditions and
12		enhance functionality through proven automated technologies were also
13		assimilated to put through the Investment Plan Analysis. The Investment Plan
14		Analysis provides an advanced and mature study of Duke Energy Indiana
15		projects. Leveraging system knowledge with the rigorous risk and value studies
16		led us to selecting the projects that provide the most benefit for the cost. In
17		selecting the TDSIC 2.0 investments, approximately \$1.7 billion of potential
18		distribution investments were analyzed through the Investment Plan Analysis,
19		which returned \$775 million of select distribution investments. The Investment
20		Plan Analysis used two funding mechanisms: "optimized" and "reserved." A
21		small portion of the distribution plan was reserved, which simply means subject
22		matter experts held a portion of the funding specifically for these necessary sub-

1		projects. This accounts for projects within Inspection Based, 4kV Conversion,
2		Underground Cable Rehab, and Capacitor Automation. These funding levels
3		were selected using historical analysis of performance, value, and necessity to the
4		TDSIC Objectives. All other projects were optimized in the model. Please refer
5		to the testimony of Mr. James Shields, Petitioner's Exhibit 4 (JWS), along with
6		Petitioner's Exhibit 4-A (the Investment Plan Report) for more information
7		regarding reserved and optimized projects.
8	Q.	MR. LEWIS, CAN YOU MORE SPECIFICALLY DISCUSS THE
9		<b>PROPOSED DISTRIBUTION PROGRAMS IN TDSIC 2.0?</b>
10	А.	The distribution programs are organized around five program categories and
11		eighteen sub-programs, each with a specific program objective: Circuit Backbone
12		Uplift, Overhead Lateral Uplift, Underground System Uplift, 4kV Conversions,
13		and Inspection Based Programs. Please also see Table $1 - TDSIC 2.0$ Investment
14		Plan Overview above.
15		The Circuit Backbone Uplift Category includes eight sub-programs
16		which target circuit enhancements to support circuit modernization, including
17		automation, segmentation, and controlling circuit operations to enable self-
18		optimization. These modernization investments reduce outage impacts with
19		respect to their occurrence frequency, grid impact footprint, recovery time, and
20		cost. Such improvements also have the added value of improving capability to
21		better integrate distributed energy resources on to the grid.

1		The Overhead Lateral Uplift Category includes four sub-programs and
2		is aimed at improving the lateral grid's reliability and resiliency. This program is
3		primarily comprised of projects that add segmentation and automation of the
4		circuit laterals to reduce the number of outages and customers impacted as well as
5		reducing the duration of the outages themselves.
6		The Underground System Uplift Category targets cable rehabilitation
7		for improved reliability.
8		4kV Conversion Category consists of the conversion of risk-prone,
9		legacy standard, and dated architecture of lower operating voltage lines to a 12 kV
10		system to address all three objectives of the Investment Plan.
11		The Inspection-Based Program includes four sub-programs and is a
12		condition-based program geared towards proactively replacing grid hardware and
13		equipment based on their effective age and historical failure rates.
14	Q.	CAN YOU PLEASE EXPAND ON THE DISTRIBUTION SUB-
15		PROGRAMS IN TDSIC 2.0?
16	A.	To achieve the objectives established for TDSIC 2.0, Duke Energy Indiana
17		aligned initiatives under the five distribution investment program categories,
18		which are further divided into eighteen sub-programs, as elaborated below.
19		Sub-Programs address specific initiatives within Program Categories. Below is a
20		brief overview of each sub-program organized by Program Category. Please see
21		Petitioner's Exhibit 4-A (JWS) (TDSIC 2.0 Investment Plan Report) for further
22		detail.

# DUKE ENERGY INDIANA TDSIC 2.0 DIRECT TESTIMONY OF JEREMY K. LEWIS FILED NOVEMBER 23, 2021

2	Self-Optimizing Grid ("SOG")
3	Advanced automation and intelligence are becoming a necessary
4	requirement to manage an increasingly dynamic power delivery system. The
5	Self-Optimizing Grid redesigns key portions of the distribution system and
6	transforms it into a dynamic self-healing network that ensures issues on the grid
7	can be isolated and customer impacts are limited. Self-healing technologies can
8	reduce outage impacts on a circuit by as much as 75 percent. These grid
9	capabilities are enabled by: (1) increasing system "connectivity" by building more
10	circuit ties that allow for more flexibility in restoration options; (2) increasing
11	"capacity" by installing larger wires, transformers, and system banks to be able to
12	handle dynamic switching and expanding two-way power flow from adjacent
13	circuits and renewable generation; and (3) increasing "control" through additional
14	system automation and intelligence. SOG includes upgrades to the Advanced
15	Distribution Management System head end systems and devices such as line
16	sensors, which are used to measure voltage and/or current levels at targeted
17	locations on the Duke Energy Indiana distribution system and transmit those
18	measurements to the Distribution Control Center ("DCC").
19	Circuit Visibility and Control ("CVC")
20	The value to benefit ratio can be cost prohibitive to expand some
21	substations and others sometimes lack physical space for standard enhancements.

Circuit Backbone Uplift

1

22 In some locations it's prudent and effective to install automated switching devices

1	outside the substation to gain circuit visibility and control. This program
2	modernizes the protection providing remote monitoring, control, data acquisition,
3	and improved fault location to Duke Energy Indiana customers and wholesale
4	customers, mostly in the rural areas of Indiana.
5	Inaccessible Right of Way ("IARW")
6	The Inaccessible Right of Way project identifies problematic sections of
7	circuits that, if moved, could provide vast reliability improvement over the
8	existing locations. That section of the circuit will be evaluated for relocation to
9	an area that reduces impact to customers' land, reduces impact to environment,
10	and improves accessibility for restoration and repair. The section of circuit will
11	then be fully rebuilt using current construction standards in the new location. All
12	equipment from the inaccessible right of way will be removed and land restored.
13	Declared Protection Zone ("DPZ")
14	Through outage tracking, a declared protection zone can be identified as a
15	section of a circuit that is experiencing an above average number of specific types
16	of faults, such as equipment failure, lightning strikes and wildlife. This project
17	includes a visual inspection of all identified DPZs, which can range from the
18	substation to the first protective device, from a recloser to the end of the line, or
19	between reclosers on the main line. The DPZ program mitigates future outage
20	events by identifying and correcting probable outage causes. The inspection looks
21	at all aspects of the construction, including clearances and span lengths. Probable

1	outage causes can include connections, arresters, switches, jumpers, system
2	grounds, any damaged equipment, and inadequate Basic Insulation Level ("BIL").
3	Integrated Volt Var Control ("IVVC")
4	IVVC allows the distribution system to optimize voltage and reactive
5	power needs through remotely operated substation and distribution line devices
6	such as voltage regulators and capacitors. These controllable line devices are
7	optimized and operated via a centralized distribution management system. IVVC
8	capabilities enable a grid operator to levelize the voltage profile and then lower
9	distribution voltage as a way of reducing demand, thereby reducing the need to
10	generate or possibly purchase additional power at peak prices or protect the
11	system from exceeding its load limitations. Benefits are achieved through circuit
12	conditioning, which is the process of analyzing circuits and implementing
13	recommended adjustments through optimizing the size and location of capacitor
14	banks and voltage regulators, as well as verifying that the conductor is adequately
15	sized, to sustain required voltage levels on a distribution circuit.
16	The investment in components that enable distribution automation and
17	IVVC will result in customer savings on enabled circuits through a reduction in
18	kWh usage and generation fuel consumed, which provides benefits to all
19	customers, including commercial and industrial customers. All customers will
20	potentially see this benefit through lower electric bills as the savings flow through
21	the fuel adjustment clause rider. The lower fuel consumption will also result in
22	lower generation emissions, thus reducing our environmental carbon footprint.

1	The reduction in kW demand can also result in extending the timeline for
2	constructing future generation facilities. Customers will experience a more
3	levelized voltage profile due to Duke Energy Indiana's ability to monitor the
4	distribution grid in real-time.
5	Capacitor Automation
6	The project replaces legacy capacitor bank controls with modern digital
7	control that is capable of two-way communications to a centralized DMS.
8	Sensors are installed at each capacitor bank to measure current, voltage and power
9	factor through the digital control. This communication capability enables IVVC
10	to control the distribution system voltage profile, while the current and voltage
11	sensors permit Duke Energy Indiana to capture system condition data for load
12	management and service restoration plans. Capacitor Automation projects were
13	not evaluated for scoring in the value framework as they are considered necessary
14	to achieve automation and enablement of other programs such as IVVC.
15	Circuit Segmentation
16	Circuits that were not optimal SOG candidates were evaluated for circuit
17	segmentation using the same segmentation criteria as SOG. Circuit Segmentation
18	improves the reliability of distribution circuits by reducing the number of
19	customers exposed to power outages associated with circuit faults such as cars
20	hitting poles, trees falling into lines, and outages caused by storms. This
21	reduction of exposure is accomplished by adding and/or re-configuring a number
22	of protective devices on mainlines, circuit backbones, and branch circuits. The

1	settings for these protective devices are coordinated to operate in a manner that
2	isolates only the faulted section of a circuit.
3	Limited Access Road Crossings
4	This project ensures compliance with Indiana Department of
5	Transportation ("INDOT") standards as Duke Energy engineers identify and
6	review locations where overhead distribution circuits cross limited access
7	roadways. A limited access road is defined as a road, or portion of a road, where
8	the only access is through on and off ramps at designated entrances or exits, for
9	example, Interstate entrance or exit ramps. It will also allow Duke Energy
10	Indiana to reinforce line across highways to protect the traveling public from
11	safety hazards, reduce the risk of conductor falling into major highways, reduce
12	the risk of power outages, and increase integrity of the system by replacing aging
13	assets.
14	<u>Overhead Lateral Uplift</u>
15	Circuit Sectionalization
16	This is a power outage mitigation project designed to improve the
17	reliability of distribution circuits by adding and/or re-configuring a number of
18	protective devices on overhead lateral circuits. Circuit Sectionalization is a
19	systematic approach whereby additional fuses and protection devices are added to
20	an existing circuit. This reduces the number of customers affected by an outage.
21	Currently, a single set of fuses protect upstream customers from experiencing an
22	outage, but with Circuit Sectionalization several additional protective devices are

1	installed. This fuse coordinated approach keeps a circuit segment issue at the end
2	of the circuit from affecting more customers upstream. This program also reduces
3	outage duration because the length of the line that requires troubleshooting is
4	reduced allowing for a more accurate pinpointing of the outage and more efficient
5	restoration. Circuit sectionalization is vital to reliability targets as the Company
6	continues to invest in programs to reduce customer minutes interrupted.
7	Deteriorated Conductor Replacements
8	Duke Energy Indiana has many miles of overhead distribution conductors
9	greater than 50 years old that are showing signs of deterioration. Most of these
10	conductors are small diameter Copper Wire ("CW") or small diameter Aluminum
11	Conductor Steel Reinforced ("ACSR") that have a higher failure rate than other
12	conductors. This project replaces targeted unreliable conductors with more
13	reliable heavier gage industry standard aluminum wire. Replacing smaller and
14	older technology wire with larger newer technology wire provides greater
15	reliability in both current carrying ability and life expectancy of the conductor.
16	The most commonly replaced wires are # 8 CW, # 4 ACSR, and # 2 ACSR.
17	Automated Lateral Device (ALD)
18	This program focuses on selectively replacing protective tap line fuses
19	with small electronic reclosing devices on segments that can eliminate a
20	significant number of sustained interruptions for customers on these taps. These
21	devices serve to prevent customer outages by allowing temporary power line
22	faults time to clear before reclosing, resulting in a targeted momentary

1	interruption instead of a sustained outage, thus eliminating unnecessary use of
2	resources (inventory, time, gasoline, etc.).
3	Targeted Underground ("TUG")
4	This is a strategic program that targets outage-prone rear-lot, heavily
5	vegetated lines for conversion to underground service. TUG projects typically
6	target "end of feeder" customers who are often low on the priority list for
7	restoration during storm events. TUG lines are selected by reviewing 10 year
8	outage history and identifying line segments that meet TUG criteria, which
9	include (1) approximately two times worse reliability than average, (2) mostly
10	residential areas, and (3) heavily vegetated rear-lot overhead lines which are
11	difficult to access and maintain.
12	The goal of the TUG selection process is to maximize the number of
13	outage events eliminated. Converting outage prone parts of the system from
14	overhead to underground enables Duke Energy Indiana to restore service more
15	quickly and cost effectively for all customers. Addressing areas with outlier
16	outage performance improves service while lowering maintenance and restoration
17	costs for all customers.
18	Underground System Uplift
19	The underground system uplift program targets cable rehabilitation for
20	improved reliability. Duke Energy Indiana currently has approximately 8,000
21	miles of underground cable installed. The cable assessment/cable replacement
22	project identifies medium voltage underground cables nearing end of life, at least

1	25 years or older. Using a complete list of Duke Energy Indiana circuits, our					
2	engineers used historical Geospatial Information System ("GIS") data to identify					
3	these segments. These segments will undergo a third-party cable assessment					
4	which identifies cable and components in pre-failure conditions. When the cable					
5	assessment results show the cable or cable splice is in pre-failure condition the					
6	cable or components will be replaced to restore reliability to the circuit. The					
7	assessment allows for the identification of cable sections that have the same level					
8	of integrity as new cable and will perform as new cable for a 25-year period.					
9	Assessing older cable is a cost efficient and reliable option helping to extend the					
10	life and reliability of the Company's cable systems.					
11	<u>4kV Conversion</u>					
12	The 4kV Conversion program is an important component of TDSIC 2.0,					
13	which is proposing to replace aging and obsolete infrastructure with Company-					
14	standard 12kV equipment. There are 43 4kV circuits on the Duke Energy Indiana					
15	system with aged equipment ranging from the substation transformer to the					
16	customer. 27 of the 43 4kV circuits are being converted with this TDSIC					
17	investment. Benefits of the 4kV conversion program include:					
18	1) Increased reliability by installing additional line recloser					
19	2) Elimination of aged end of life equipment, which has become less					
20	reliable and is difficult to replace because the equipment is no longer					
21	manufactured.					

1	3) Upgraded circuits can join in with neighboring standard 12kv circuits
2	to create a more networked grid with self-healing capabilities, instead
3	of being constrained to only adjacent 4kv circuit pairs. With upgraded
4	equipment and lines, the Company has an increasingly more resilient
5	system with greater flexibility in restoration options.
6	4) Currently, 4kv substations and circuits have a limited ability to accept
7	distributed energy resources, such as solar. By upgrading the circuits
8	to current standards, the infrastructure will be able to support the two-
9	way power flow; a requirement for increasing distributed energy
10	resources.
11	Inspection Based Programs
12	Ground Line Treatment ("GLT") Pole Inspect and Replace
13	This project replaces or structurally modifies defective distribution poles
14	and pole components identified during annual pole inspections. This involves the
15	inspection of distribution wood poles, cross arms, insulators, and minor
16	equipment for ground line decay, above ground decay, pole top damage, or other
17	defects that threaten the structural integrity and reliable condition of the pole
18	location.
19	Surface Mount Equipment Inspect and Replace ("SMEI")
20	This project is specifically focused on examining the external enclosure
21	integrity, pad integrity, safety/clearance signage, locking mechanism integrity,
22	and general safe operations of pad mounted equipment. The equipment includes

1	pad mounted transformers, switchgear, meter panels, and switching cabinets.
2	Further this program will proactively replace live-front transformers with the
3	newer standard, dead front transformers.
4	Switchgear Inspect and Replace
5	The General Switchgear Replacement project proactively inspects and
6	replaces aged equipment, prior to failure. There are approximately 1,100
7	switchgears in Duke Energy Indiana's service territory. On average, 54
8	switchgears are inspected per year looking for signs of wear and functionality of
9	the equipment, such as bad terminations, non-operative parts, deteriorated
10	cabinets, possible hazards, and targeted replacement of older switchgear such as
11	Malton and live-front switchgear. An infrared/thermal scan is also used to
12	identify potential failures that are not visible to the naked eye. Historically, an
13	average of fifteen units are identified per year as needing replacement. The work
14	is performed in a planned manner to minimize customer impact and extensive
15	outages.
16	Recloser Replacements
17	As a recloser operates over a period of time, its gaskets degrade and allow
18	moisture and other pollutants to contaminate oil or degrade functionality.
19	Climate, use, and operating conditions also impact a recloser's electrical and
20	mechanical components, contributing to its rate of decline. Proactively inspecting
21	and replacing hydraulic reclosers enhances the system by ensuring devices
22	perform properly, rapidly, and reliably to clear faults. This project replaces aged

1	electrical and oil filled reclosers with new or refurbished units to ensure proper
2	operation of the equipment.

Q. PLEASE DISCUSS THE DISTRIBUTION PROGRAMS THAT WILL
 FACILITATE EXPANSION OF SOLAR AND RENEWABLES AND HOW

5 THIS WILL BENEFIT DUKE ENERGY INDIANA CUSTOMERS.

A. Distribution has five main programs that contribute to the enablement of
expanding solar. These programs are SOG, CVC, Capacitor Automation, IVVC,
and Deteriorated Conductor.

9 SOG allows reconfiguring of circuits to match load to production, and it 10 supports two-way power flow that is associated with significant penetration of 11 distributed energy resources on a circuit. In particular, during shoulder seasons 12 which have more temperate weather and light load demand, high adoption circuits 13 can produce more power than is locally needed. SOG automation and rerouting 14 capability will allow the company to match load to that production. This has 15 several benefits, one of which is locally produced power can be quickly rerouted 16 to local neighborhoods on adjacent circuits, which reduces line losses. This also 17 reduces localized high voltage issues during periods of overproduction. These 18 renewable benefits from SOG are created by (1) increasing system "connectivity" 19 by building more circuit ties that allow for more flexibility in restoration options, 20 (2) increasing "capacity" by installing larger wires, transformers, and system 21 banks to be able to handle dynamic switching and expanding two-way power flow

1	from adjacent circuits and renewable generation, and (3) increasing "control"
2	through additional system automation and intelligence.
3	Circuit Visibility and Control also plays a role in the greater distributed
4	generation picture by providing remote and/or automated grid operation and real
5	time situational awareness. These factors combined with existing DMS
6	infrastructure enhances distributed energy resource readiness and provides a
7	positive cost benefit analysis.
8	Automating capacitor banks helps to dynamically manage voltage and
9	VAR conditions, minimizing line losses. These investments complete our eight-
10	year capacitor automation effort which facilitates us to perform IVVC.
11	IVVC is the primary renewable and distributed energy resource benefit
12	driver as it adapts well to the on and off nature of solar power systems due to
13	overproduction concerns in shoulder seasons as well as intermittent cloud cover.
14	IVVC circuits target operation in the middle of the voltage band, providing more
15	headroom for voltage rise during those shoulder seasons while at the same time
16	minimizing line losses, maximizing the value of locally produced power from
17	distributed generation.
18	The deteriorated conductor sub-program also supports distributed energy
19	resource enablement as it improves line connectivity and upgrading the wire size
20	conforms to that latest standards which transmits more power upstream in support
21	of distributed energy resources.

1		Collectively, the TDSIC 2.0 Plan distribution capital investments leverage
2		grid automation, data management and automated grid sensors, and
3		communication and response capability to effectively integrate a greater
4		proportion of renewable and distributed energy resources across its distribution
5		grid network, while improving grid reliability, economic performance and
6		customer choice. As distributed generation grows on the system, a strong,
7		reliable and increasingly resilient distribution system is needed to efficiently
8		integrate those resources.
9	Q.	PLEASE DISCUSS HOW THE DISTRIBUTION PROGRAMS ABOVE
10		SUPPORT THE OBJECTIVE OF HARDENING AND RESILIENCY AND
11		BENEFIT DUKE ENERGY INDIANA CUSTOMERS AS A WHOLE?
12	A.	Eleven of the sub-programs improve grid hardening and resiliency; SOG,
13		Declared Circuits, IARW, Limited Access, Deteriorated Conductor, TUG, 4kV,
14		GLT, SMEI, Switchgear, and Recloser Replacements. These efforts replace or
15		upgrade aged infrastructure with modern materials and new technology that
16		strengthen the distribution system to better withstand extreme weather events,
17		enable better monitoring and control, and lead to future support of more
18		distributed energy resources, all of which allow the system to recovery quickly
19		from the inevitable fault event. Because many of the programs included in the
20		TDSIC 2.0 Plan will be implemented throughout the Company's service territory,
21		ultimately every customer will benefit from efficiencies and system hardening.
22		The TDSIC 2.0 Plan programs allow Duke Energy Indiana to take a holistic,

1		coordinated approach to addressing these identified areas of concern, in contrast
2		to a reactive strategy.
3	Q.	PLEASE DISCUSS THE DISTRIBUTION PROGRAMS THAT WILL
4		IMPROVE RELIABILITY AND HOW THIS WILL BENEFIT DUKE
5		ENERGY INDIANA CUSTOMERS.
6	A.	Thirteen of the eighteen sub-programs contribute to reliability benefits. In
7		summary, these sub-programs are SOG, CVC, Capacitor Automation, Declared
8		Protection Zone, Inaccessible Right of Way, Circuit Segmentation, Deteriorated
9		Conductor, ALD, TUG, Circuit Sectionalization, Underground System Uplift,
10		4kV Conversion, Recloser Replacements. As stated above, the Company intends
11		to improve reliability through the utilization of these programs in the TDSIC 2.0
12		Investment Plan that will help transform the system to a dynamic smart-thinking
13		and self-healing grid that will reroute power around faults, help to quickly locate
14		faults and restore power more quickly to our customers, thus avoiding CI and
15		CMI both on MED and non-MED.
16		V. OVERALL TDSIC 2.0 INVESTMENT PLAN COST ESTIMATES
17	Q.	HAS DUKE ENERGY INDIANA PROVIDED A DETAILED COST
18		ESTIMATE FOR EVERY PROJECT IN THE TDSIC 2.0 INVESTMENT
19		PLAN?
20	A.	Yes. The high-level cost information for the TDSIC 2.0 Investment Plan can be
21		found in Petitioner's Exhibit 2-A (JKL). Petitioner's Confidential Exhibit 2-B
22		(JKL) contains additional detail related to the Distribution Circuit Upgrade project

#### DUKE ENERGY INDIANA TDSIC 2.0 DIRECT TESTIMONY OF JEREMY K. LEWIS FILED NOVEMBER 23, 2021

1	costs, with the complete Distribution Circuit Project Workplan presented in
2	Petitioner's Confidential Exhibit 2-C (JKL) and Petitioner's Confidential
3	Workpaper 1-JKL. Specific detail down to the year and cost driver for substation
4	and transmission line work can be found in Petitioner's Confidential Exhibit 3-A
5	(MDD), and Petitioner's Confidential Workpapers 1-MDD and 2-MDD.
6	Economic Development estimates can be found in Petitioner's Confidential
7	Exhibit 5-E (ENS).

Duke Energy Indiana - TDSIC 2.0 System Improvement Plan				
Line	Project Category	2023 - 2028		
No.		Capital	Project O&M	Cap & O&M Total
1	Distribution System Circuit Improvements	\$704,060,933	\$108,273,358	\$812,334,291
2	Distribution System Substation Improvements	\$176,965,506	\$41,837	\$177,007,344
3	Total Distribution - Contingency	\$155,475,254	\$0	\$155,475,254
4	Total Distribution System Improvements	\$1,036,501,694	\$108,315,195	\$1,144,816,889
5	Transmission System Line Improvements	\$494,662,048	\$22,610,931	\$517,272,980
6	Transmission System Substation Improvements	\$198,038,203	\$0	\$198,038,203
7	Total Transmission - Contingency	\$122,241,221	\$0	\$122,241,221
8	Total Transmission System Improvements	\$814,941,472	\$22,610,931	\$837,552,403
9	Total TDSIC 2.0 Improvements	\$1,851,443,166	\$130,926,126	\$1,982,369,292
10	Targeted Economic Development - Identified Projects	\$44,143,497	\$0	\$44,143,497
11	Targeted Economic Development - Potential Transmission Improvements	\$90,000,000	\$0	\$90,000,000
12	Total Targeted Economic Development - Contingency	\$23,672,382	\$0	\$23,672,382
13	Total Improvement Plan	\$2,009,259,044	\$130,926,126	\$2,140,185,171

8

# 9 Q. HOW DID DUKE ENERGY INDIANA DERIVE THE COST ESTIMATES

10 **FOR TDSIC 2.0**?

1	A.	Duke Energy Indiana has spent significant time and resources putting together
2		cost estimates for every project identified within TDSIC 2.0. We utilized the
3		Association for the Advancement of Cost Engineering International ("AACE")
4		standards and our own Duke Energy Project Management Center of Excellence
5		guidelines for developing TDSIC 2.0 cost estimates. At a high level, cost
6		estimates are derived utilizing either engineered work, built up estimates, or
7		parametric modeling.
8		Each project identified in TDSIC 2.0 is estimated based on asset or
9		compatible unit using historical values, subject matter expertise and reviewed by
10		B&V. We have high confidence in our estimating process through utilizing the
11		AACE standards and through Duke Energy's experience estimating similar
12		projects. AACE is recognized internationally as the technical authority in cost
13		and schedule management for programs, projects, products, assets, and services.
14		The following is a brief definition of each Class of estimate:
15		• Class 2 - Engineering 30% to 70% complete, detailed unit cost, -15% to
16		+20% estimating accuracy
17		• Class 3 – Engineering 10% to 40% complete, semi-detailed unit cost, -
18		20% to +30% estimating accuracy
19		• Class 4 – Engineering 1% to 15% complete, parametric models from
20		historical cost estimates, -30% to +50% estimating accuracy
21	Q.	CAN YOU EXPLAIN THE COST ESTIMATING PROCESS IN DETAIL?

1	A.	Yes. As part of the of the initial TDSIC 2.0 Workplan described above, a Class 5
2		estimate was assigned to each potential project. This is the initial list of
3		investments that ran through the Investment Plan Analysis and was scored
4		through a cost benefit ratio by substation. Once projects were evaluated through
5		the Value Framework, Asset and Project Management teams then studied the
6		work plan model to spread work appropriately, while working to not saturate a
7		given region with too many projects in a given year. This provided our Annual
8		Work Plan.
9		Utilizing the Annual Work Plan and the AACE guidelines mentioned
10		above, engineering was performed and the majority of years one and two
11		achieved Class 2 status for the projects within TDSIC 2.0. Outer years are
12		considered Class 3 or Class 4. Note that a few projects were identified as Class 3
13		in 2023/2024 for distribution. This is due to the nature of inspection based or
14		work that requires cable testing. We have well-supported parametric and
15		historical models to substantiate a AACE Class 3 estimate for these programs.

#### DUKE ENERGY INDIANA TDSIC 2.0 DIRECT TESTIMONY OF JEREMY K. LEWIS FILED NOVEMBER 23, 2021

## Figure 1. Estimating Approach – AACE Standards

1

Class of Estimate	Class 5	Class 4	Class 3	Class 2	Class 1
% Design Complete (Level of Scope Definition)	0% to 2%	1% to 15%	10% to 40%	30% to 70%	50% to 100%
Typical Cost Estimate Methodology	Capacity Factored, Parametric Models, Judgement, or Analogy	Equipment Factored or Parametric Models	Semi-Detailed Unit Costs with Assembly Level Line Items	Detailed Unit Cost with Contract Expected Cost	Detailed Unit Cost with Detailed Invoice Forecast
Expected Range Boundaries	H: +30% to +100%	H: +20% to +50%	H: +10% to +30%	H: +5% to +20%	H: +3% to +15%
(Variation in Estimate to Complete - \$)	L: -20% to -50%	L: -15% to -30%	L: -10% to -20%	L: -5% to -15%	L: -3% to -10%

Distribution	Sub-Program	2023	2024	2025	2026	2027	2028	
Program Categories			-			-		
	Self Optimizing Grid (SOG)	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
	Circuit Visibility & Control (CVC)	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
	Capacitor Automation	Class 2	Class 2					
Circuit Backbone	Declared Protection Zone	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
Reliability Uplift	Integrated Volt Var Control (IVVC)	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
	Inaccessible Right of Way			Class 4	Class 4		Class 4	
	Circuit Segmentation - Backbone	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
	Limited Access Road Crossing		Class 2	Class 4	Class 4	Class 4	Class 4	
	Deteriorated Conductor	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
Overhead Lateral	Automated Lateral Device (ALD)	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
Reliability Uplift	Targeted Undergrounding (TUG)	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
	Circuit Sectionalization - Lateral	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
Underground System Uplift	Underground System Uplift	Class 3	Class 3	Class 4	Class 4	Class 4	Class 4	
4KV Conversion	4kV Conversion	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
	GLT Pole Inspect & Replace	Class 3	Class 3	Class 4	Class 4	Class 4	Class 4	
	Switchgear Inspect & Replace	Class 3	Class 3	Class 4	Class 4	Class 4	Class 4	
Inspection Based	Surface Mounted Equipment Inspect & Replace (SMEI)	Class 3	Class 3	Class 4	Class 4	Class 4	Class 4	
	Recloser Replacements	Class 2	Class 2	Class 4	Class 4	Class 4	Class 4	
Transmission								
Program Categories	Sub-Program	2023	2024	2025	2026	2027	2028	
	Upgrade T&D Transformers							
	SCADA Communications							
	Remote Line Sectionalizing							
	- Looping Short Radials Through Existing Substations							
	Transmission Relay Replacements							
Substation	T&D Transformer Replacements	Class 2	Class 2		Cla	ss 4		
Hardening & Resiliency	Substation Small Asset Replacements		C1033 2					
	Replace T&D Circuit Breakers							
	Substation Reconfiguration for Improved Reliability							
	Condition Based Monitoring							
	- Transformers and Circuit Breakers							
	Wood Structures - Wood to Non-Wood Replacement							
	Circuit Rebuilds							
	Remote Line Sectionalizing - SCADA to Switches							
	356kV Towers							
Line	- Install Intermediate Deadend Structures	Class 2	Class 2		Cla	cc /		
Hardening & Resiliency		Class 2	Class 2 Class 4					
	Overhead Ground Wire Replacement							
	Towers - Cathodic Protection							
	Towers - Tower Replacement							
	Wood Structures - Cross Arm Replacement							

1		Our cost estimates are also informed by historical experience with similar projects
2		and performed in accordance with industry standards. They are the best estimate
3		of costs, as required under the TDSIC statute.
4	Q.	IS CONTINGENCY INCLUDED IN THE PROJECT COST ESTIMATES?
5	A.	Yes. Contingency is included in the total project category estimates as per the
6		Association for the Advancement of Cost Engineering ("AACE") recommended
7		practices. Contingency is added to the base cost estimates of the project to cover
8		estimate uncertainty and risk.
9		AACE defines contingency as an amount added to an estimate to allow for
10		items, conditions, or events for which the state, occurrence, or effect is uncertain
11		and that experience shows that it will likely result in aggregate, additional costs.
12		For projects that extend over multiple years, such as in our proposed
13		TDSIC 2.0 investment plan, there are many possible risks and uncertainties that
14		could trigger and cause project cost increases. This likelihood must be recognized
15		in a fully transparent cost estimate for TDSIC 2.0.
16	Q.	WHAT IS THE PROJECT CONTINGENCY AMOUNT IN TDSIC 2.0?
17	A.	TDSIC 2.0 contingency amount was determined to be 15% based on the detailed
18		risk analysis; TDSIC 1.0 was 11% of the seven-year cost. In TDSIC 1.0 all the
19		contingency is forecasted to be allocated due to discrete project risks that
20		triggered as well as price increases for labor and material that exceeded the 3%
21		escalation per year assumption. Due to the length of time between the TDSIC 2.0
22		estimates, 2021 and the end of the program in 2028, many uncertainties exist.

1		Changes in work processes along with labor and material price uncertainty could
2		result in project actuals greater than expected 2021 values.
3	Q.	HOW IS CONTINGENCY ALLOCATED ACROSS THE PROJECTS?
4	A.	Contingency is broken out for each year and separated by distribution and
5		transmission FERC account as shown in Petitioner's Exhibit 2-A (JKL).
6	Q.	HOW WAS CONTINGENCY CALCULATED?
7	A.	Contingency includes risk and estimate uncertainty. The contingency is the result
8		of the Monte Carlo simulation. Risks and uncertainty events were identified by
9		the project teams and subject matter experts. Each risk/project was assigned a
10		probability and cost impact for best-case, most likely, and worst-case scenarios.
11		The model runs for 1,000 iterations. The resulting value was then selected for the
12		contingency.
13	Q.	WHAT HAPPENS TO CONTINGENCY IF IT IS NOT USED?
14	A.	Since projects go into service each year, contingency is broken out for each year.
15		However, contingency is a six-year plan value. For example, if contingency is
16		found to be needed to a lesser extent than expected in year one the remaining
17		amount would extend to future years to account for ongoing risk that are more
18		backend loaded to a plan of this scale.
19	Q.	WHAT IS THE DIFFERENCE BETWEEN CONTINGENCY AND THE
20		AACE CLASS ESTIMATE RANGES?
21		Contingency is added to the base cost estimate of the project to cover estimate
22		uncertainty and risk. Contingency is part of the expected case value at P50. The

1		AACE class estimate ranges are applied to the expected case estimate including
2		contingency based on the level of project definition. As the level of project
3		definition rises, an example would be an increase in the level of engineering
4		complete, the estimate class changes, and the expected accuracy range applied to
5		the single point estimate is tightened. The ranges for estimate classes represent
6		P10 (90% chance that the cost will be exceeded) to P90 (90% chance that cost
7		will not be exceeded). Typically, the P50 value that includes the single point
8		estimate with contingency is selected as the expected value.
9	Q.	IS IT COMMON ESTIMATING PRACTICE TO INCLUDE BOTH
10		CONTINGENCY AND THE APPLICATION OF CLASS ESTIMATE
11		RANGES?
12	A.	Yes. This is addressed in the AACE International Recommended Practice No.
13		18R-97, it states, "typical variation in low and high ranges after the application of
14		contingency (determined at a 50% level of confidence). Typically, this represents
15		about 80% confidence that the actual cost will fall within the bounds of the low
16		and high ranges. The estimate confidence interval or accuracy range is driven by
17		the reliability of the scope information available at the time of the estimate in
18		addition to the other variables and risk identified above."
19	Q.	IS DUKE ENERGY INDIANA REQUESTING THE RECOVERY OF O&M
20		EXPENSE RELATED TO ITS DISTRIBUTION INVESTMENTS?
21	A.	Yes. There is direct, project O&M related to some of the capital projects in
22		TDSIC 2.0. This is the O&M that is incurred while the capital project is under

1		construction. These estimates are included in Petitioner's Exhibit 2-A (JKL). It
2		is my understanding that inclusion of this type of project-related O&M is
3		provided for in the TDSIC Statute.
4	Q.	IS THIS O&M INCLUDED IN THE COST ESTIMATE FOR EACH
5		PROJECT?
6	A.	Yes. Any direct project O&M related to a capital project is included in the cost
7		estimate. This is standard practice in the utility industry.
8	Q.	IS DUKE ENERGY INDIANA REQUESTING THE RECOVERY OF ANY
9		<b>VEGETATION REMOVAL ASSOCIATED WITH TDSIC 2.0?</b>
10	A.	Yes. There is direct, project-related vegetation removal related to some of the
11		capital projects in TDSIC 2.0. This is the vegetation removal necessary to
12		perform the capital project construction. These costs are included in the estimate
13		and are provided for in the TDSIC Statute. Further, these costs are not being
14		recovered elsewhere through rates.
15	Q.	DID ANY THIRD PARTY VERIFY DUKE ENERGY INDIANA'S COST
16		ESTIMATING PROCESS?
17	A.	Yes. The B&V team and their AACE Certified Engineer conducted an
18		independent review of Duke Energy Indiana's TDSIC 2.0 investment plan cost
19		estimates and estimating process. The details of their review are included with
20		the testimony of B&V's witness, Mr. Jim Shields.
21		VI. <u>B&amp;V REVIEW</u>
22	Q.	WHAT WAS B&V's ROLE IN THIS TDSIC 2.0 FILING?

1	A.	B&V was brought in as a third party to further evaluate and validate Duke
2		Energy's transmission and distribution project selections, estimates, and economic
3		impact.
4	Q.	PLEASE EXPAND ON HOW B&V HELPED WITH VALIDATION OF
5		THE ESTIMATED PROJECTS IN THE TDSIC INVESTMENT PLAN.
6	A.	As stated above, B&V evaluated our estimating strategy by reviewing cost
7		estimates and verifying class estimates are in alignment with AACE standards.
8		B&V concluded that the process Duke Energy Indiana used for TDSIC 2.0 project
9		cost estimating was reasonable and within the typical band of uncertainty seen
10		across the industry for capital planning and cost forecasting purposes. For the
11		review, B&V selected projects and Duke Energy Indiana provided the detailed
12		material and labor estimates for specific planned projects that provide a line-item
13		breakdown of costs that include quantities, materials, and labor costs. For these
14		estimates, B&V independently developed similar detailed cost estimates, using
15		B&V estimating tools and historical labor and material costs and the same
16		detailed scope breakdown used by Duke Energy Indiana. After the line-item
17		estimates were developed, B&V compared the total estimate to Duke Energy
18		Indiana's estimate to calculate a percent difference and assess the reasonableness
19		of the estimate. In reviewing Duke Energy Indiana's cost estimating process,
20		B&V held detailed discussions reviewing the different transmission and
21		distribution cost estimating models and approach used to the develop TDSIC 2.0
22		cost estimates. More detail on the B&V cost estimating review can be found in

#### JEREMY K. LEWIS - 43 -

1		the testimony of Mr. James Shields and Confidential Exhibit 4-B (JWS). For all
2		of the reviewed sample projects, the cost estimate workbooks, backup
3		documentation, and detail of these documents are consistent with the AACE class
4		level that Duke Energy Indiana states in TDSIC 2.0.
5	Q.	PLEASE DESCRIBE THE INVESTMENT PLAN ANALYSIS AND B&V
6		INVOLVEMENT IN SCORING AND EVALUATING PROJECTS.
7	A.	Duke Energy Indiana set forth a goal in the TDSIC 2.0 Investment Plan to assess
8		project value and select projects that provide a positive cost benefit ratio. B&V
9		helped by combining Copperleaf's Decision Analytics, their Value Model and the
10		B&V proprietary RAPP model. This comprehensive and rigorous process
11		produced a calculated net value, benefits mapping, and value measures that
12		ultimately provides a cost benefit ratio by project. This led to selecting the
13		programs and projects best suited and most cost effective in reaching the TDSIC
14		2.0 Investment Plan objectives. The overall process is referred to as the
15		Investment Plan Analysis and is described in detail by Mr. Shields testimony and
16		Petitioner's Exhibit 4-A, The Investment Plan report.
17	Q.	PLEASE EXPLAIN THE ECONOMIC IMPACT STUDY PERFORMED
18		ON THE TDSIC 2.0 INVESTMENT PLAN?
19	A.	Along with the benefits discussed to improve and modernize the Duke Energy
20		Indiana grid systems, TDSIC 2.0 is also expected to provide secondary benefits to
21		the state by generating additional economic activity. An economic impact study
22		was performed by the Indiana Business Research Center ("IBRC") at Indiana

1		University's Kelley School of Business to assess the secondary economic impacts
2		to Indiana from the proposed TDSIC 2.0 investments. To summarize, IBRC
3		found that for the six-year duration of the TDSIC 2.0 Investment Plan, excluding
4		TED and contingency, Duke Energy Indiana will contribute an estimated \$1.04
5		billion in compensation in Indiana and approximately \$1.29 billion in gross
6		domestic product.
7		Studies like this are widely used by the electric sector to measure such
8		benefits in the areas of employment, income, value added, wages, federal taxes,
9		and state/local taxes. Inputs of the TDSIC 2.0 plan such as project types,
10		locations, and spending levels help IBRC to analyze the full employment footprint
11		of the TDSIC 2.0 plan. Using aggregated production, employment, and trade data
12		from local, regional, and national sources along with the Duke Energy Indiana
13		project inputs gives IBRC insight into economic factors such as supply chain,
14		construction, and engineering jobs in the area to support the TDSIC 2.0 plan. The
15		results of the IBRC economic impact study are described in Petitioner's Exhibit
16		2-D (JKL).
17		VII. TDSIC 2.0 INVESTMENT PLAN UPDATES AND FLEXIBILITY
18	Q.	PLEASE DESCRIBE HOW TDSIC 2.0 WILL BE UPDATED.
19	A.	Any long-term plan will need to be updated as time proceeds. The TDSIC statute
20		provided for this by requiring updates in the TDSIC rider proceedings. At this
21		point, Duke Energy Indiana plans to continue filing its TDSIC rider on a semi-
22		annual basis, so we would be updating the TDSIC 2.0 Workplan in the Fall and

1	filing recovery in the Spring. The work plan is created based on today's best
2	information of future locations and identified for all six years of the TDSIC 2.0
3	plan. The work plan will be progressively expounded, based on system
4	conditions, and communicated annually to the Commission. Units in the project
5	may be susceptible to change, especially in outer years, due to the most current
6	evaluations of system needs. Change order processes and internal approval
7	requirements are in place to ensure both system requirements and customer
8	benefits are validated for any change request. As with TDSIC 1.0, in addition to
9	updating project costs, schedule, and benefits, there could be a need to move
10	projects forward and back in TDSIC 2.0 and, to a lesser extent, even to move
11	some projects in to or out of the Active Plan (i.e. the TDSIC 2.0 projects
12	previously identified) to an Alternate list of projects. New governance, standards,
13	technology, load/system changes, and reliability can change over a six-year
14	period. As these change, Duke Energy Indiana understands the value of
15	continuously evaluating the benefit of projects to the customer and the system.
16	One way we have mitigated the likelihood of change is by including an
17	Alternate List of projects in several categories of work. The Alternate List, as in
18	TDSIC 1.0, is a list of projects that were analyzed in the Investment Plan Analysis
19	but were not selected for inclusion of the current TDSIC 2.0 Active Plan. As you
20	may expect, many projects have very close scores and there are variety of system
21	conditions that can lead to a project's score improving or decreasing over time.
22	Having these alternate projects available for continuous study allows the project

1	team to evaluate the appropriate projects for customer and system needs in a
2	given year. For instance, a Declared Circuit project scheduled for the year three
3	execution in the Active Plan could be evaluated prior to execution and determined
4	to be of lessor value compared to a Declared Protection Zone on the Alternate
5	List. In this case, the project team would submit an internal change order
6	justifying the exchange of the projects from the Active Plan to the Alternate List
7	and vice versa. Petitioner's Confidential Exhibit 2-C (JKL) and Confidential
8	Workpapers 1-MDD and 2-MDD include these Alternate List projects, which are
9	identified by Substation and Circuit.
10	The Company would like the Commission to designate the projects on the
11	Alternate List as eligible projects, so that in future TDSIC rider filings, the
12	Company would have the option of moving projects on to and off of the Alternate
13	List and the Active Plan as necessary for the greatest benefit to the system and
14	customers. This flexibility was extremely beneficial in the TDSIC 1.0 plan, as it
15	allowed us to meet the contemplated scope of the overall plan, even if certain
16	projects fell out to the alternate list because their scope was expanded, an outage
17	was not available, or the costs increased substantially. Duke Energy Indiana
18	commits that the overall costs of TDSIC 2.0 would not be substantially changed
19	by substituting these alternate plans. The Company suggests that if the overall
20	investment plan is tracking under its expected cost, it is prudent and beneficial to
21	customers to insert projects off the Alternate List into the Active Plan to create

1		additional customer value while staying under the overall cost estimate and within
2		the 1% customer annual rate increase.
3		Finally, there could arise a major project category addition or major shift
4		in priorities in the six-year period; in that event, the Company would work with
5		the Commission, the Office of the Utility Consumer Counselor and the
6		intervening parties to develop an acceptable review procedure or changes to the
7		TDSIC 2.0 plan as provided for in the statute.
8		VIII. OVERALL TDSIC 2.0 INVESTMENT PLAN SUMMARY
9	Q.	PLEASE ADDRESS ANY QUANTIFIABLE BENEFITS TO THE
10		<b>OVERALL TDSIC 2.0 INVESTMENT PLAN?</b>
11	A.	At the completion of the TDSIC 2.0 period, the reliability of the Duke Energy
12		Indiana system will improve with the full implementation of the programs
13		described above. We are quantifying reliability performance through Customer
14		Interruptions avoided and Customer Minutes Interrupted avoided. Duke Energy
15		Indiana estimates there is an 80% probability we will avoid between 22 and 45
16		million Customer Minutes Interrupted and avoid between 149k and 249k
17		Customer Interruptions upon the conclusion of our TDSIC 2.0 investments.
18		Based on a historical five-year average, all things being equal, we expect TDSIC
19		2.0 to produce a minimum 19% improvement to System Average Interruption
20		Duration Index ("SAIDI"), and a minimum 17% improvement to System Average
21		Interruption Frequency Index ("SAIFI"). The 80% probability factor is based on

#### DUKE ENERGY INDIANA TDSIC 2.0 DIRECT TESTIMONY OF JEREMY K. LEWIS FILED NOVEMBER 23, 2021

1 variables outside of TDSIC 2.0 such as increased vehicle accidents, invasive 2 vegetation species, weather events, etc. 3 Duke Energy Indiana commits to tracking CI/CMI of the self-optimizing 4 grid based on its automation savings and contribution to SAIDI/SAIFI. Duke 5 Energy Indiana is proposing to track our progress by reviewing total savings by 6 annum for minimum and maximum CI/CMI, inclusive of the target, and the 7 impact of MED and Non-MEDs. The table below is a representation of what we 8 expect to produce following the execution of the TDSIC 2.0 Workplan. 9 Table 2 – TDSIC 2.0 Reliability Impact Tracking Proposal

> **TDSIC 2.0 Reliability Impact Total Savings** Min Cl Max CI Min CMI Max CMI 2029 Target Х Х Х Х 2029 Actuals - Non MED Х Х Х Х 2029 Actuals - MED 2029 Actuals - Total Х Х Х Х Х 2029 Variance Х Impact from TDSIC SAIFI SAIDI Without MEDs Χ% Χ% Including MEDs Χ% Χ% Percent Customers fed by Automation Χ%

### 10 Q. HOW DID DUKE ENERGY INDIANA DEVELOP THE QUANTITATIVE

11

### **CUSTOMER BENEFITS OUTLINED IN YOUR TESTIMONY?**

12 A. Duke Energy subject matter experts utilized the most recent complete five-year

13 historical reliability data in conjunction with the scope of the TDSIC 2.0

- 14 programs checked against similar work in other jurisdictions. Those effects are
- 15 then calculated on the expected future reliability performance of the Indiana
- 16 system.

1	Q.	ARE THERE ANY OTHER EXPECTED BENEFITS FROM THE TDSIC
2		2.0 INVESTMENT PLAN?
3	A.	Yes. Aside from the benefits stated throughout this testimony, an additional
4		benefit is the Value of Lost Load calculated by B&V utilizing the Department of
5		Energy Interruption Cost Estimator ("ICE") calculator. See Petitioner's Exhibit
6		4-A, Appendix B.
7	Q.	DID DUKE ENERGY INDIANA INCLUDE ALL OF ITS ANNUAL
8		TRANSMISSION AND DISTRIBUTION SPENDING IN TDSIC 2.0?
9	A.	No. Duke Energy Indiana has a multitude of projects and programs that are not
10		included in TDSIC 2.0. These include, but are not limited to, projects such as
11		new customer growth, customer expansion, emergent corrective maintenance,
12		emergent power quality issues, outage restoration, vegetation management,
13		INDOT relocation projects, telecommunications make-ready, projects required by
14		local, state or federal governmental authorities, projects required by the
15		Midcontinent Independent System Operation ("MISO"), distribution and
16		transmission buildings, vehicles, and warehouses, among others.
17	Q.	PLEASE DESCRIBE HOW THE APPROACH FOR IDENTIFYING
18		ASSETS FOR REPLACEMENT IS APPROPRIATE IN THE TDSIC 2.0
19		INVESTMENT PLAN.
20	A.	As described earlier in my testimony, the Company believes that the rigorous
21		Investment Plan Analysis performed, particularly the new methodology of
22		evaluating projects methodically, with benefit to cost ratio sets a new bar for

1		TDSIC project identification. This methodology takes into account the risk
2		strategies that are still very important to the goals of any TDSIC deployment and
3		adds a value scoring process to ensure investments hold appropriate customer and
4		system value.
5	Q.	ARE THERE DUPLICATIVE ITEMS IN THE TDSIC 2.0 INVESTMENT
6		PLAN?
7	A.	No. All projects scopes are unique to a specific goal outlined in TDSIC 2.0. It
8		should be understood that there are certain items, such as transformers, regulators,
9		capacitors, reclosers and switches, that are common to both transmission and
10		distribution projects. Duke Energy Indiana's project summaries detail precisely
11		what materials are included in each project. Further, the detailed designs and
12		engineering specifications completed to date are available for review in discovery.
13		Any intervenor will have access to the engineering specifications for each project
14		in the TDSIC 2.0 plan.
15		IX. <u>CONCLUSION</u>
16	Q.	HAS DUKE ENERGY INDIANA PROVIDED THE BEST ESTIMATE OF
17		THE COSTS OF THE ELIGIBLE IMPROVEMENTS?
18	A.	Yes. As mentioned earlier in my testimony, Duke Energy Indiana has spent
19		significant time and resources putting together cost estimates for every project
20		identified within TDSIC 2.0 for all six years. We utilized the AACE standards for
21		developing TDSIC 2.0 cost estimates. We have high confidence in our estimating
22		process through utilizing the AACE standards and our historic experience. Each

1		asset identified in TDSIC 2.0 is estimated based on replacement of that specific
2		asset. No high-level budgetary estimates were utilized in creating TDSIC 2.0.
3		Further, B&V has validated that the projects provided by Duke Energy Indiana
4		are the best estimate of the cost of the eligible improvements.
5	Q.	DOES PUBLIC CONVENIENCE AND NECESSITY REQUIRE EACH
6		COMPONENT OF TDSIC 2.0?
7	A.	Yes. TDSIC 2.0 supports a significant reduction of operational risk through
8		replacement of aging infrastructure and by modernizing the distribution grid. The
9		risk profile analysis demonstrates that TDSIC 2.0 results in tangible risk reduction
10		and reliability benefits. Additionally, TDSIC 2.0 improves the operational
11		efficiency of Duke Energy Indiana's transmission and distribution system.
12		Finally, TDSIC 2.0 addresses and improves upon the overall customer experience
13		and will enable a number of customer benefits and programs in this filing and in
14		future years.
15	Q.	DO THE ESTIMATED COSTS OF TDSIC 2.0 JUSTIFY THE
16		INCREMENTAL BENEFITS OF THE PLAN?
17	A.	Yes. The Company has described both quantitative and qualitative benefits of the
18		TDSIC 2.0 Plan, as detailed in the TDSIC 2.0 Investment Plan Report, my
19		testimony and the testimonies of Mr. James Shields and Mr. Martin Dickey.
20		For example, the Investment Plan Report demonstrates that for the
21		combined transmission and distribution investments of \$1.57 billion, excluding
22		TED, O&M, and contingency, the overall transmission result has a cost to benefit

1	ratio of 3.5 and overall program value of \$2.8 billion for the \$800 million core
2	project planned investment. The overall distribution plan result has a positive cost
3	to benefit ratio of 2.1 and overall program value of \$1.6 billion for the \$775
4	million core project planned investment. Even with the full allocation of
5	contingency, the overall plan continues to show a benefit to cost ratio of 2.4.
6	As described in the Investment Plan Analysis and mentioned above, the
7	overall cost benefit ratio from TDSIC 2.0's proposed distribution investments is
8	2.1. There are several distribution programs that have less benefits to Duke
9	Energy Indiana customers as a whole, but have a significant benefit to a smaller
10	subset of our customers located in more rural, remote locations. Switchgear
11	Inspection and Replacement, Circuit Visibility and Control, and the 4 kV
12	conversion programs are all important investments in our system and will
13	positively impact those customers located in the areas in which we invest. The
14	Company believes it is important to improve and support the reliability of these
15	areas, just in the same way that it's important to the state to ensure broadband is
16	not only provided to densely populated areas, but also to rural areas.
17	By executing the combined TDSIC 2.0 Investment Plan at \$1.57 billion,
18	the program value is estimated at \$4.4 billion. All this combined demonstrates
19	that the projects and programs included in the TDSIC 2.0 Plan are reasonable,
20	necessary, and justified by significant reliability, hardening and resiliency, and
21	modernization benefits.

1	Q.	WERE PETITIONER'S EXHIBITS 2-A (JKL), 2-D (JKL), AND
2		CONFIDENTIAL EXHIBITS 2-B (JKL) AND 2-C (JKL) PREPARED BY
3		YOU OR AT YOUR DIRECTION?
4	А.	Yes, they were.
5	Q.	DOES THIS CONCLUDE YOUR PREFILED TESTIMONY?
6	A.	Yes, it does. Thank you.

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 1 of 12

	Duke Energy Indiana - TDSIC 2.0 Infra	structure Improvement	Plan	
	6 Year Summa	ry		
	Distribution System Impr	ovements		
Line No.	Project Category	2023-2028 Capital Additions	2023-2028 O&M	2023-2028 Capital & O&M Total
1	Distribution System Circuit Improvements	\$704,060,933	\$108,273,358	\$812,334,291
2	Distribution System Substation Improvements	\$176,965,506	\$41,837	\$177,007,344
3	Total Distribution - Contingency	\$155,475,254	\$0	\$155,475,254
4	Total Distribution Improvements	\$1,036,501,694	\$108,315,195	\$1,144,816,889

	Transmission System Ir	mprovements		
5	Transmission System Line Improvements	\$494,662,048	\$22,610,931	\$517,272,980
6	Transmission System Substation Improvements	\$198,038,203	\$0	\$198,038,203
7	Total Transmission - Contingency	\$122,241,221	\$0	\$122,241,221
8	Total Transmission Improvements	\$814,941,472	\$22,610,931	\$837,552,403
9	Total TDSIC 2.0 Improvements	\$1,851,443,166	\$130,926,126	\$1,982,369,292
10	Targeted Economic Development - Identified Projects	\$44,143,497	\$0	\$44,143,497
11	Targeted Economic Development - Potential Transmission Improvements	\$90,000,000	\$0	\$90,000,000
12	Total Targeted Economic Development - Contingency	\$23,672,382	\$0	\$23,672,382
13	Total Investment Plan	\$2,009,259,044	\$130,926,126	\$2,140,185,171

## 6 Year Summary By Year

	Distribution System Improvements						
Line No.	Project Category	2023 Capital Additions	2023 O&M	2023 Capital & O&M Total	2024 Capital Additions	2024 O&M	2024 Capital & O&M Total
1	Distribution System Circuit Improvements - TDSIC 2.0	\$86,070,023	\$17,975,406	\$104,045,429	\$95,838,470	\$14,658,664	\$110,497,134
2	Distribution System Substation Improvements - TDSIC 2.0	\$14,493,107	\$41,837	\$14,534,945	\$18,052,441	\$0	\$18,052,441
3	Total Distribution - Contingency - TDSIC 2.0	\$17,746,435	\$0	\$17,746,435	\$20,098,396	\$0	\$20,098,396
4	Total Distribution Improvements - TDSIC 2.0	\$118,309,565	\$18,017,244	\$136,326,809	\$133,989,307	\$14,658,664	\$148,647,971
5	Cumulative Distribution Improvements - TDSIC 2.0	\$118,309,565	\$18,017,244	\$136,326,809	\$252,298,872	\$32,675,908	\$284,974,779
6	Transmission System Improvements Transmission System Line Improvements - TDSIC 2.0	\$35,900,449	\$2,862,794	\$38,763,243	\$58,015,946	\$2,661,355	\$60,677,301
7	Transmission System Eller Improvements - TDSIC 2.0	\$26,046,227	\$2,802,754	\$26,046,227	\$47,816,638	\$2,001,333	\$47,816,638
8	Total Transmission - Contingency - TDSIC 2.0	\$10,931,766	\$0 \$0	\$10,931,766	\$18,676,338	<u> </u>	\$18,676,338
9	Total Transmission Improvements - TDSIC 2.0	\$72,878,442	\$2,862,794	\$75,741,236	\$124,508,922	\$2,661,355	\$127,170,277
10	Cumulative Transmission Improvements - TDSIC 2.0	\$72,878,442	\$2,862,794	\$75,741,236	\$197,387,364	\$5,524,149	\$202,911,513
11		¢101 188 007	¢20.000.020	¢212.000.044	¢258,408,220	617 220 010	¢275 010 240
11 12	Total T & D Improvements - TDSIC 2.0 Cumulative T & D Improvements - TDSIC 2.0	\$191,188,007 \$191,188,007	\$20,880,038 \$20,880,038		\$258,498,229 \$449,686,235	\$17,320,019 \$38,200,057	\$275,818,248 \$487,886,292

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 2 of 12

## 6 Year Summary By Year

	Distribution System Improvements						
Line No.	Project Category	2025 Capital Additions	2025 O&M	2025 Capital & O&M Total	2026 Capital Additions	2026 O&M	2026 Capital & O&M Total
1	Distribution System Circuit Improvements - TDSIC 2.0	\$119,415,156	\$16,548,331	\$135,963,487	\$126,131,284	\$17,941,286	\$144,072,570
2	Distribution System Substation Improvements - TDSIC 2.0	\$67,758,300	\$0	\$67,758,300	\$40,531,401	\$0	\$40,531,401
3	Total Distribution - Contingency - TDSIC 2.0	\$33,030,610	\$0	\$33,030,610	\$29,411,062	\$0	\$29,411,062
4	Total Distribution Improvements - TDSIC 2.0	\$220,204,066	\$16,548,331	\$236,752,397	\$196,073,747	\$17,941,286	\$214,015,033
5	Cumulative Distribution Improvements - TDSIC 2.0	\$472,502,938	\$49,224,238	\$521,727,176	\$668,576,685	\$67,165,525	\$735,742,209
6	Transmission System Improvements Transmission System Line Improvements - TDSIC 2.0	\$141,075,955	\$3,704,375	\$144,780,330	\$107,008,432	\$3,097,939	\$110,106,371
7	Transmission System Substation Improvements - TDSIC 2.0	\$19,402,294	\$3,704,375	\$19,402,294	\$38,242,832	\$3,057,555 \$0	\$38,242,832
8	Total Transmission - Contingency - TDSIC 2.0	\$15,402,254	\$0 \$0		\$25,632,576	<u> </u>	\$25,632,576
9	Total Transmission Improvements - TDSIC 2.0	\$188,797,941	\$3,704,375	\$192,502,315	\$170,883,840	\$3,097,939	\$173,981,779
10	Cumulative Transmission Improvements - TDSIC 2.0	\$386,185,305	\$9,228,524	\$395,413,828	\$557,069,144	\$12,326,463	\$569,395,607
11	Total T & D Improvements - TDSIC 2.0	\$409,002,007	\$20,252,705	\$429,254,712	\$366,957,587	\$21,039,225	\$387,996,812
12	Cumulative T & D Improvements - TDSIC 2.0	\$858,688,242	\$58,452,762		\$1,225,645,829	\$79,491,987	\$1,305,137,816

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 3 of 12

## 6 Year Summary By Year

	o real Summary by real						
	Distribution System Improvements						
Line No.	Project Category	2027 Capital Additions	2027 O&M	2027 Capital & O&M Total	2028 Capital Additions	2028 O&M	2028 Capital & O&M Total
1	Distribution System Circuit Improvements - TDSIC 2.0	\$132,418,981	\$19,685,394	\$152,104,375	\$144,187,021	\$21,464,276	\$165,651,297
2	Distribution System Substation Improvements - TDSIC 2.0	\$20,911,112	\$0	\$20,911,112	\$15,219,145	\$0	\$15,219,145
3	Total Distribution - Contingency - TDSIC 2.0	\$27,058,252	\$0	\$27,058,252	\$28,130,500	\$0	\$28,130,500
4	Total Distribution Improvements - TDSIC 2.0	\$180,388,344	\$19,685,394	\$200,073,738	\$187,536,665	\$21,464,276	\$209,000,941
5	Cumulative Distribution Improvements - TDSIC 2.0	\$848,965,029	\$86,850,919	\$935,815,948	\$1,036,501,694	\$108,315,195	\$1,144,816,889
	Transmission System Improvements						
6	Transmission System Improvements Transmission System Line Improvements - TDSIC 2.0	\$85,638,312	\$7,895,606	\$93,533,918	\$67,022,954	\$2,388,862	\$69,411,816
6 7		\$85,638,312 \$26,363,501	\$7,895,606 \$0	\$93,533,918 \$26,363,501	\$67,022,954 \$40,166,711	\$2,388,862 \$0	\$69,411,816 \$40,166,711
6 7 8	Transmission System Line Improvements - TDSIC 2.0						
6 7 8 9	Transmission System Line Improvements - TDSIC 2.0 Transmission System Substation Improvements - TDSIC 2.0	\$26,363,501	\$0	\$26,363,501 \$19,765,026	\$40,166,711	\$0	\$40,166,711
6 7 8 9 10	Transmission System Line Improvements - TDSIC 2.0 Transmission System Substation Improvements - TDSIC 2.0 Total Transmission - Contingency - TDSIC 2.0	\$26,363,501 \$19,765,026	\$0 \$0	\$26,363,501 \$19,765,026 <b>\$139,662,445</b>	\$40,166,711 \$18,915,823	\$0 \$0	\$18,915,823
	Transmission System Line Improvements - TDSIC 2.0 Transmission System Substation Improvements - TDSIC 2.0 Total Transmission - Contingency - TDSIC 2.0 Total Transmission Improvements - TDSIC 2.0 Cumulative Transmission Improvements - TDSIC 2.0	\$26,363,501 \$19,765,026 <b>\$131,766,839</b> <b>\$688,835,983</b>	\$0 \$0 <b>\$7,895,606</b> <b>\$20,222,069</b>	\$26,363,501 \$19,765,026 <b>\$139,662,445</b> <b>\$709,058,052</b>	\$40,166,711 \$18,915,823 <b>\$126,105,489</b> <b>\$814,941,472</b>	\$0 \$0 <b>\$2,388,862</b> <b>\$22,610,931</b>	\$40,166,711 \$18,915,823 <b>\$128,494,351</b> <b>\$837,552,403</b>
6 7 8 9 10 11	Transmission System Line Improvements - TDSIC 2.0 Transmission System Substation Improvements - TDSIC 2.0 Total Transmission - Contingency - TDSIC 2.0 Total Transmission Improvements - TDSIC 2.0	\$26,363,501 \$19,765,026 <b>\$131,766,839</b>	\$0 \$0 <b>\$7,895,606</b>	\$26,363,501 \$19,765,026 <b>\$139,662,445</b>	\$40,166,711 \$18,915,823 <b>\$126,105,489</b>	\$0 \$0 <b>\$2,388,862</b>	\$40,166,711 \$18,915,823 <b>\$128,494,351</b>

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 4 of 12

## 6 Year Summary By Year

	Distribution System Improvements			
Line No.	Project Category	6 Year Capital Additions	6 Year O&M	6 Year Capital & O&M Total
1	Distribution System Circuit Improvements - TDSIC 2.0	\$704,060,933	\$108,273,358	\$812,334,291
2	Distribution System Substation Improvements - TDSIC 2.0	\$176,965,506	\$41,837	\$177,007,344
3	Total Distribution - Contingency - TDSIC 2.0	\$155,475,254	\$0	\$155,475,254
4	Total Distribution Improvements - TDSIC 2.0	\$1,036,501,694	\$108,315,195	\$1,144,816,889
5	Cumulative Distribution Improvements - TDSIC 2.0	\$1,036,501,694	\$108,315,195	\$1,144,816,889
	•			
	Transmission System Improvements			
6	Transmission System Line Improvements - TDSIC 2.0	\$494,662,048	\$22,610,931	\$517,272,980
7	Transmission System Substation Improvements - TDSIC 2.0	\$198,038,203	\$0	\$198,038,203
8	Total Transmission - Contingency - TDSIC 2.0	\$122,241,221	\$0	\$122,241,221
9	Total Transmission Improvements - TDSIC 2.0	\$814,941,472	\$22,610,931	\$837,552,403
10	Cumulative Transmission Improvements - TDSIC 2.0	\$814,941,472	\$22,610,931	\$837,552,403
11	Total T & D Improvements - TDSIC 2.0	\$1,851,443,166	\$130,926,126	\$1,982,369,292
12	Cumulative T & D Improvements - TDSIC 2.0	\$1,851,443,166	\$130,926,126	\$1,982,369,292

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 5 of 12

# 6 Year Detailed Summary By Year

## **Distribution System Improvements**

						2023 Total				
Line No.	Project Category	2023 Material	2023 Labor	2023 Indirects	2023 AFUDC	Capital Additions	2023 O&M	2023 Capital and O&M	2023 Retirements	2023 Total Project
1	Distribution System Circuit Improvements	\$21,611,814	\$41,675,052	\$20,455,932	\$2,327,224	\$86,070,023	\$17,975,406	\$104,045,429	\$19,215,447	\$123,260,876
2	Distribution System Substation Improvements	\$4,985,306	\$6,790,365	\$2,101,254	\$616,182	\$14,493,107	\$41,837	\$14,534,945	\$2,359,223	\$16,894,168
3	Total Distribution Improvements	\$26,597,120	\$48,465,418	\$22,557,186	\$2,943,406	\$100,563,130	\$18,017,244	\$118,580,374	\$21,574,670	\$140,155,044
Transm	ission System Improvements									
4	Transmission System Line Improvements	\$8,213,869	\$20,891,917	\$5,863,430	\$931,233	\$35,900,449	\$2,862,794	\$38,763,243	\$3,429,486	\$42,192,728
5	Transmission System Substation Improvements	\$8,330,976	\$13,440,251	\$4,013,037	\$1,217,027	\$26,046,227	\$0	\$26,046,227	\$2,866,589	\$28,912,816
6	Total Transmission Improvements	\$16,544,845	\$34,332,168	\$9,876,467	\$2,148,261	\$61,946,675	\$2,862,794	\$64,809,469	\$6,296,075	\$71,105,544
7	Total T & D Improvements	\$43,141,965	\$82,797,586	\$32,433,653	\$5,091,666	\$162,509,806	\$20,880,038	\$183,389,843	\$27,870,745	\$211,260,588

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 6 of 12

Total T & D Improvements

# 6 Year Detailed Summary By Year

.

7

Distributi	on System Improvements						
Line No.	Project Category	2024 Material	2024 Labor	2024 Indirects	2024 AFUDC	2024 Total Capital Additions	
1	Distribution System Circuit Improvements	\$24,400,105	\$46,786,550	\$21,609,669	\$3,042,146	\$95,838,470	
2	Distribution System Substation Improvements	\$6,342,343	\$8,096,259	\$2,800,538	\$813,300	\$18,052,441	_
3	Total Distribution Improvements	\$30,742,449	\$54,882,809	\$24,410,206	\$3,855,447	\$113,890,911	
Transmiss	ion System Improvements						
4	Transmission System Line Improvements	\$12,371,231	\$34,799,480	\$9,247,730	\$1,597,506	\$58,015,946	_
5	Transmission System Substation Improvements						
		\$17,216,557	\$21,963,154	\$6,958,181	\$1,678,746	\$47,816,638	<b> </b>
6	Total Transmission Improvements	\$29,587,787	\$56,762,634	\$16,205,911	\$3,276,252	\$105,832,584	

\$60,330,236 \$111,645,443

\$40,616,117

\$7,131,698

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 7 of 12

2024 O&M	2024 Capital and O&M	2024 Retirements	2024 Total Project
\$14,658,664	\$110,497,134	\$20,983,652	\$131,480,786
\$0	\$18,052,441	\$981,149	\$19,033,589
\$14,658,664	\$128,549,575	\$21,964,801	\$150,514,375
\$2,661,355	\$60,677,301	\$8,244,755	\$68,922,056
\$0	\$47,816,638	\$2,617,636	\$50,434,273
\$2,661,355	\$108,493,939	\$10,862,391	\$119,356,330
\$17,320,019	\$237,043,513	\$32,827,191	\$269,870,705

\$219,723,494

# 6 Year Detailed Summary By Year

## **Distribution System Improvements**

Distribut	Distribution System Improvements									
Line No.	Project Category	2025 Material	2025 Labor	2025 Indirects	2025 AFUDC	2025 Total Capital Additions	2025 O&M	2025 Capital and O&M	2025 Retirements	2025 Total Project
1	Distribution System Circuit Improvements	\$31,931,771	\$56,847,172	\$27,049,867	\$3,586,346	\$119,415,156	\$16,548,331	\$135,963,487	\$23,920,905	\$159,884,392
2	Distribution System Substation Improvements	\$20,670,588	\$33,115,809	\$10,887,924	\$3,083,979	\$67,758,300	\$0	\$67,758,300	\$3,200,811	\$70,959,112
3	Total Distribution Improvements	\$52,602,358	\$89,962,981	\$37,937,791	\$6,670,325	\$187,173,456	\$16,548,331	\$203,721,787	\$27,121,716	\$230,843,504
Transmis	sion System Improvements									
4	Transmission System Line Improvements	\$20,239,503	\$92,369,757	\$24,159,173	\$4,307,522	\$141,075,955	\$3,704,375	\$144,780,330	\$12,387,550	\$157,167,880
5	Transmission System Substation Improvements	\$5,736,954	\$9,878,242	\$3,112,939	\$674,160	\$19,402,294	\$0	\$19,402,294	\$1,125,311	\$20,527,606
6	Total Transmission Improvements	\$25,976,457	\$102,247,999	\$27,272,111	\$4,981,681	\$160,478,250	\$3,704,375	\$164,182,624	\$13,512,861	\$177,695,485
7	Total T & D Improvements	\$78,578,816	\$192,210,981	\$65,209,903	\$11,652,007	\$347,651,706	\$20,252,705	\$367,904,411	\$40,634,578	\$408,538,989

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 8 of 12

# 6 Year Detailed Summary By Year

Distribution	System Improvements

Line No.	Project Category	2026 Material	2026 Labor	2026 Indirects	2026 AFUDC	2026 Total Capital Additions	2026 O&M	2026 Capital and O&M	2026 Retirements	2026 Total Project
1	Distribution System Circuit Improvements	\$37,015,298	\$54,287,933	\$30,841,467	\$3,986,586	\$126,131,284	\$17,941,286	\$144,072,570	\$27,899,702	\$171,972,272
2	Distribution System Substation Improvements	\$13,952,670	\$19,131,397	\$6,245,354	\$1,201,980	\$40,531,401	\$0	\$40,531,401	\$1,825,252	\$42,356,653
3	Total Distribution Improvements	\$50,967,968	\$73,419,330	\$37,086,821	\$5,188,566	\$166,662,685	\$17,941,286	\$184,603,971	\$29,724,954	\$214,328,925
Transmiss	ion System Improvements									
4	Transmission System Line Improvements	\$6,750,653	\$71,930,140	\$24,892,902	\$3,434,737	\$107,008,432	\$3,097,939	\$110,106,371	\$11,450,880	\$121,557,252
5	Transmission System Substation Improvements	\$13,960,263	\$17,010,487	\$5,943,877	\$1,328,205	\$38,242,832	\$0	\$38,242,832	\$1,603,854	\$39,846,686
6	Total Transmission Improvements	\$20,710,916	\$88,940,627	\$30,836,779	\$4,762,942	\$145,251,264	\$3,097,939	\$148,349,203	\$13,054,734	\$161,403,937
7	Total T & D Improvements	\$71,678,884	\$162,359,957	\$67,923,600	\$9,951,508	\$311,913,949	\$21,039,225	\$332,953,174	\$42,779,688	\$375,732,862

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 9 of 12

# 6 Year Detailed Summary By Year

U TCU	· Detailed Summary By rear							
Dist	ribution System Improvements							
						2027 Total		
						Capital		2
Line No.	Project Category	2027 Material	2027 Labor	2027 Indirects	2027 AFUDC	Additions	2027 O&M	
1	Distribution System Circuit Improvements	\$35,559,859	\$59,413,169	\$33,126,208	\$4,319,744	\$132,418,981	\$19,685,394	
2	Distribution System Substation Improvements	\$6,462,560	\$10,166,928	\$3,323,352	\$958,272	\$20,911,112	\$0	
3	Total Distribution Improvements	\$42,022,420	\$69,580,097	\$36,449,560	\$5,278,016	\$153,330,092	\$19,685,394	
Trans	smission System Improvements							
4	Transmission System Line Improvements	\$4,730,528	\$57,755,763	\$20,686,112	\$2,465,910	\$85,638,312	\$7,895,606	
5	Transmission System Substation Improvements							
		\$8,580,200	\$13,055,961	\$3,843,439	\$883,902	\$26,363,501	\$0	
6	Total Transmission Improvements	\$13,310,727	\$70,811,723	\$24,529,551	\$3,349,811	\$112,001,813	\$7,895,606	
7	Total T & D Improvements	\$55,333,147	\$140,391,820	\$60,979,110	\$8,627,828	\$265,331,906	\$27,581,001	

### Distribution System Im

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 10 of 12

	2027 Capital and O&M	2027 Retirements	2027 Total Project
	\$152,104,375	\$32,467,153	\$184,571,528
	\$20,911,112	\$870,902	\$21,782,014
	\$173,015,487	\$33,338,055	\$206,353,542
5	\$93,533,918	\$9,561,994	\$103,095,912
	\$26,363,501	\$1,622,803	\$27,986,304
	\$119,897,419	\$11,184,797	\$131,082,217
	\$292,912,906	\$44,522,852	\$337,435,758

# 6 Year Detailed Summary By Year

## **Distribution System Improvements**

Distributi	Distribution System Improvements									
						2028 Total				
						Capital		2028 Capital	2028	
Line No.	Project Category	2028 Material	2028 Labor	2028 Indirects	2028 AFUDC	Additions	2028 O&M	and O&M	Retirements	2028 Total Project
1	Distribution System Circuit Improvements	\$40,150,414	\$63,168,349	\$36,139,148	\$4,729,110	\$144,187,021	\$21,464,276	\$165,651,297	\$35,573,960	\$201,225,256
2	Distribution System Substation Improvements	\$5,399,879	\$7,109,073	\$2,252,107	\$458,085	\$15,219,145	\$0	\$15,219,145	\$761,310	\$15,980,455
3	Total Distribution Improvements	\$45,550,293	\$70,277,422	\$38,391,255	\$5,187,195	\$159,406,165	\$21,464,276	\$180,870,441	\$36,335,270	\$217,205,711
Transmiss	ion System Improvements									
4	Transmission System Line Improvements	\$1,225,822	\$47,830,418	\$16,235,784	\$1,730,930	\$67,022,954	\$2,388,862	\$66,911,816	\$6,575,512	\$73,487,328
5	Transmission System Substation Improvements									
		\$13,555,397	\$19,169,042	\$6,032,246	\$1,410,027	\$40,166,711	\$0	\$40,166,711	\$1,756,266	\$41,922,978
6	Total Transmission Improvements	\$14,781,219	\$66,999,460	\$22,268,030	\$3,140,957	\$107,189,665	\$2,388,862	\$109,578,528	\$8,331,778	\$117,910,306
7	Total T & D Improvements	\$60,331,512	\$137,276,881	\$60,659,285	\$8,328,152	\$266,595,831	\$23,853,138	\$290,448,969	\$44,667,048	\$335,116,017

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 11 of 12

## Duke Energy Indiana - T & D Infrastructure Improvement Plan 6 Year Detailed Summary By Year

## **Distribution System Improvements**

Distribut	Distribution System Improvements										
Line No.	Project Category	6 Year Total Material	6 Year Total Labor	6 Year Total Indirects	6 Year Total AFUDC	6 Year Total Capital Additions	6 Year Total O&M	6 Year Total Capital and O&M	6 Year Total Retirements	6 Year Total Project	
1	Distribution System Circuit Improvements	\$190,669,261	\$322,178,225	\$169,222,291	\$21,991,157	\$704,060,933	\$108,273,358	\$812,334,291	\$160,060,819	\$972,395,110	
2	Distribution System Substation Improvements	\$57,813,347	\$84,409,831	\$27,610,529	\$7,131,799	\$176,965,506	\$41,837	\$177,007,344	\$9,998,648	\$187,005,992	
3	Total Distribution Improvements	\$248,482,608	\$406,588,056	\$196,832,819	\$29,122,956	\$881,026,440	\$108,315,195	\$989,341,635	\$170,059,466	\$1,159,401,101	
Transmiss	sion System Improvements										
4	Transmission System Line Improvements	\$53,531,606	\$325,577,475	\$101,085,130	\$14,467,837	\$494,662,048	\$22,610,931	\$517,272,980	\$51,650,177	\$566,423,156	
5	Transmission System Substation Improvements	\$67,380,346	\$94,517,136	\$29,903,718	\$7,192,067	\$198,038,203	\$0	\$198,038,203	\$11,592,460	\$209,630,662	
6	Total Transmission Improvements	\$120,911,952	\$420,094,611	\$130,988,849	\$21,659,904	\$692,700,251	\$22,610,931	\$715,311,182	\$63,242,636	\$776,053,819	
7	Total T & D Improvements	\$369,394,560	\$826,682,667	\$327,821,668	\$50,782,860	\$1,573,726,691	\$130,926,126	\$1,704,652,817	\$233,302,103	\$1,935,454,920	

### PETITIONER'S EXHIBIT 2-A (JKL) DEI TDSIC 2.0 PAGE 12 of 12

Duke Energy Indiana -	T & D Infrastructure Improvement

Plan, Distribution System Capital Improvements

Line No.	Distribution Circuit Upgrade Projects	2023 Material	2023 Labor	2023 Indirects	2023 AFUDC	2023 Total Capital Additions	2023 Project O&M	2023 Capital & O&M Total	2023 Retirements	2023 Total Project
1	4kV Conversion									
2	Automated Lateral Device (ALD)									
3	Capacitor Automation									
4	Circuit Sectionalization									
5	Circuit Segmentation									
6	Circuit Visibility & Control									
7	Declared Circuits									
8	Deteriorated Conductor									
9	General Switchgear									
10	GLT									
11	Inaccessible R/W	\$0	\$0	\$0	\$0	\$0		\$0		\$
12	Limited Access Road Crossing	\$0	\$0	\$0	\$0	\$0		\$0		\$
13	Recloser Replacement Program									
14	SMEI									
5	SOG - Circuit Connectivity									
16	SOG - Recloser									
17	Targeted Undergrounding (TUG)									
18	Underground Cable Rehabilitation									
9	ιννς			-	[]					
20	IVVC Circuit Conditioning Capacitor									
21	IVVC Circuit Conditioning Reconductor									
22	IVVC Circuit Conditioning Regulator	\$0	\$0	\$0	\$0	\$0		\$0		\$0
23	IVVC EOL Voltage Sensors									
24	IVVC Line Voltage Regulator Control Replacement									

Plan, Distribution System Capital Improvements

PPETITIONER'S EXHIBIT 2-B (JKL)

ine No.	Distribution Circuit Upgrade Projects	2024 Material	2024 Labor	2024 Indirects	2024 AFUDC	2024 Total Capital Additions	2024 Project O&M	2024 Capital & O&M Total	2024 Retirements	2024 Total Project
1	4kV Conversion									
2	Automated Lateral Device (ALD)									
3	Capacitor Automation									
4	Circuit Sectionalization									
5	Circuit Segmentation									
6	Circuit Visibility & Control									
7	Declared Circuits									
8	Deteriorated Conductor									
9	General Switchgear									
10	GLT									
11	Inaccessible R/W	\$0	\$0	\$0	\$0	\$0		\$0		\$0
12	Limited Access Road Crossing							P		
13	Recloser Replacement Program									
14	SMEI									
15	SOG - Circuit Connectivity									
16	SOG - Recloser									
7	Targeted Undergrounding (TUG)									
8	Underground Cable Rehabilitation									
19	ιννς									
20	IVVC Circuit Conditioning Capacitor									
21	IVVC Circuit Conditioning Reconductor	6								
2	IVVC Circuit Conditioning Regulator	\$0	\$0	\$0	\$0	\$0	12.5	\$0		\$0
and I	IVVC EOL Voltage Sensors	\$								
23										

Duke Energy Indiana - T & D Infrastructure Improvement Plan, Distribution System Capital Improvements PETITIONER'S EXHIBIT 2-B (JKL)

ine No.	Distribution Circuit Upgrade Projects	2025 Material	2025 Labor	2025 Indirects	2025 AFUDC	2025 Total Capital Additions	2025 Project O&M	2025 Capital & O&M Total	2025 Retirements	2025 Total Project
1	4kV Conversion									
2	Automated Lateral Device (ALD)			_						
3	Capacitor Automation	\$0	\$0	\$0	\$0	\$0		\$0		\$0
4	Circuit Sectionalization									
5	Circuit Segmentation									
6	Circuit Visibility & Control									
7	Declared Circuits									
8	Deteriorated Conductor									
9	General Switchgear									
10	GLT									
11	Inaccessible R/W									
12	Limited Access Road Crossing									
13	Recloser Replacement Program									
14	SMEI									
15	SOG - Circuit Connectivity									
16	SOG - Recloser									
17	Targeted Undergrounding (TUG)									
18	Underground Cable Rehabilitation									
19	IVVC									
20	IVVC Circuit Conditioning Capacitor									
21	IVVC Circuit Conditioning Reconductor									
22	IVVC Circuit Conditioning Regulator									
23	IVVC EOL Voltage Sensors									
24	IVVC Line Voltage Regulator Control Replacement									
25		\$29,860,855	\$51,516,720	\$25,572,474	\$3,263,092	\$110,213,140	\$16,120,247	\$126,333,387	\$23,268,851	\$149,602,239

Duke Energy Indiana - T & D Infrastructure Improvement Plan, Distribution System Capital Improvements PETITIONER'S EXHIBIT 2-B (JKL)

Line No.	Distribution Circuit Upgrade Projects	2026 Material	2026 Labor	2026 Indirects	2026 AFUDC	2026 Total Capital Additions	2026 Project O&M	2026 Capital & O&M Total	2026 Retirements	2026 Total Projec
1	4kV Conversion									
2	Automated Lateral Device (ALD)						÷		-	
3	Capacitor Automation	\$0	\$0	\$0	\$0	\$0		\$0	1	\$0
4	Circuit Sectionalization									
5	Circuit Segmentation									
6	Circuit Visibility & Control									
7	Declared Circuits									
8	Deteriorated Conductor									
9	General Switchgear									
10	GLT									
11	Inaccessible R/W									
12	Limited Access Road Crossing									
13	Recloser Replacement Program									
14	SMEI									
15	SOG - Circuit Connectivity									
16	SOG - Recloser									
17	Targeted Undergrounding (TUG)									
18	Underground Cable Rehabilitation									
19	IVVC						6			i.
20	IVVC Circuit Conditioning Capacitor									
21	IVVC Circuit Conditioning Reconductor									
22	IVVC Circuit Conditioning Regulator									
23	IVVC EOL Voltage Sensors									
24	IVVC Line Voltage Regulator Control Replacement									
25		\$35,880,787	\$52,952,231	\$30,206,326	\$3,971,934	\$123,011,278	\$17,754,669	\$140,765,947	\$27,579,670	\$168,345,617

Duke Energy Indiana - T & D Infrastructure Improvement Plan, Distribution System Capital Improvements PETITIONER'S EXHIBIT 2-B (JKL)

ine No.	Distribution Circuit Upgrade Projects	2027 Material	2027 Labor	2027 Indirects	2027 AFUDC	2027 Total Capital Additions	2027 Project O&M	2027 Capital & O&M Total	2027 Retirements	2027 Total Project
1	4kV Conversion									
2	Automated Lateral Device (ALD)									
3	Capacitor Automation	\$0	\$0	\$0	\$0	\$0		\$0		\$0
4	Circuit Sectionalization									
5	Circuit Segmentation									
6	Circuit Visibility & Control									
7	Declared Circuits									
8	Deteriorated Conductor									
9	General Switchgear									
0	GLT									
1	Inaccessible R/W	\$0	\$0	\$0	\$0	\$0		\$0	1	\$0
2	Limited Access Road Crossing	· · · · · · · · · · · · · · · · · · ·								
3	Recloser Replacement Program									
4	SMEI									
5	SOG - Circuit Connectivity									
6	SOG - Recloser									
7	Targeted Undergrounding (TUG)									
8	Underground Cable Rehabilitation									
9	IVVC									
0	IVVC Circuit Conditioning Capacitor									
1	IVVC Circuit Conditioning Reconductor									
2	IVVC Circuit Conditioning Regulator									
3	IVVC EOL Voltage Sensors									
4	IVVC Line Voltage Regulator Control Replacement									

Duke Energy	Indiana - T	& D In	frastructure	Improvement
-------------	-------------	--------	--------------	-------------

Plan, Distribution System Capital Improvements

DEI TDSIC 2.0

ine No.	Distribution Circuit Upgrade Projects	2028 Material	2028 Labor	2028 Indirects	2028 AFUDC	2028 Total Capital Additions	2028 Project O&M	2028 Capital & O&M Total	2028 Retirements	2028 Total Project
1	4kV Conversion									
2	Automated Lateral Device (ALD)									
3	Capacitor Automation	\$0	\$0	\$0	\$0	\$0		\$0	(mmm)	\$0
4	Circuit Sectionalization									
5	Circuit Segmentation									
6	Circuit Visibility & Control									
7	Declared Circuits									
8	Deteriorated Conductor									
9	General Switchgear									
10	GLT									
11	Inaccessible R/W									
12	Limited Access Road Crossing									
13	Recloser Replacement Program									
14	SMEI									
15	SOG - Circuit Connectivity									
16	SOG - Recloser									
17	Targeted Undergrounding (TUG)									
8	Underground Cable Rehabilitation									
19	IVVC									
20	IVVC Circuit Conditioning Capacitor									
21	IVVC Circuit Conditioning Reconductor									
22	IVVC Circuit Conditioning Regulator									
23	IVVC EOL Voltage Sensors									
24	IVVC Line Voltage Regulator Control Replacement									

Duke Energy Indiana - T & D Infrastructure Improvement Plan, Distribution System Capital Improvements PETITIONER'S EXHIBIT 2-8 (JKL)

DEI TDSIC 2.0

Line No.	Distribution Circuit Upgrade Projects	6 Year Total Material	6 Year Total Labor	6 Year Total Indirects	6 Year Total AFUDC	6 Year Total Capital Additions	6 Year Total Project O&M	6 Year Total Capital & O&M Total	6 Year Total Retirements	6 Year Total Project
1	4kV Conversion									
2	Automated Lateral Device (ALD)									
3	Capacitor Automation									
4	Circuit Sectionalization									
5	Circuit Segmentation									
6	Circuit Visibility & Control									
7	Declared Circuits									
8	Deteriorated Conductor									
9	General Switchgear									
10	GLT									
11	Inaccessible R/W									
12	Limited Access Road Crossing									
13	Recloser Replacement Program									
14	SMEI									
15	SOG - Circuit Connectivity									
16	SOG - Recloser									
17	Targeted Undergrounding (TUG)									
18	Underground Cable Rehabilitation									
19	IVVC									
20	IVVC Circuit Conditioning Capacitor									
21	IVVC Circuit Conditioning Reconductor									
22	IVVC Circuit Conditioning Regulator									
23	IVVC EOL Voltage Sensors									
24	IVVC Line Voltage Regulator Control Replacement									
25		\$186,031,040	\$311,940,390	\$165,796,073	\$21,509,841	\$685,277,343	\$105,285,956	\$790,563,299	\$156,267,436	\$946,830,73

#### PETITIONER'S EXHIBIT 2-C IS FILED SEPARATELY ON CD-ROM DUE TO SIZE

#### THE CD ROM IS AVAILABLE FOR VIEWING BY THE PUBLIC BY CONTACTING THE COMMISSION



# The Economic Effects of Duke Energy's Planned Transmission and Distribution System Investments



**KELLEY SCHOOL OF BUSINESS** 

INDIANA UNIVERSITY Indiana Business Research Center Prepared for

# The Economic Effects of Duke Energy's Planned Transmission and Distribution System Investments

November 2021

Prepared for Duke Energy By Indiana Business Research Center, Kelley School of Business, Indiana University

## **Table of Contents**

EXECUTIVE SUMMARY	2
ESTIMATES OF ECONOMIC CONTRIBUTIONS	3
Economic Effects of Duke Energy's Investments in Indiana	
Economic Effects of Transmission System Investments	5
Economic Effects of Distribution System Investments Total Effects of Duke Energy's Transmission and Distribution System Investments	6 6
Economic Effects of Investment Plan in Duke Energy's Service Area Economic Effects of Transmission System Investments	8 8
Economic Effects of Distribution System Investments	9
Total Effects of Duke Energy's Transmission and Distribution System Investments	9
Appendix	12
Methodology and Assumptions	12
Key Terms	12
About IMPLAN Economic Modeling Software	13
Index of Figures Figure 1: Duke Energy's Projected Annual Spending for Electric Transmission and Distribution System Upgrades	3
Figure 2: Duke Energy Service Area in Indiana	4
Figure 3: Indiana—Annual Total Employment Effects of Duke Energy Spending by Investment Type	7
Figure 4: Indiana—Annual Total GDP Effects of Duke Energy Spending by Investment Type	8
Figure 5: Duke Energy Service Area—Annual Total Employment Effects of Duke Energy Spending by Investment Type	10
Figure 6: Duke Energy Service Area—Annual Total GDP Effects of Duke Energy Spending by Investment Type	11
Index of Tables Table 1: Indiana—Average Annual Economic Contributions of Duke Energy T&D System Investments, 2023 to 2028	2
Table 2: Indiana—Average Annual Economic Contributions of Duke Energy's Transmission System Investments, 2023 to 2028	
Table 3: Indiana—Average Annual Economic Contributions of Duke Energy's Distribution System Investments, 2023 to 2028	
Table 4: Indiana—Average Annual Economic Contributions of Duke Energy's Total T&D System Investments, 2023 to 2028	
Table 5: Duke Energy Service Area—Average Annual Economic Contributions of Duke Energy's Transmission System Investments, 2023 to 2028	
Table 6: Duke Energy Service Area—Average Annual Economic Contributions of Duke Energy's Distribution System Investments, 2023 to 2028	9
Table 7: Duke Energy Service Area—Average Annual Economic Contributions of Duke Energy's Total T&D System Investments, 2023 to 2028	9

## **Executive Summary**

Duke Energy has prepared a plan to invest more than \$1.7 billion over the next six years to upgrade the electric transmission and distribution (T&D) system throughout its Indiana service area. These investments are designed to modernize the T&D system and provide a more reliable, efficient, and safe service for Duke Energy customers. In addition to these core benefits, Duke Energy's investments will also have secondary effects by generating additional economic activity in the state.

To estimate the economic effects of this plan, Duke Energy partnered with the Indiana Business Research Center (IBRC) at Indiana University's Kelley School of Business to conduct an analysis of these activities and measure the economic ripple effects that this investment will generate both within Duke Energy's service area as well as throughout the state of Indiana.

The headline findings from this analysis show that Duke Energy's approximately \$1.7 billion investment over this six-year period will support an estimated 1,270 jobs annually in Indiana worth \$172.9 million in compensation (i.e., pay and benefits) per year (see **Table 1**). In terms of the broader economy, Duke Energy's activities will contribute an estimated average of \$215.0 million to the state's gross domestic product (GDP) annually over the life of the plan. This increased economic activity will also generate roughly \$4.3 million per year in state and local government revenues.

Over the duration of this project, Duke Energy's investments will contribute roughly \$1.04 billion in compensation in Indiana and nearly \$1.29 billion in GDP.

#### **Ripple** Total **Multiplier** Direct Effects Effects Effects 770 500 1,270 1.65 Employment (FTE) \$148.3 \$24.6 \$172.9 1.17 Employee Compensation (millions, 2021 \$) \$173.8 \$41.2 \$215.0 1.24 GDP (millions, 2021 \$) State and Local Tax Revenue (millions, 2021 \$) \$4.3

#### Table 1: Indiana—Average Annual Economic Contributions of Duke Energy T&D System Investments, 2023 to 2028

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software


When we narrow our focus to Duke Energy's service area in Indiana, these average annual economic effects amount to a total of 1,040 jobs, approximately \$159 million in compensation and more than \$190 million in GDP.

The report that follows will provide more detail on these findings, as well as outline the methodology used to produce these estimates.

## **Estimates of Economic Effects**

**Figure 1** outlines Duke Energy's expected spending over the next six years to upgrade and modernize its electric T&D system in Indiana. Duke Energy plans to invest an average of \$284 million per year over this period, with peak spending in 2023 when expenditures will reach \$316 million. In all, Duke Energy's investment plan calls for slightly more than \$1.7 billion in capital investment over this span.

### Figure 1: Duke Energy's Projected Annual Spending for Electric Transmission and Distribution System Upgrades



Source: Duke Energy

Duke Energy's investments will take place throughout its Indiana service area, which covers 69 of the state's 92 counties (see **Figure 2**). As with any economic activity, some portion of supply-chain spending associated with Duke Energy's investments will leak outside of the local economy to contractors, manufacturers and service providers that are located elsewhere.

Given that upgrading and modernizing an electric T&D system requires a great deal of highly specialized equipment and material, as well as a specialized labor force, Duke Energy estimates that roughly 73 percent of its investment dollars—or \$1.24 billion over the six-year period—will go to contractors and vendors outside of Indiana. Within the framework of economic impact analysis, this "non-local" spending is considered a leakage and much of it does not factor into the economic contributions of Duke Energy's investments discussed in this report.

One exception to this rule involves the spending of workers who reside outside of the region of analysis (whether it be Indiana or the Duke Energy service area). The compensation of these workers cannot be treated as new household income since most of their spending will occur back in

their local communities. However, their income while working on these projects is not a total economic leakage since they will spend some their earnings in the local area when they are on the job. Therefore, the research team treats the economic activity generated by out-of-region workers as something akin to visitor spending for the purposes of this analysis (see the methodology for a detailed description).



#### Figure 2: Duke Energy Service Area in Indiana

In terms of local expenditures, Duke Energy expects to spend an average of \$77.1 million per year in Indiana over the life of this plan. In the terminology of economic impact analysis, these local expenditures and the associated employment describe the "direct effects" of Duke Energy's

investments on the local economy. The benefits of these investments do not end there, however. The additional economic activity generated by these direct effects—the supply chain purchases from other businesses in the area along with the household spending of workers engaged in these T&D system improvements—cascade throughout the local economy.

To estimate these so-called economic "ripple effects," the IBRC used the IMPLAN economic modeling software to conduct an input-output analysis for Duke Energy's investment plan. This widely used software relies on a variety of secondary data sources to build economic models that are tailored to reflect the unique industry mix of any given geographic area (the IBRC constructed separate models for the Duke Energy service area and Indiana for this study). The ripple effect estimates derived from this analysis combine with the direct effects to describe the full economic contributions of Duke Energy's investments.

It is important to point out that the findings presented in this report only describe the ways in which Duke Energy's investments will affect the state or regional economies. This analysis does not constitute a cost-benefit analysis or net economic impact statement that balances the economic effects presented here against any effects caused by potential rate increases.

# Economic Effects of Duke Energy's Investments in Indiana

Of Duke Energy's \$1.7 billion total investment, roughly \$711.1 million will be dedicated to improvements in its transmission system while the remaining \$992.4 million will go towards upgrading its distribution infrastructure. The following tables will show the estimated economic effects in Indiana of each of these components, as well as for the project as a whole.

#### **Economic Effects of Transmission System Investments**

The spending associated with the transmission system improvements will support an estimated 370 direct jobs per year in the state over the life of the project. Along with these direct employment effects, this increased economic activity will support an additional 220 local ripple effect jobs per year resulting from supply chain purchases and the household spending associated with these direct jobs (see **Table 2**). This brings the full employment footprint of Duke Energy's planned transmission system investments to an estimated 590 jobs per year on average between 2023 and 2028. This total employment impact will combine to produce an estimated \$81.4 million annually in total compensation.

A helpful way to interpret these impacts is to look at the multipliers. The ratio of direct jobs to total jobs, for instance, gives a ratio of 1.59, meaning that every job directly tied to these transmission system improvements support another 0.59 jobs with other employers in the area (or every 10 direct jobs support nearly 6 additional jobs elsewhere in the state). The compensation multiplier of 1.14 suggests that every dollar of direct payroll generates an additional \$0.14 in compensation with other local employers.

In terms of total economic activity, the effect of these transmission system investments will combine to contribute an estimated \$100.5 million per year to the state's gross domestic product (GDP) over

the six-year period. The multiplier of 1.20 indicates that every dollar of GDP directly generated by these investments will trigger an additional \$0.20 in economic activity in the state.

Duke Energy's transmission system investments will also generate state and local government revenues. The IMPLAN model estimates the tax revenues from business profits, indirect business taxes (e.g., sales, property and excise taxes), personal taxes (e.g., income and property taxes), and employer and employee contributions to social insurance. Fueled primarily by sales and property taxes, this economic activity will generate an estimated \$1.8 million per year in state and local government revenue.

Table 2: Indiana—Average Annual Economic Contributions of Duke Energy'sTransmission System Investments, 2023 to 2028

	Direct Effects	Ripple Effects	Total Effects	Multiplier
Employment	370	220	590	1.59
Compensation (millions, 2021 \$)	\$71.4	\$10.0	\$81.4	1.14
GDP (millions, 2021 \$)	\$83.6	\$16.9	\$100.5	1.20
State and Local Tax Revenue (millions, 2021 \$)	—	_	\$1.8	_

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

#### **Economic Effects of Distribution System Investments**

Switching our view to Duke Energy's planned distribution system upgrades, the spending tied to these activities will create an average of 400 direct jobs per year over the course of the project while also supporting an additional 280 ripple effect jobs annually, which brings the full employment effect to a total of 680 jobs per year (see **Table 3**). Furthermore, the average annual GDP impact of these investments will be an estimated \$114.5 million.

Table 3: Indiana—Average Annual Economic Contributions of Duke Energy's Distribution
System Investments, 2023 to 2028

	Direct Effects	Ripple Effects	Total Effects	Multiplier
Employment	400	280	680	1.70
Compensation (millions, 2021 \$)	\$76.9	\$14.5	\$91.5	1.19
GDP (millions, 2021 \$)	\$90.2	\$24.3	\$114.5	1.27
State and Local Tax Revenue (millions, 2021 \$)			\$3.4	

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

#### Total Effects of Duke Energy's Transmission and Distribution System Investments

Looking at Duke Energy's T&D system investments as a whole, the average annual total employment effect in Indiana rises to 1,270 jobs worth nearly \$173 million in compensation per year (see **Table 4**). The employment multiplier of 1.65 indicates that every 10 jobs directly created by Duke Energy's investments support nearly seven additional jobs in the state. This activity will also contribute an average of \$215 million per year to the state's GDP


	Direct Effects	Ripple Effects	Total Effects	Multiplier
Employment (FTE)	770	500	1,270	1.65
Employee Compensation (millions, 2021 \$)	\$148.3	\$24.6	\$172.9	1.17
GDP (millions, 2021 \$)	\$173.8	\$41.2	\$215.0	1.24
State and Local Tax Revenue (millions, 2021 \$)			\$4.3	

Table 4: Indiana—Average Annual Economic Contributions of Duke Energy's Total T&D System Investments, 2023 to 2028

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

On a year-by-year basis, the largest economic effects will be seen right out of the gate with a total employment footprint estimated at 1,440 jobs in the state in 2023 (see **Figure 3**). The employment effect in 2025 will be nearly as large with an estimated total of 1,430 jobs. The employment effects will be slightly smaller in the second half of the project timeline.

### Figure 3: Indiana—Annual Total Employment Effects of Duke Energy Spending by Investment Type



Note: Total effects are the sum of direct effects and ripple effects

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

GDP effects in the state will follow a similar path with the largest contributions seen in 2023 and 2025 (see **Figure 4**). All told, Duke Energy's investments will generate an estimated total of \$1.29 billion in GDP in Indiana over the life of the project.




Figure 4: Indiana—Annual Total GDP Effects of Duke Energy Spending by Investment Type

Note: Total effects are the sum of direct effects and ripple effects

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

# Economic Effects of Investment Plan in Duke Energy's Service Area

All numbers presented to this point reflect the estimated economic effects of Duke Energy's investments on the entire state of Indiana. As referenced in **Figure 2**, however, Duke Energy's service area covers 69 of the state's 92 counties, and all the work associated with this investment plan will occur in that service area. The following tables and graphics will highlight the economic effects of these investments in this service area alone.

Note that because these investments will engage contractors and vendors that are based in Indiana but outside of the Duke Energy service area, the economic ripple effects for the state are always greater than the ripple effects in the smaller service area. Also note that the following effects are a subset of the statewide effects and are not to be added to the numbers for Indiana.

#### **Economic Effects of Transmission System Investments**

With employment ripple effects estimated at 130 jobs, Duke Energy's planned transmission system investments will have a total employment effect of 500 jobs per year on average in its service area (see **Table 5**). Furthermore, these investments will generate an annual average of nearly \$76 million in employee compensation and more than \$90 million in GDP over the life of the project.

	Direct Effects	Ripple Effects	Total Effects	Multiplier
Employment (FTE)	370	130	500	1.35
Compensation (millions, 2021 \$)	\$71.4	\$4.6	\$75.9	1.06
GDP (millions, 2021 \$)	\$82.2	\$8.2	\$90.4	1.10
State and Local Tax Revenue (millions, 2021 \$)	_	—	\$1.0	_

Table 5: Duke Energy Service Area—Average Annual Economic Contributions of Duke Energy's Transmission System Investments, 2023 to 2028

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

#### **Economic Effects of Distribution System Investments**

Regarding Duke Energy's planned distribution system upgrades, the spending tied to these activities will create an average of 540 jobs per year in its service area between 2023 and 2028 (see **Table 6**). Furthermore, the average annual GDP impact of these investments will be nearly \$100 million.

Table 6: Duke Energy Service Area—Average Annual Economic Contributions of Duke
Energy's Distribution System Investments, 2023 to 2028

	Direct Effects	Ripple Effects	Total Effects	Multiplier
Employment	400	140	540	1.35
Compensation (millions, 2021 \$)	\$76.9	\$6.3	\$83.3	1.08
GDP (millions, 2021 \$)	\$88.6	\$11.0	\$99.6	1.12
State and Local Tax Revenue (millions, 2021 \$)			\$1.4	

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

#### Total Effects of Duke Energy's Transmission and Distribution System Investments


All told, Duke Energy's T&D system investments will have an estimated average annual employment effect in this region of approximately 1,040 jobs per year along with nearly \$159 million in compensation per year (see **Table 7**). The employment multiplier of 1.35 indicates that every 10 jobs directly created by Duke Energy's investments will support 3.5 additional jobs in the region. This activity will also contribute an average of \$190 million per year to the region's GDP.


### Table 7: Duke Energy Service Area—Average Annual Economic Contributions of Duke Energy's Total T&D System Investments, 2023 to 2028

	Direct Effects	Ripple Effects	Total Effects	Multiplier
Employment (FTE)	770	270	1,040	1.35
Employee Compensation (millions, 2021 \$)	\$148.3	\$10.9	\$159.2	1.07
GDP (millions, 2021 \$)	\$170.8	\$19.2	\$190.0	1.11
State and Local Tax Revenue (millions, 2021 \$)			\$2.4	

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

**Figure 5** highlights the total estimated employment effects in the service area for each year of the investment plan. The peak employment effect will be in 2023 and 2025 at an estimated 1,200 jobs in the region while 2026 and 2028 represents the lows at 930 jobs.






Note: Total effects are the sum of direct effects and ripple effects

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

The total GDP effects in the region will range from roughly \$219 million in 2025 to \$171 million in 2026 and 2028 (see **Figure 6**). In all, Duke Energy's investments will generate an estimated total of \$1.14 billion in GDP in its service area over the life of the project.

Figure 6: Duke Energy Service Area—Annual Total GDP Effects of Duke Energy Spending by Investment Type



Note: Total effects are the sum of direct effects and ripple effects

Source: IBRC, using data from Duke Energy and the IMPLAN economic modeling software

# Appendix

### **Methodology and Assumptions**

Duke Energy provided the research team with estimated annual expenditures for the years 2023 through 2028. For each category of spending, Duke Energy provided detail on the share of the total spending that will be dedicated to equipment and materials, services, and labor. Duke Energy also provided the research team with assumptions on the geographic location of vendors and contractors. This type of detail helps to improve the accuracy of these estimates. For instance, if Duke Energy knows that some of the equipment and materials they will purchase for this project will be supplied by out of state vendors, then researchers can treat this spending as an economic leakage from the geographic area of analysis, and therefore not include it in the estimates of economic effects. This same approach is applied to the compensation earned by the labor that Duke Energy expects to engage in this project. For the share of the labor force on this project that is expected to reside in the region of analysis, researchers modeled this amount of compensation as typical household income since workers who live in the region will spend most of their earnings locally.

The spending of workers from outside the region, however, is more akin to visitor spending. Workers who live in Indiana but outside of a Duke Energy service area may commute to the work site on a daily basis but only purchase lunch and gasoline in the region (for these workers, the estimated effects of their typical household spending are captured in the statewide numbers but not in the figures for the service area). Out-of-state workers may stay in a local motel and will spend more on food and other purchases. However, most of their income is a considered a leakage since it will be spent in another state.

For out-of-region workers, the research team estimated the average annual number of person-days they will spend in the region of analysis. To these person-day totals, the research team applied the daily dollar amounts for purchases that are listed below. Researchers assumed that workers who lived in Indiana but outside of the relevant region of analysis did not spend any money on lodging and spent half of all other listed dollar amounts in the relevant region on a daily basis.

- Lodging \$48/day
- Restaurants \$25.27/day
- Food Stores \$25.27/day
- General Merchandise Stores \$4.23/day
- Gas Stations \$4.23/day

Researchers derived these spending amounts by reviewing lodging rates and the U.S. General Services Administration's per diem rates for Indiana.

### **Key Terms**

**Direct Effects:** Refers to the increase in final demand or employment in a given area that can be attributed specifically to Duke Energy's investment plan.

**Ripple Effects:** A combination of the indirect and induced effects generated by the direct effects. Indirect effects measure the change in dollars or employment caused when Duke Energy increases its purchase of goods and services from suppliers and, in turn, those suppliers purchase more inputs and so on throughout the economy. Induced effects reflect the changes—whether in dollars or employment— that result from the household spending of direct workers, along with the employees in the supply chain.

**Total Effects:** The total of all economic effects is the sum of the direct and ripple effects. The IMPLAN model also tracks the tax effects associated with all the transactions and economic activity associated with the direct and ripple effects. For example, household spending at retailers generates state sales tax. In addition, those retailers also pay property taxes to local governments. As a result, this analysis was also able to estimate the state and local government tax flows.

**Multiplier:** The multiplier is the magnitude of the economic response in a particular geographic area associated with a change in the direct effects. The multiplier equals the total effect divided by the direct effect.

**GDP:** Also known as value added, GDP is a measure of the economic activity generated by a company, industry, state, nation, etc. GDP is the difference between total output (i.e., sales) and the cost of production inputs. GDP consists of four components: employee compensation, proprietor income, other property income and indirect business tax.

### About IMPLAN Economic Modeling Software

IMPLAN is built on a mathematical input-output (I-O) model that expresses relationships between sectors of the economy in a chosen geographic location. In expressing the flow of dollars through a regional economy, the input-output model assumes fixed relationships between producers and their suppliers based on demand. It also omits any dollars spent outside of the regional economy—say, by producers who import raw goods from another area, or by employees who commute and do their household spending elsewhere.

The idea behind input-output modeling is that the inter-industry relationships within a region largely determine how that economy will respond to economic changes. In an I-O model, the increase in demand for a certain product or service causes a multiplier effect, layers of effect that come in a chain reaction. Increased demand for a product affects the producer of the product, the producer's employees, the producer's suppliers, the supplier's employees, and so on—ultimately generating a total effect in the economy that is greater than the initial change in demand. For instance, say demand for Andersen Windows' wood window products increases. Sales grow, so Andersen has to hire more people, and the company may buy more from local vendors, and those vendors in turn have to hire more people ... who in turn buy more groceries. The ratio of that overall effect to the initial change is called a regional multiplier and can be expressed like this:

(Direct Effect + Indirect Effects + Induced Effects) / (Direct Effect) = Multiplier

Multipliers are industry- and region-specific. Each industry has a unique output multiplier, because each industry has a different pattern of purchases from firms inside and outside of the regional economy. (The output multiplier is in turn used to calculate income and employment multipliers.)

Estimating a multiplier is not the end goal of IMPLAN users. Most wish to estimate other numbers and get answers to questions such as: How many jobs will this new firm produce? How much will the local economy be affected by this plant closing? What will the effects be of an increase in

product demand? Based on those user choices, IMPLAN software constructs "social accounts" to measure the flow of dollars from purchasers to producers within the region. The data in those social accounts will set up the precise equations needed to finally answer those questions users have—about the impact of a new company, a plant closing or greater product demand—and yield the answers.

IMPLAN constructs its input-output model using aggregated production, employment and trade data from local, regional and national sources, such as the U.S. Census Bureau's annual *County Business Patterns* report and the U.S. Bureau of Labor Statistics' annual report called *Covered Employment and Wages*. In addition to gathering enormous amounts of data from government sources, the company also estimates some data where they haven't been reported at the level of detail needed (county-level production data, for instance), or where detail is omitted in government reports to protect the confidentiality of individual companies whose data would be easily recognized due to a sparse population of businesses in the area.

The IBRC's analysts have attended advanced training in the use of the IMPLAN modeling software. The estimates that the IBRC analysts generate are scrutinized closely to ensure that they are accurate and reflect the most trustworthy application of the modeling software. In all instances, the most conservative estimation assumptions and procedures are used to produce the IMPLAN results.

#### VERIFICATION

I hereby verify under the penalties of perjury that the foregoing representations are true to the best of my knowledge, information and belief.

Signed: Jeremy K. Lewis

Dated: November 23, 2021